


**HYDRO POWER SCHEMES
AND
LARGE DAMS
IN
AUSTRIA**

1985



HYDRO POWER SCHEMES AND LARGE DAMS IN AUSTRIA

No. 29
of the Series
"Die Talsperren Österreichs"
Editor: Helmut Simmler

Published by
ÖSTERREICHISCHE STAUBECKENKOMMISSION
ÖSTERREICHISCHER WASSERWIRTSCHAFTSVERBAND
ÖSTERREICHISCHES NATIONALKOMITEE FÜR TALSPERREN
Vienna 1985

All rights reserved
© 1985 by the Österreichischer Wasserwirtschaftsverband
An der Hülben 4, A-1010 Vienna, Austria
Printed by Druckerei G. Grasl, A-2540 Bad Vöslau

Eigenverlag des Österreichischen Wasserwirtschaftsverbandes, Wien

In Kommission bei Springer-Verlag Wien - New York

ISBN 3-211-81875-8 Springer-Verlag Wien - New York
ISBN 0-387-81875-8 Springer-Verlag New York - Wien

Preface

For eight decades the construction of large dams and large river barrages in Austria has almost exclusively been undertaken by electricity supply companies, which at present produce approximately 70 per cent of the country's power requirements from hydro. It is only for the power stations on the Danube that the government pays a subsidy to construction costs as a compensation for the resulting improvement of navigation on this important trans-European waterway. The multi-purpose benefits from the large Alpine seasonal-storage schemes, including substantial improvement of flood control, are offered free of charge.

The 45th Executive Meeting of the International Commission on Large Dams, held in Salzburg in 1977, gave rise to the publication of a systematic description of all the Austrian dams in operation and under construction which are defined as "large" according to the I.C.O.L.D. criteria (116 in total in the World Register of Dams, Edition 1984).

A similar occasion is now afforded by the XVth World Congress of the International Commission on Large Dams to be held in Lausanne and by the subsequent Study Tours to Austria, the more so as Switzerland, Austria's neighbour in the Alps, is much alike in terms of economic importance and technical characteristics of hydro power. Advantage has been taken of this occasion to devote one number of this series of publications, normally dealing with large dams only, to a synoptic description of hydro development as a vehicle for large dam construction in Austria.

The first report will present a survey of the eleven largest seasonal storage schemes and their importance for Austria's electricity supply, describing their overall design concepts and main features, and will also deal with the environmental effects involved.

Whereas the seasonal storage schemes with their large heads, high dams and extensive diversion systems represent the prevailing type of development in high-lying Alpine valleys, development of the rivers is almost only by low-head run-of-river stations. To an increasing degree, the latter have come to form continuous series in developable river reaches, on the basis of master plans separately prepared for each river. These series of power stations on seven rivers will be the subject of the second report, with particular attention being given to the power stations on the Danube, which account for more than one-third of total hydro generation in Austria.

In developing Austria's hydro resources, Austrian engineers have been able to draw upon and apply the latest expert knowledge and experience available, thanks to the free exchange of opinion on a worldwide basis as is traditional to engineering and cultivated in such an outstanding manner by international organisations like I.C.O.L.D. On the other hand, however, they have also made their contribution towards hydro power engineering and have introduced a number of innovations in this field. This will be the subject of the third report.

The editors, the Austrian National Committee on Large Dams in conjunction with the Österreichische Staubeckenkommission and the Österreichische Wasserwirtschaftsverband, would like to express their thanks to the two authors, who, having devoted their lives' work to, and put their stamp on, the development of hydro power in Austria, are particularly competent to report on this subject.

Thanks are also due to many renowned firms within the Austrian construction industry which, inseparably linked with hydro power development and dam construction by the great engineering feats they have accomplished for many decades, have kindly made possible the publication of this Issue.

Dr. Wolfgang Pircher

Chairman
Austrian National Committee
on large Dams

Contents

Austria's seasonal storage schemes (H. Lauffer)	7
1. The Importance of Water Power for the Austrian Electricity Supply Industry	7
2. Hydro-Development in Austria in General	9
3. Austria's Seasonal Storage Schemes of more than 80 MW Capacity	12
4. General Survey of Design Concepts and Economic Repercussions	33
5. Main Features and Environmental Effects	36
6. Conclusions	45
7. References	47
 Run-of-River Plant in Austria (R. Fenz)	71
1. Danube	72
2. Drau	79
3. Enns	81
4. Inn	82
5. Mur	83
6. Salzach	84
7. Traun	85
8. Other Run-of-River Plant	87
9. Summary	88
 Austria's Contribution Towards the Development of Water Power (H. Lauffer)	97
1. Introduction	97
2. Pioneers in Relevant Sciences and Special Fields	97
3. Innovations and Progress in the Construction of Large Dams in Austria	97
4. New Developments in Power Conduit Construction	100
5. New Developments in the Run-of-River Schemes on Austria's Rivers	101
6. Environmental Requirements	102
7. References	103
 Register of Large Dams and River Barrages in Austria (from: World Register of Dams, 1984 Edition)	105
 Acknowledgement	111
 Colourphotographs	113

Austria's Seasonal Storage Schemes

(Power Schemes and Groups of Schemes of more than 80 MW Capacity)

By H. Lauffer

Dipl.-Ing. Dr. techn. Dr. techn. h. c. Baurat h. c., retired Executive Director of Tiroler Wasserkraftwerke AG (TIWAG), Honorary Chairman of the Austrian National Committee on Large Dams.


This Report is an attempt to present a comparative survey of Austria's major seasonal storage schemes and to discuss their overall arrangements and main features, with due regard to environmental effects. Chapter headings will be as follows:

1. The Importance of Water Power for the Austrian Electricity Supply Industry
 2. Hydro Development in Austria in General
 3. Austria's Seasonal-Storage Schemes of more than 80 MW Capacity:
 - Preliminary Remarks
 - A + B Upper Ill-Lünersee Power Schemes Owned by VIW (see Tables I and II)
 - C Kaunertal Scheme Owned by TIWAG (see Table III)
 - D Sellrain-Silz Power Scheme Owned by TIWAG (see Table III)
 - E Achensee Power Scheme Owned by TIWAG (see Table III)
 - F Zemm-Ziller Power Scheme Owned by TKW (see Table IV)
 - G Gerlos Power Scheme Owned by TKW (see Table IV)
 - H Glockner-Kaprun Power Scheme Owned by TKW (see Table V)
 - J Stubach Power Scheme Owned by ÖBB (see Table VI)
 - K Fragant Power Scheme Owned by KELAG (see Tables VII and VIII)
 - L Reisseck-Kreuzeck Power Scheme Owned by ÖDK (see Table IX)
 - M Malta Power Scheme Owned by ÖDK (see Table X)
 4. General Survey of Design Concepts and Economic Repercussions
 5. Main Features and Environmental Effects
 - A Basic Procedure
 - B1 Main Features and their Impact on the Landscape
 - B2 Water Level Variations in Storage Reservoirs and Compensating Basins
 - B3 Flow and Water Level Changes in the Affected Streams
 - B4 Effects on Bed Load Transport
 - B5 and B6 Effects on Underground Water Conditions
 - B7 Effects on the Climate
 - B8 Benefits to Downstream Regions
 6. Conclusions
 7. References
- Supplement: Tables I to X with power scheme data

1. The Importance of Water Power for the Austrian Electricity Supply Industry

Austria is fortunate in being able to satisfy the greater proportion of her generating requirements from her own hydro power, which, as an ever renewing source of energy, counts among Austria's most valuable resources. Figure 1 is a diagram showing electricity generation and consumption patterns since 1920. It is seen that, despite the abundance of development possibilities, it has never been possible to meet electricity requirements from hydro alone. Taking five-year means to neglect short-term fluctuations, the proportion of total annual generation accounted for by hydro reached its maximum of 80 per cent during the periods 1931 to 1935, 1936 to 1940 and 1946 to 1950. These are all periods during which consumption was low as a result of economic crisis or war. During the following decade 1951 to 1960, the share of hydro ranged around a constant value of 75 per cent, and then dropped to 62.5 per cent by the 1971—1975 period, because the development of hydro resources fell short of consumption growth. Ranging around 66 per cent in the period 1976 to 1980, the share of hydro has

Fig. 1. Austria's electricity production and domestic consumption since 1920 as well as average annual energy (AAE) generated by hydro plant since 1960






Fig. 2. Monthly electricity consumption, hydro generation and effects from reservoir storage in the years 1978, 1979 and 1980

since exhibited an upward trend, which however is partly a result of decreasing consumption growth rates. Since 1977, consumption growth has been substantially below the 5.3 per cent annual growth trend line, which up to then had corresponded in the long term to the development of consumption ever since 1920.

In 1983, hydro generation amounted to 30.6 TWh, which accounted for 72 per cent of a total generation of 42.6 TWh. With total consumption including losses being 39.1 TWh, one is tempted to conclude that 78 per cent of the total electricity requirements could have been met from hydro. However, apart from the large regional differences in generation and consumption patterns, simple comparison of annual values tends to be misleading, because the seasonal distributions of hydro generation and electricity consumption vary in opposite directions. This is clearly demonstrated by the monthly values of the years 1978 to 1980, shown plotted in Figure 2 along with the effects of reservoir storage.

Whereas in summer, hydro generation substantially exceeds electricity consumption, especially during wet years, winter generation may fall below 50 per cent of total consumption. Better compensation could be accomplished if a much larger storage capacity were available, as for instance in Switzerland, where favourable financing possibilities have rendered possible the provision of ample storage facilities. Thus, as can be seen from Figure 2, while there is a large export surplus during the summer months, exports and imports are practically equal in terms of kWh in winter, with imports even tending to exceed exports during periods of low flow.




Fig. 3. Daily load curves of public electricity supply for January 26, 1981 (winter day) and June 10, 1981 (summer day)

[based on Federal System Control Centre: Statistics 1981]

Table 1. Developed and developable hydro potential in Austria, 1982
(based on A. Götz and G. Schiller, ÖZE, 35. Jg., October 1982)

	Average annual energy production in TWh (developed percentage of the respective total potential)					
	Run-of-river plant		Storage plant		Total	
In operation	19.37	(52.2%)	8.68	(52.5%)	28.05	(52.3%)
Under construction	3.53	(9.5%)	0.66	(4.0%)	4.19	(7.7%)
Balance of development possibilities	14.26	(38.3%)	7.20	(43.5%)	21.46	(40.0%)
Total potential	37.16	(100.0%)	16.54	(100.0%)	53.70	(100.0%)

The daily load curves for a summer day and a winter day, shown in Figure 3, demonstrate even more clearly the decrease in hydro generation along with a rising total consumption during the winter months. This increased demand must be met from increased thermal generation and imports. The balancing effect of storage schemes on load changes is clearly seen. What cannot be inferred from this diagram is the storage schemes' function as a reserve in the case of transmission or generation failures, in particular those of the much more vulnerable thermal plant, as well as in the case of sudden load fluctuations as may be caused for instance by radio and TV. The energy supplied by the electricity generating companies is a service rather than an article that can be kept in stock, because every consumer is served at the instant of his cutting in. In order to ensure a reliable

supply it is necessary that—apart from sufficient transmission capacity—generating capacity suited for immediate start-up be available. This requirement is best met by storage schemes.

Recent studies have estimated the developable hydro potential at 53.7 TWh in total (Table 1), of which 69 per cent accounts for run-of-river plant and 31 per cent, for storage plant including daily and weekly storage. Whereas by 1982 the developed share of total developable potential was nearly equal for run-of-river plant and storage plant, i. e. 52.2 per cent and 52.5 per cent, respectively, construction of storage schemes will continue at a lower rate than that of run-of-river schemes in the years to come. That means that the winter shortage of hydro, due to reduced inflows, will increasingly have to be made up for by thermal generation or imports.

2. Hydro Development in Austria in General

Figure 4 is a diagram showing Austria's hydro schemes of more than 10 MW capacity plotted against plant capacity and head as well as rated discharge. Symbols indicate mode of operation and approximate equivalent utilisation period at maximum output capacity as an indication of energy generated p. a.

Run-of-river stations, which lack the possibility of regulation, are used for generating base load. They exhibit large equivalent utilisation periods, ranging from 4000 to 6000 h p. a. In contrast, most of the storage schemes have equivalent utilisation periods of between 500 h and 2000 h. Thus, a 100 MW-capacity power station will generate an annual energy of 400 GWh to 600 GWh if it is of the run-of-river type, and only 50 GWh to 200 GWh if it is a storage station.

Heads less than 30 m are found only in run-of-river schemes in Austria, whereas heads greater than 200 m to a maximum of about 1800 m (Reisseck storage scheme) are found only in storage schemes. This latter head range comprises rated discharges of between 5 m³/s and 100 m³/s, which is evidence of the great differences among the storage schemes. Until some 40 years ago, the head ranges shown in the diagram used to correspond approximately to the preferred applications of the three turbine types, i. e. Kaplan turbines for low heads, Francis turbines for medium heads and Pelton turbines for high heads. But meanwhile these applications have all moved up the head scale. Examples of this are the St. Martin station of the Teigitsch scheme, where Kaplan turbines work under a head of 75 m, and the Häusling power station on the Ziller, now under con-

struction, where Francis turbines will be used for a head of 740 m, whereas unregulated multi-stage pump turbines have recently come to be used for the top head ranges.

In terms of hydrology, Austrian streams exhibit substantial differences. Shown plotted on Figure 5, for comparison, are examples of annual curve of specific run-off. The upper row refers to streams harnessed by storage schemes, the lower one, to typical streams in run-of-river development. Apart from the Kamp river, all the examples shown in the upper row belong in the region of the Central Alps, where run-off is characterised by a very small winter proportion, reaching not more than 8 per cent to 14 per cent of the annual volume of flow. This decreases with increasing glaciation, because run-off from glaciers is practically zero in winter. In such cases, a reservoir storage equal to 30 per cent or 40 per cent of the annual volume of flow is required for full compensation.

Figure 6 presents the existing Austrian storage reservoirs arranged in order of active storage and top water level in terms of metres above sea-level. Stored energy reserves are shown related to a uniform altitude of 200 m above sea-level. Kölnbrein ranks highest by far in terms of active storage and energy reserve and is followed by Gepatsch and Schlegeis. Three preferred ranges of altitude may be distinguished:

1. An upper range situated between 2200 m and 2500 m a. s. l.:
Mainly impounded cirque lakes, used for seasonal




Fig. 4. Heads and capacities of Austria's hydro schemes with indication of mode of operation and equivalent utilisation period at maximum output capacity

storage. Most of them need pumping for filling because natural catchment areas are too small.

2. A medium range extending from 1650 m to 2050 m a. s. l.:
Wide high-lying valleys of glacial origin. Most of the large seasonal storage reservoirs are situated at such sites.
3. A lower range between 400 m and 1100 m a. s. l.:
Impounding possibilities mainly situated in the foothills of the Alps and in the Calcareous Alps, and natural lakes utilised by means of water level drawdown. These include the small number of developed gorges on streams, as for instance the Klaus reservoir on the Steyr and the Ottenstein and Dobra reservoirs on the Kamp. Klaus and Ottenstein are the only true dam

power stations in Austria, with the power plant directly below an arch dam, whereas all the other reservoirs discharge to diversion-type power stations.

The reservoirs of the two higher ranges of altitude, accounting for the greater part of the total storage capacity available in Austria, are all situated in Western Austria (Fig. 41), with the Tauern motorway forming an approximate boundary. The tributary valleys in the partly glaciated Central Alps obviously afford the best conditions for seasonal storage. Among the eleven power schemes and groups of schemes of more than 80 MW capacity, discussed in greater detail in the following chapter, the Lünensee reservoir (belonging in B2) and the whole Achensee scheme (E) are the only ones not to be situated in the Central Alps, but in the adjoining Northern Calcareous Alps.




Fig. 5. Examples of annual hydrograph of specific runoff, in terms of $l/s \times km^2$, for Austrian streams and rivers

The great distance of this region from the population and load centres in the Linz – Vienna – Graz area and the fact that most of Austria's run-of-river stations and in particular all the river stretches developed by continuous chains of power schemes as well as all the thermal power stations are situated east of the above boundary line have led to entirely different developments in the East and West of Austria. This applies to an even larger degree to the provinces of Vorarlberg and Tyrol.

This is also demonstrated by Table 2, comparing consumption with generation from hydro and thermal power and the balance of power interchanges with foreign countries, in the individual groups of provincial supply areas and Vienna. To accentuate the substantial seasonal differences, primarily between the consumption and hydro generation patterns, this table is based on the relatively wet Hydrological Year 1980/81, rather than a calendar year. Percentages in brackets behind con-

Austria's Storage Reservoirs




Fig. 6. Top water level, active storage and energy storage of the Austrian reservoirs

Table 2. Electricity consumption and generation (not including ÖBB) in provincial supply areas in the hydrological year 1980/81 (Wi=winter half-year 1980/81, Su=summer half-year 1981)

Provincial supply area ¹		Consumption incl. losses		Generation (perc. of consumption)						Balance of interchanges with foreign countries (export / import) GWh
		GWh	(% of h.yr.)	hydro GWh	(% of C.)	thermal GWh	(% of C.)	total GWh	(% of C.)	
1. Vienna	Wi	3803	(56.8)	52	(1.4)	2509	(65.9)	2561	(67.3)	—
	Su	2898	(43.2)	49	(1.7)	1481	(51.1)	1530	(52.8)	—
	H. yr.	6701	(100.0)	101	(1.5)	3990	(59.6)	4091	(61.1)	—
2. Niederösterreich Burgenland Oberösterreich Steiermark	Wi	10467	(54.3)	6821	(65.2)	5415	(51.7)	12236	(116.9)	— 981
	Su	8805	(45.7)	8692	(98.7)	2173	(24.6)	10865	(123.4)	+ 1173
	H. yr.	19272	(100.0)	15513	(80.5)	7588	(39.4)	23101	(119.9)	+ 192
3. Kärnten Salzburg	Wi	2906	(51.6)	2758	(94.9)	759	(26.1)	3517	(121.0)	+ 97
	Su	2724	(48.4)	3444	(126.4)	396	(14,5)	3840	(140.9)	+ 155
	H. yr.	5630	(100.0)	6202	(110.2)	1155	(20.5)	7357	(130.7)	+ 252
4. Tirol Vorarlberg	Wi	2617	(52.3)	2113	(80.8)	23	(0.8)	2136	(81.6)	+ 1073
	Su	2384	(47.7)	4601	(193.0)	12	(0.5)	4613	(193.5)	+2625
	H. yr.	5001	(100.0)	6714	(134.3)	35	(0.7)	6749	(135.0)	+3698
5. Austria	Wi	19792	(54.1)	11744	(59.3)	8706	(43.9)	20450	(103.3)	+ 189
	Su	16811	(45.9)	16786	(99.9)	4062	(24.1)	20848	(124.0)	+3953
	H. yr.	36603	(100.0)	28530	(77.9)	12768	(34.9)	41298	(112.8)	+4142

¹ Boundaries of provincial supply areas do not coincide with provincial boundaries.

sumption values are related to the respective annual totals to make evident consumption variations. Generation percentages in brackets are related to consumption levels in the respective periods to indicate the proportions contributed by hydro and thermal for satisfying regional electricity requirements.

Vienna has always met the greater part of her demand from thermal generation, which accounts for more than 50 per cent of the total consumption even in summer. As to the other groups, there is a continuous increase in hydro from east to west along with a decrease in thermal generation to near zero in Group 4 (Tirol and Vorarlberg). It is only in Group 3 (Kärnten and Salzburg) that hydro production during the winter half-year approaches

the consumption level, whereas Group 4 suffers from a severe shortage, mainly of midwinter base load, which must be met by transfers from other provincial supply areas, and from abroad in exchange for peak power from seasonal storage schemes.

As can be seen from the last column of Table 2, electricity interchanges with foreign countries in the period considered are practically balanced during the winter half-year. The export surplus is limited to the summer half-year. If periods of low flow (dry year) had occurred in 1980/81, assuming the same consumption level, there would have been a substantial import surplus in winter and a much smaller export surplus in summer, as it actually happened in subsequent years.

3. Austria's Seasonal Storage Schemes of more than 80 MW Capacity

The following description of existing schemes includes new plant and plant extensions under construction, but no planned projects. The 80 MW limit encompasses all major seasonal storage schemes, which account for about 95 per cent of total storage plant capacity and for about 97 per cent of total stored energy in Austria. The plant capacity of the daily and weekly storage schemes, not treated in this report, accounts for not more than 10 per cent of the seasonal storage schemes.

Description of the schemes (symbolised by A to M for convenience) will in each case start with a list of main reservoirs and power stages (symbolised by A1, A2, etc.) with the following indications and abbreviations:

Reservoir:

Top water level in terms of metres above sea-level.

Active storage in terms of hecto cubic metres (1 hm³ = 10⁶ m³).

Power stage:

Q_r rated discharge in terms of cubic metres per second,

max H_{gr} maximum gross head, in terms of metres,

AAE average annual generation in terms of gigawatt-hours (1 GWh = 10⁶ kWh),

T maximum plant capacity in the generating mode, in terms of megawatts (1 MW = 10³ kW),

P maximum power take in the pumping mode, in terms of megawatts (1 MW = 10³ kW),
 wi. share winter share of AAE, in per cent of AAE,
 full-load-h equivalent utilisation period at maximum output capacity (AAE/T), in terms of hours,
 PE annual pumping power requirements, in terms of gigawatt-hours (1 GWh = 10⁶ kWh).

Values without short-term pumping include average seasonal pumping that may be necessary to fill the reservoir, whereas values in brackets with short-term pumping include pumped storage operation superimposed on seasonal pumping.

To avoid a detailed description of the individual plant features, main plant data have been summarised in tabular form (see Tables I to X in the Supplement). Each Table covers two pages. Part 1 lists catchments utilised, reser-

voirs with dams as well as diversions to reservoirs and diversions discharging into power conduits. The lines reserved for feeder pumping stations may also contain minor intermediate power stations. Part 2 gives power stage data (power conduit and station) and generating data.

The great variety of plant features characterising Austria's power schemes has in some cases not allowed other than summary data to be presented, and departures from the uniform concept of the tables have been necessary. Hydrological and geological data, although important, have been omitted for lack of space.

The individual power companies and the Austrian Federal Railways (ÖBB) have been kind enough to make available, or check, the drawings, photographs and data presented in this report.

A + B: Upper III-Lünersee Group of Power Schemes (Vorarlberger Illwerke AG, Bregenz)

Symbol	Reservoir Name		Power stage Name		Capacity T	AAE	Wi. share/full-load-h without short-term pumping (values in brackets with short-term pumping)		PE
Initial operation	T.W.L./Active storage		Q _r /max H _{gr}		(P)				
in year	m a.s.l.	hm ³	m ³ /s	m	MW	GWh	%	h	GWh
A1	Silvretta		Obervermunt		31	45	58 / 1450		—
1950	2030 / 38.6		14 / 311		(—)	—	no short-term pumping		—
A2	Vermunt		Vermunt		148	260	37 / 1760		—
1930/53	1743 / 5.3		26 / 727		(—)	—	no short-term pumping		—
A3	Kops		Kops		245	392	34 / 1600		9
1969	1809 / 43.5		38 / 780		(—)	—	no short-term pumping		—
A4	Rifa compens. res.		Rifa		9	—	only short-term pumping		—
1969	1000 / 0.7		30 / 37		(9)	(8)	50 / 1000		(13)
A	Upper III group		without short-term pumping (with short-term pumping)		433 (9)	697 (705)	37 / 1610 (37 / 1630)		9 (22)
B1	Partennen compens. res.		Latschau		8	22	34 / 2750		—
1950	1024.7 / 0.1		44 / 28		(—)	—	no short-term pumping		—
B2	Lünersee		Lünersee		230	170	100 / 740		220
1958	1970 / 78.3		32 / 975		(220)	(371)	(78,5 / 1615)		(541)
B3	Latschau	{	Rodund I		173	212	41 / 1220		—
1943/52	992.25 / 2.3		60 / 364		(40)	(332)	(52 / 1920)		(58)
B4			Rodund II		270	311	41 / 1150		—
1976			90 / 364		(286)	(486)	(52 / 1800)		(359)
B	Lünersee-Rodund group		without short-term pumping (with short-term pumping)		681 (546)	715 (1211)	55 / 1050 (62 / 1780)		220 (958)
A + B	Upper III-Lünersee group		without short-term pumping (with short-term pumping)		1114 (555)	1412 (1916)	46 / 1270 (53 / 1720)		229 (980)

As suggested by the location map and schematic section (Figs. 7 and 8), this development consists in fact of two power schemes connected by a conduit, 18.7 km long and mainly of the free-surface flow type, leading from Partennen to Latschau. Scheme A, Upper III (Table I), without pumped storage, includes two large seasonal storage reservoirs. The Silvretta reservoir (Fig. 9), situated at a higher elevation, is filled by natural inflow and a single diversion, which supplies flow from the Biel valley. The much smaller Vermunt reservoir is fed by several diverted tributary streams. The Kops reservoir (Fig. 46) is

fed by long-distance diversions from the Paznaun valley (Trisanna stream) in Tyrol and from the upper course of the Rosanna. 90 per cent of the total reservoir inflow at Kops, and 10 per cent of the total inflow at Silvretta, come from the Inn basin, which causes an annual volume of 226 hm³, i. e. 56 per cent of the power water discharged from the Vermunt and Kops stations, to flow to the North Sea instead of the Black Sea.

Stored water released from the Silvretta reservoir is utilised in two high-head stages, and that from the Kops reservoir, in a single stage (Fig. 58), both ending in a




Fig. 7. Location map of VIW-owned Upper III-Lünersee group of power schemes (A+B)

common compensation reservoir at Partennen. This is connected to the Rifa compensating basin situated immediately downstream via a low-head pumped storage plant, which enables flow to be controlled to suit the limited transport capacity of the conduit towards Latschau, which in turn receives additional flows from a second water intake in the III and from its tributaries. Scheme B, Lünersee-Rodund (Table II), is situated fur-

ther downstream. Lake Lünersee acts as a high-level seasonal storage reservoir (Fig. 45) and is capable of storing 225 GWh of energy. Apart from a great amount of sealing works, construction of this reservoir required not more than 41000 m³ of concrete. 83 per cent of the total reservoir capacity must be filled by pumping. For this purpose, the Lünersee power station, situated next to the Latschau reservoir, and the parallel Rodund I and




Fig. 8. Schematic longitudinal section of VIW-owned Upper III-Lünersee group of power schemes (A+B)



Fig. 9. Silvretta reservoir (A1) with Silvretta gravity dam and Biel embankment dam

II stations following downstream (Fig. 10) have been equipped for pumped storage operation. With a pumping head of about 1000 m from Latschau and a total head on turbines of approximately 1300 m at Rodund, seasonal pumping to the Lünensee reservoir involves relatively high pumping power requirements. This may affect seasonal storage operation during periods of pumping power shortage.

Downstream of the existing Rodund lower reservoirs, a further power project, Walgau, with a 21 km-long power tunnel, was commissioned in 1985. Utilising once more the flows of the III and the diverted flows of the Meng stream, this station will have an output capacity of 86 MW and generate 356 GWh p. a. under a gross head of 165 m. The winter generating proportion will be 38 per cent. As a medium-load station, it will not be included in the data given in this report.

Construction of the Upper III-Lünensee power schemes was started with the Vermunt scheme (of 80 MW capacity in a first phase) in 1925. The present state—with a capacity 14 times as large—was reached with the commissioning of Rodung II¹ in 1975. Consistent pursuance of a basic project idea combined with constant adapta-

tions to answer requirements as they emerged, over a construction period of 50 years with some interruptions, has helped to maintain the uniformity of the main concept.

Adverse environmental effects from the construction of the four large reservoirs, eight power stations and more than twenty stream intakes have been very small indeed owing to a careful embedding of the structures into the terrain and an exemplary conservation of the landscape in the areas concerned. On the other hand, the impetus coming from power project construction has made an important contribution to the Montafon region's economic development, and the new traffic routes, as for instance the Silvretta Alpine Highway, as well as several cableways and lifts have brought lasting benefits to tourist trade, in spite of the long construction periods (Fig. 42).



Fig. 10. Penstock and powerhouse of Lünensee scheme (B2), Latschau compensation reservoir with Rodund I (B3) and Rodund II (B4) and the respective lower reservoirs

¹ The 270 MW-capacity pump turbine at Rodund is the most powerful hydraulic machine in Austria.

C: Kaunertal Scheme (Tiroler Wasserkraftwerke AG, Innsbruck)

Symbol	Reservoir Name	Power stage Name	Capacity T	AAE	Wi. share/full-load-h without short-term pumping (values in brackets with short-term pumping)	PE
Initial operation	T.W.L./Active storage	$Q_r/\max H_{gr}$	(P)		% h	GWh
in year	m a.s.l. hm ³	m ³ /s m	MW	GWh		
C	Gepatsch	Kaunertal	390	620	59 / 1520	—
1964	1767 / 138	53 / 895	(—)	(—)	no short-term pumping	—




Fig. 14. Location map of TIWAG-owned Sellrain-Silz scheme (D)




Fig. 15. Schematic longitudinal section of TIWAG-owned Sellrain-Silz scheme (D)



Fig. 16. Finstertal reservoir and rockfill dam (D1) as well as Längental reservoir and embankment dam (D2) with Kühtai power station (D1)




Fig. 17. The Stuiben Falls of the Horlach stream, which is affected by the Sellrain-Silz group (D); viewed at different rates or flow

This plan was finally abandoned, because it was realised that the ratio of pumping head to total gross head on turbines, i.e. approximately 1100 m to 1600 m or 1700 m, was too unfavourable to warrant implementation. The Sellrain-Silz scheme in its present form in no way prejudices development possibilities in the Ötz valley.

Serious opposition was encountered only in regard of the Stuiben Falls near Umhausen, which are affected by the Horlach stream diversion. The compromise which was finally adopted consisted in fixing, on the basis of detailed photographic documentation, of which Fig. 17 shows a selection, minimum flows ($2 \text{ m}^3/\text{s}$ in summer, $1.5 \text{ m}^3/\text{s}$ in spring and autumn) to be maintained during




Fig. 18. Location map of TIWAG-owned Achensee scheme (Group E)

the daytime to ensure a satisfactory appearance of the landscape.

The concentration in the close vicinity of Kühtai, a renowned skiing resort, of construction activities comprising the sites for both embankments, the upper power station with pressure shaft, two diversion galleries and three stream intakes with a few kilometres of

hillside pipelines (Fig. 16), had been feared to affect tourist trade and to lead to a reduction in the number of visitors during the four year construction period. This fear proved unfounded. Roads improved and newly constructed for the power project as well as the interest taken by the public in the individual features of the project brought many visitors so that the advantages by far outweighed potential disadvantages (Fig. 63).

E: Achensee Power Scheme

(Tiroler Wasserkraftwerke AG, Innsbruck)

Symbol	Reservoir Name	Power stage Name	Capacity T	AAE	Wi. share/full-load-h without short-term pumping (values in brackets with short-term pumping)	PE
Initial operation	T.W.L./Active storage	$Q_r/\max H_{gr}$	(P)			
in year	m a.s.l. hm ³	m ³ /s m	MW	GWh	% h	GWh
E	Achensee	Achensee	80	214	53 / 2700	4
1927/52	829.6 / 80.6	28 / 397	(—)	(—)	no short-term pumping	—




Fig. 19. Schematic longitudinal section of TIWAG-owned Achensee scheme (Group E)

Construction of the Achensee scheme was commenced in 1924. With all its features being situated below 1000 m a.s.l., it is the only one among the power schemes described in this Report not to extend to high-mountain regions. Achensee, a natural lake in the Isar river basin, is utilised by water level drawdown. Flow is utilised in the Inn valley, over a head of approximately 400 m. For more than two decades, Achensee was the largest reservoir in Austria in terms of both active storage and stored energy.

Apart from the tapping of the lake with the help of caissons, the pressure shaft and the Ampelsbach diversion, constructed during a first phase, represented technical feats that set examples for the hydro development projects that followed.

The experience gathered during the 58 years of operation of the Achensee scheme has shown that lake water level drawdown and water abstraction have had no uncontrollable detrimental effects, but have in fact improved the quality of the water. Contrary to all the apprehensions prior to the construction of the Achensee scheme, tourist trade has taken a very favourable course in this region as well.

For further details, see Figs. 18 and 19 as well as Table III.

F: Zemm-Ziller Power Scheme

(Tauernkraftwerke AG, Salzburg)

Symbol	Reservoir Name	Power stage Name	Capacity T	AAE	Wi. share/full-load-h without short-term pumping (values in brackets with short-term pumping)	PE
Initial operation	T.W.L./Active storage	$Q_r/\max H_{gr}$	(P)			
in year	m a.s.l. hm ³	m ³ /s m	MW	GWh	% h	GWh
F1	Schlegeis	Zemm upper stage	230	284	76 / 1230	—
1970	1782 / 128	50 / 676	(240)	(534)	(59 / 2320)	(362)
F2	Stillup	Main stage	345	613*	51 / 1780	—
1971	1120 / 7	92 / 476	(—)	—	no short-term pumping	—
F3	Zillergründl	Ziller upper stage	360	176	91 / 490	7
1986	1850 / 89	65 / 744	(360)	(684)	(56 / 1900)	(726)
F	Zemm-Ziller group	without short-term pumping (with short-term pumping)	935 (600)	1073* (1831)	64 / 1150 (55 / 1960)	7 (1088)




Fig. 20. Location map of TKW-owned Zemm-Ziller scheme (F)

As can be seen from Figs. 20 and 21 and Table IV, this group will include, when the Ziller upper stage is complete, two seasonal storage reservoirs holding 560 GWh of energy. Both reservoirs are formed by large arch dams. The Schlegeis reservoir is filled, without pumping, by the diverted flows of the Tux streams and the upper Zemm, and further tributary streams are diverted into the pressure tunnel of the upper stage power plant following downstream. Filling of the Zillergründl reservoir by diversions from the Gerlos valley and by diverted trib-

utary streams of the Ziller is not always ensured, so that pumping from the Stillup reservoir is necessary in dry years. In addition to the turbine discharge from the upper stages, Stillup is filled by additional tributary streams and by diversion of the remaining flows of the Zemm, whereas in the Tux valley, diversions are all situated at high elevations so that downstream effects are much less felt.




Fig. 21. Schematic longitudinal section of TKW-owned Zemm-Ziller scheme (F)



Fig. 22. Schleieis reservoir and arch dam (F1)

As both upper stages are equipped for pumped storage, the connexion galleries of major length, i. e. those leading from the Rosshag power station in the Zemm valley (Fig. 56) and the Häusling power station in the Ziller valley (under construction) to the Stillup reservoir

are operated as pressure tunnels. The power units, equipped with Francis turbines and two-stage pumps, are remarkable for the high geodetic head under which they work. This is a maximum of 672 m at Rosshag and a maximum of 740 m at Häusling, with particularly high unit capacities in the latter station.

The power station of the main stage, situated at Mayrhofen, works under a much smaller head and is equipped with Pelton turbines.

The construction of roads including a great number of road tunnels as part of the power project has afforded new or improved access to large mountainous areas. An example is the Schlegeis reservoir (Fig. 22), which is now easily accessible by a small road, and has come to attract large numbers of visitors. The same is anticipated for the Zillergrund valley after completion of the work.

The permit for the implementation of this second development phase in the upper Ziller valley, now under construction, was obtained from the authorities in agreement with the local population after long debates. But the very fact that the inhabitants of this world-famous tourist region have given their consent, in the light of their experience gathered during a long period of construction and operation, shows that the beneficial effects of such a project are valued above the inevitable nuisance involved, which is mainly felt during construction.

G: Gerlos Power Scheme (Tauernkraftwerke AG, Salzburg)

Symbol	Reservoir Name	Power stage Name	Capacity T	AAE	Wi. share/full-load-h without short-term pumping	PE
Initial operation	T.W.L./Active storage	$Q_r/\max H_{gr}$	(P)		(values in brackets with short-term pumping)	
in year	m a.s.l. hm ³	m ³ /s m	MW	GWh	% h	GWh
G1	Durlassboden	Gerlos upper stage	25	56	74 / 1000	—
1967	1405 / 51	26 / 135	(—)	—	no short-term pumping	—
G2	Gmünd	Gerlos lower stage	65	294	45 / 4520	—
1945/48	1190 / 0.7	13.5 / 614	(—)	—	no short-term pumping	—
G	Gerlos group	without short-term pumping (with short-term pumping)	90 (—)	319 —	47 / 3540 no short-term pumping	— —

For further details, see Figs. 23 and 24 and Table IV.

The lower stage of the Gerlos scheme was built for weekly storage by TIWAG. The great war-time difficulties experienced during construction were partly responsible for the subsequent pressure shaft damage.

The small weekly storage reservoir at Gmünd is formed by Austria's first arch dam, which had subsequently to be reinforced as a precaution against the risk of rockfall. To avoid rapid reservoir sedimentation, a bed load diversion facility was provided for the first time in Austria. Under the Second Nationalisation Act, the Gerlos lower

stage was taken over by TKW, which then constructed the Durlassboden seasonal storage reservoir as an upper stage to this project. This is not directly followed by the lower stage. In between is a fairly flat reach, which was not included in the development. The Durlassboden reservoir blends very well with the surrounding landscape (Fig. 25). Filling is ensured by diversions from the Salzach basin. The dam is of the earthfill type. Very difficult foundation conditions called for a deep grout curtain.

H: Glockner-Kaprun Power Scheme
(Tauernkraftwerke, Salzburg)

Symbol	Reservoir Name		Power stage Name		Capacity	AAE	Wi. share/full-load-h without short-term pumping		PE
	Initial operation	T.W.L./Active storage	$Q_r/\max H_{gr}$		\bar{T} (P)		(values in brackets with short-term pumping)		
	in year	m a.s.l. hm ³	m ³ /s m		MW	GWh	%	h	GWh
H1		Margaritze	Möll pumping stage		—	—	pumping only		15
1952		2000 / 3.2	(20) / 36		(13)	—	no short-term pumping		—
H2		Mooserboden	Kaprun upper stage		112	152	53 / 1360		—
1955		2036 / 85.5	36 / 446		(130)	(252)	(58 / 2250)		(156)
H3		Wasserfallboden	Kaprun lower stage		220	454	85 / 2060		—
1944/53		1672 / 83	36.5 / 891		(—)	—	no short-term pumping		—
H		Glockner-Kaprun group	without short-term pumping (with short-term pumping)		332 (130)	606 (706)	77 / 1825 (75 / 2130)		15 (171)




Fig. 26. Location map of TKW-owned Glockner-Kaprun scheme (H)

For further details, see Figs. 26 and 27 as well as Table V.

This is a rare example of two large seasonal storage reservoirs being located in one high-level valley. They are formed by Austria's first large arch dams (Fig. 28).

Natural inflow is by far insufficient in spite of the substantial runoff from the northern flank of the Tauern mountains. The only possibility of extension was to the south, because to the east there is the deeply incised Fusch valley, and the catchments situated to the west are utilised by the ÖBB-owned Stubach group of schemes (J). The Möll diversion, providing more than half the scheme's power water, takes off from the Margaritze reservoir situated below the Pasterze glacier. As at the time of construction, the glacier tongue extended to a much lower level, it was not possible to site the water intake at a higher elevation so as to allow gravity flow to the Mooserboden reservoir. Therefore, the diversion was constructed as a pressure tunnel with a pumping station below the Drossen dam, one of the two dams forming the Mooserboden reservoir.

Water is utilised in two stages. The upper stage is equipped for pumping between the two reservoirs. The power station of the lower stage was not built on the Salzaach, but in the Kaprun valley (Fig. 52) below the first steep rise in the valley, where better foundation conditions were found.

Hydro development planning in the Hohe Tauern mountains is based on a concept elaborated by H. Grengg in 1938, and carried through against unrealistic but at that time rather influential attempts at excessive centralisation. This concept has remained unchanged except for some raising of the top water levels and the addition of the Hirzbach diversion from the Fusch valley, and another minor diversion from the west, presently under construction and thus not yet included in the Tables. Constructed under the most adverse war and post-war conditions, this project involved pioneer work in many respects and led to an undreamt-of economic development in the Kaprun valley. The traffic facilities provided for the construction of the project made accessible one of the finest high-mountain sceneries in the Eastern Alps, which now attracts about 300 000 visitors a year and has encouraged further development also in adjoining regions.




Fig. 27. Schematic longitudinal section of TKW-owned Glockner-Kaprun scheme (H)



Fig. 28. Mooserboden reservoir with Drossen and Mooser dams (H2) as well as Wasserfallboden reservoir with Limberg dam (H3) and upper power station (H2) (released for publication by BMfLV under ZI. 13080/347 — 1. 6./82)

J: Stubach Power Scheme

(Österreichische Bundesbahnen, Generaldirektion, Vienna)

Symbol	Reservoir Name	Power stage Name	Capacity T	AAE	Wi. share/full-load-h without short-term pumping (values in brackets with short-term pumping)	PE
Initial operation	T.W.L./Active storage	$Q_r/\max H_{gr}$	(P)			
in year	m a.s.l. hm ³	m ³ /s m	MW	GWh	% h	GWh
J1	Weißsee + another 2	none at present	—	—	remote reservoir for J2	—
1952/59	2250 / 16+7	— / —	—	—		—
J2	Tauernmoossee	upper stage	81.2	120	79 / 1480	—
1929/74	2023 / 55	17.6 / 558	(—)	—	no short-term pumping	—
J3	Enzingerboden	middle stage	35.4	115	65 / 3250	—
1940/64	1463.5 / 0.3	10.5 / 428	(—)	—	no short-term pumping	—
J4	Stauwehr	lower stage	27	75	53 / 2880	—
1948/50	1035.7 / —	15.0 / 244	(—)	—	no short-term pumping	—
J	Enzingerboden group	without short-term pumping (with short-term pumping)	143.6 (—)	310 (—)	68 / 2160 no short-term pumping	—




Fig. 29. Location map of ÖBB-owned Stubach scheme (J)

For further details, see Fig. 29 and 30 as well as Table VI.

This scheme supplies peak energy to the railway electricity system (single-phase, 16 $\frac{2}{3}$ Hz). First development of lake Tauernmoos and construction of the upper stage was started in 1925. This was for a long time the only seasonal-storage reservoir in the Hohe Tauern mountains. Another remarkable feature was the fact that an active storage of as much as 21 hm³ was created by a concrete volume of only 28 500 m³. With subsequent additions by the construction of a middle stage and a lower stage and by the inclusion of the Weissee lake as a remote seasonal-storage reservoir, the scheme remained limited to the Stubach valley. Later on, the Stubach development has further been extended by the construction of a North diversion conveying water from the Amersee lake in the Felber valley to the Weissee, and by a South trans-basin diversion delivering water from the Landeck stream (Isel system) to lake Tauernmoos.

The storage of lake Tauernmoos has been more than doubled by the construction of a new dam (Fig. 31). With the Grünsee lake being utilised for station service supply, this development comprises five diversion levels, which allows a very large proportion of flow in the Stubach stream to be utilised.

The traffic facilities provided for the power project, combined with the construction of an Alpine Centre on the shore of the Weissee reservoir, at an altitude of 2300 m a. s. l., by the Austrian Alpine Club have provided an impetus for tourist trade. The success of this project can be regarded as a demonstration of the fact that mountaineering and hydro power development are compatible.




Fig. 30. Schematic longitudinal section of ÖBB-owned Stubach group of schemes (J) [based on Wohlgemuth, J.: EuM, 89. Jg. (1971), H. 2]



Fig. 31. Tauernmoossee reservoir and dam (J2), with Weisssee dam (J1) below the large snow-field in the background (Photo: D. I. Öhreneder)

K: Fragant Power Scheme
(Kärntner Elektrizitäts-AG, Klagenfurt)

Symbol	Reservoir Name	Power Name	Capacity	AAE	Wi. share/full-load-h without short-term pumping (values in brackets with short-term pumping)	PE
Initial operation	T.W.L./Active storage	$Q_r/\text{max. } H_{gr}$	T (P)		% h	
in year	m a.s.l. hm ³	m ³ /s m	MW	GWh		GWh
K1	Zirmsee	none at present	—	—	remote res. for K2	—
1982	2529.5 / 8.7	— / —	—	—	—	—
K2	Großsee + Hochwurten	Zirknitz	32	55	91 / 1720	10.3
1974	2417 / 26.7	11.4 / 689	(—)	—	no short-term pumping	—
K3	Wurtenalm + Feldsee	Wurten	66	99	57 / 1500	—
1969	1695 / 2.7 + 1.6	16 / 490	(—)	—	no short-term pumping	—
K4	Oscheniksee	Oschenik	108	82	100 / 760	64
1968/80	2391 / 33	10 / 1186	(100)	—	pumping from K3 + K5	—
K5	Haselstein	Haselstein	4	9	33 / 2250	see K4
1968	1470.5 / 0.04	1.7 / 276	(5)	—	short-term p. possible	—
K6	Innerfragant	Ausserfragant	96	236*	49 / 2460	—
1968/84	1201 / 0.18	23 / 488	(—)	—	no short-term pumping	—
K7	Wölla	Wölla	17	40	25 / 2370	—
1982/84	1542 / 0.1	6 / 326	(—)	—	no short-term pumping	—
K	Fragant group	without short-term pumping (with short-term pumping)	323 (105)	521 —	61 / 1610 short term p. possible	74.3 —

* after completion of K7

See also Figs. 32 and 33 as well as Tables VII and VIII.




Fig. 32. Location map of KELAG-owned Fragrant scheme (K)




Fig. 33. Schematic longitudinal section of KELAG-owned Fragrant scheme (K)

Characterised by great variety, the Fragant development utilises for seasonal storage four natural cirque lakes situated at very high elevations along the main ridge of the Tauern mountains. Total storage is 90 hm³. The special features of this scheme have made possible phase-wise development conceived to meet the provincial electricity company's growing requirements. Planned extensions will take another two decades to realise. Reservoirs are formed by embankment dams with asphaltic concrete facings. Heightening in several phases has allowed step-wise enlargement of storage.

The Zirmsee reservoir and the interconnected Grossee and Hochwurten reservoirs can for the most part be filled by stream diversions and several feeding pumps so that pumping from the Wurtenalm reservoir, situated at an intermediate level, will not be needed until the Zirmsee reservoir is enlarged. The Oscheniksee reservoir in turn (Fig. 47) relies for filling almost entirely on pumping from the Wurtenalm reservoir and an artificial basin at Haselstein. Pumping heads are approximately 670 m and 870 m, respectively, whereas total head on turbines is as much as 1670 m. 1200 m of this is accounted for by the Oscheniksee stage, from which a pressure shaft descends to the Innerfragant power station, which Oscheniksee shares with the Wurten stage. Both the power station and the Innerfragant compensation reservoir are situated in a hanging basin (Fig. 34) threatened by avalanches and mudslides. From there the Ausserfragant stage descends to the Möll valley. Additional flow is brought to this stage, through a sag pipe, by the Wölla trans-basin diversion from the mountains south of the Möll, with an upper stage collecting stream-flow from tributaries of the Möll and the Drau.

The construction of this scheme involved large-scale development of the southern flank of the Goldberg massif, which on this side is little frequented by tourists. The roads, most of which are single-lane to ensure minimum impact on the landscape, afford access to new areas for alpinists and tourists.



Fig. 34. Innerfragant valley head. From the top downwards: Hochwurten reservoir (K2), Wurtenalm reservoir with penstock of Wurten stage (K3) as well as powerhouse (K3+K4) and Innerfragant compensation reservoir (K6) and Haselstein stage (K5); construction road to the Oscheniksee reservoir (K4) in the bottom right-hand corner (released for publication by the BMFLV under ZL. 13080/254 — 1. 6./79)

L: Risseck-Kreuzeck Power Scheme
(Österreichische Draukraftwerke AG, Klagenfurt)

Symbol	Reservoir Name	Power stage Name	Capacity T	AAE	Wi. share/full-load-h without short-term pumping	PE
Initial operation	T.W.L./Active storage	Q _r /max H _{gr}	(P)		(values in brackets with short-term pumping)	
in year	m a.s.l. hm ³	m ³ /s m	MW	GWh	% h	GWh
L1	Gr. and Kl. Mühld.-See and another 2 res.	Risseck storage stage	68	73	100 / 1070	26
1957/60	2319 till 2399 / 17.2	4.5 / 1772.5	(18)	—	no short-term pumping	—
L2	Gondelwiese	Risseck run-of-river scheme	23	62	27 / 2700	—
1950/52	1288 / 0.04	5 / 678.5	(—)	—	no short-term pumping	—
L3	Roßwiese	Kreuzeck run-of-river scheme	45	163	27 / 3600	—
1958/60	1195 / 0.2	9 / 587.5	(—)	—	no short-term pumping	—
L	Risseck-Kreuzeck group	without short-term pumping (with short-term pumping)	136 (18)	298 —	45 / 2190 no short-term pumping	26 —

See also Figs. 35 and 36 as well as Table IX.




Fig. 35. Location map of ÖDK-owned Reisseck-Kreuzeck scheme (L)




Fig. 36. Schematic longitudinal section of ÖDK-owned Reisseck-Kreuzeck scheme (L)

Development of four natural cirque lakes situated around an elevation of approximately 2300 m a. s. l., in the Reisseck massif, has created an active storage of 17.2 hm³. Three of these lakes are impounded by gravity dams with enlarged base galleries and one, by a rockfill dam with a reinforced-concrete core. Each of the four reservoir lakes can be drawn down through low-level intakes, and alternatively connected through steel piping laid for the most part in galleries, to the penstock of the storage stage descending to the Möll. This offers a maximum head of 1772.5 m, which is the largest natural head in the world. About one-third of the required water must be pumped over a head of about 1100 m from the intake level of the Reisseck run-of-river stage, which has a small daily storage reservoir. The pumping station is situated at an elevation of about 1100 m a. s. l. and is connected to the pressure pipe of the run-of-river stage and to that of the storage stage (Fig. 37). On the opposite valley slope, the tributaries of the Möll are diverted at an elevation of about 1200 m a. s. l. and those of the Drau, around 1260 m. Flows are conveyed directly, through an intermediate power station, to the daily storage reservoir of the Kreuzeck run-of-river scheme, from which a penstock leads to the common Kolbnitz power station. The inclined hoists along the penstocks and a tunnel railway leading from the surge tank of the storage stage to the reservoirs afford access to an Alpine region for summer and winter tourists without disrupting the landscape.



Fig. 37. Penstock of Reisseck stages (L1+L2) with Kolbnitz power station to the left as well as penstock from Malta main stage (M2) with Rottau power station and compensation reservoir of the Malta lower stage (M3) to the right

M: Malta Power Scheme

(Österreichische Draukraftwerke AG, Klagenfurt)

Symbol	Reservoir Name		Power stage Name		Capacity T	AAE	Wi. share/full-load-h without short-term pumping		PE
Initial operation	T.W.L./Active storage		Q _r /max H _{gr}		(P)		(values in brackets with short-term pumping)		
in year	m a.s.l.	hm ³	m ³ /s	m	MW	GWh	%	h	GWh
M1	Kölnbrein		Malta upper stage		120	76	94 / 630		52.4
1978	1902 / 200		44—70 / 222		(116)	—	no short-term pumping		—
M2	Galgenbichl + Gösskar		Malta main stage		730	715	83 / 980		138
1978	1704 / 6		80 / 1102.5		(290)	(1155)	(k. A. / 1580)		(740)
M3	Rottau		Malta lower stage		42	114	45 / 2780		—
1978	598 / 0.5		110 / 45		(—)	—	no short-term pumping		—
M	Malta group		without short-term pumping		892	905	79 / 1015		190
			(with short-term pumping)		(406)	(1345)	(k. A. / 1510)		(792)

See also Figs. 38 and 39 as well as Table X.

The Malta development was constructed between 1971 and 1978, after lengthy studies and several modifications of the project.

The dominating feature of this development is the Kölnbrein seasonal storage reservoir situated in the upper Malta valley. With an active storage of 200 hm³ and an energy storage of almost 600 GWh, this is by far the largest in Austria. This superlative also applies to the Kölnbrein dam, 200 m in height and with a relatively wide span in its lower portion (Fig. 40). The water load acting

on the valley cross section (nominal load after Grengg) is 3.8 million t, i. e. 2.3 times the nominal load of the Schlegeis dam, which as an arch dam is second in size. As natural inflow and flow from the neighbouring catchments that can be included at top water level (1902 m a. s. l.) are insufficient, flow is mainly collected at the level of two intermediate reservoirs situated some 200 m below. These are Galgenbichl on the Malta stream and Gösskar on the Göss stream. Diversions to these bring additional flows from the upper Lieser stream and from tributaries of the upper Malta and Göss streams.




Fig. 38. Location map of ÖDK-owned Malta scheme (M)




Fig. 39. Schematic longitudinal section of ÖDK-owned Malta scheme (M)

Almost half the power water needed in the upper stage must be obtained by pumping over a head of between 50 m and 200 m depending on reservoir water level. Mean total head on turbines is about 1300 m.

The upper stage power house (Fig. 40), situated below the Galgenbichl intermediate reservoir, is equipped with Isogy pump turbines with two speeds to allow adaptation to fluctuating heads. In the main stage leading to Rottau in the Möll valley, intermediate reservoirs were provided to avoid excessive loading of the almost 20 km-long power tunnel. A short pressure shaft leads from the surge tank to the two above-ground penstocks (Fig. 37) which rank among the most highly loaded in the world. The main stage is also highest in capacity among Austria's hydro stations. Out of the four power units with Pelton turbines in the Rottau power station (Fig. 55), two are equipped with four-stage pumps for pumped storage operation, mainly on a short-term basis, but also for seasonal pumping in dry years.

The rated flow of the main stage, 80 m³/s, is discharged to the Rottau compensation reservoir on the Möll. Together with the flow of the Möll river, to which the discharge from the Kolbnitz power station of the Reisseck-Kreuzeck scheme is fed a short way upstream, this is utilised by the low-head lower stage discharging into the Drau river. In this way, the riverbed of the Möll remains unaffected by the surges resulting from peaking.

Flow abstraction mainly affects the upper Malta valley. Its picturesque gorge has always been a favourite sight for visitors. Owing to the access that has been provided to the reservoirs in an otherwise unaffected high-mountain region, the number of visitors is now 20 or 30 times larger than that prior to the construction of the power scheme.



Fig. 40. Kölnbrein reservoir and arch dam (M1) as well as Galgenbichl intermediate reservoir and embankment dam (M2) with power station of Malta upper stage (M1)

4. General Survey of Design Concepts and Economic Repercussions

Fig. 41 is a schematic map of western Austria showing hydro power schemes with special emphasis on seasonal storage. Study of this map will confirm what has been said in chapter 2 in respect of all the important seasonal storage schemes being situated to the west of the Tauern motorway.

It can also be seen from the map that most of the power schemes cover substantial areas, but differ perceptibly in character, as the basic design concept of each group calls for different combinations of reservoirs, diversions and head stages. The following list classifies seasonal storage schemes according to the number of seasonal storage reservoirs and high-head stages they contain. The fact that no more than two schemes fall under a certain combination possibility demonstrates the great variety of project arrangements.

Due to the differences in area, flow and head, the energy produced also varies substantially from scheme to scheme. Table 3, listing the groups of power schemes in order of average annual energy generation (AAE), suggests a division into two groups, the lower group consisting of four groups of power schemes with a max-

Classification of Groups of Power Schemes A to M

Per scheme	Number of reservoirs for seasonal storage			
	1	2	3	4
1 stage	C, E	—	—	—
2 stages	D, G	—	—	—
3 stages	(B), M	(A), F	J	L
4 stages and more	—	—	A + B	K

imum annual energy of 320 GWh, and the upper group comprising seven groups of power schemes generating between 500 GWh and 1400 GWh p. a. If the VIW-owned A + B installations figuring at the top were regarded as two separate schemes generating 697 GWh and 715 GWh, respectively, six developments would generate an annual energy of between 500 GWh and 700 GWh, and there would be one development with an annual energy of about 950 GWh and one with an energy of 1100 GWh. Groups of seasonal storage schemes




Fig. 41. Schematic map of western Austria showing locations of seasonal-storage schemes A to M and most of the other hydro plants of more than 10 MW capacity

Table 3. Energy data of the Austrian seasonal-storage schemes of more than 80 MW capacity, including extensions under construction, ranked in order of AAE not including short-term pumping

Rank	Power schemes	Capacity T/P MW	Energy without short-term pumping			Pumping energy PE		Energy with short-term pumping			Pumping energy PE	
			AAE GWh	Wi. share %	Full-load h	GWh	% of AAE	AAE GWh	Wi. share %	Full-load h	GWh	% of AAE
1	Upper Ill-Lünersee (A+B)	1114/555	1412	46	1270	229	16	1916	53	1720	980	51
2	Zemm-Ziller (F)	935/600	1073	64	1150	7	0.7	1831	55	1960	1088	59
3	Malta (M)	892/406	905	79	1015	190	21	1345	k. A.	1510	792	59
4	Kaunertal (C)	390/ —	620	59	1590	—	—	no short-term pumping				
5	Glockner-Kaprun (H) .	332/130	606	77	1825	15	2.5	706	75	2130	171	24
6	Fragant (K)	323/105	521	61	1610	74	14	some short-term pumping possible				
7	Sellrain-Silz (D)	765/247	515	46	680	65	13	719	54	950	336	47
8	Gerlos (G)	90/ —	319	47	3540	—	—	no short-term pumping				
9	Stubach (J)	144/ —	310	68	2160	—	—	no short-term pumping				
10	Reißeck-Kreuzeck (L)	136/ 18	298	45	2190	26	8.5	no short-term pumping				
11	Achensee (E)	80/ —	214	53	2700	—	—	no short-term pumping				

generating more than 1 TWh p. a. are rare, even in the Western Alps. This is due to the ramified relief of the Alps, which renders difficult the combination of major areas for hydro power development.

Another result of this closely spaced structuring of the Alps is the fact that utilisation of none of the seasonal storage reservoirs can rely on natural inflow only, additional flows being supplied by diversions, including trans-basin diversions, or pumping from lower levels, in particular to the high-lying reservoirs. This is accomplished either by providing intermediate pumping stations which, where major capacities are involved, may resemble power stations (schemes H and L), or by equipping downstream power stations for pumped storage operation. The latter applies to at least one stage of six developments in the upper group. In these cases, daily or weekly pumping (short-term pumping) can be superimposed on the seasonal pumped storage operation necessary for reservoir filling.

The high pumping energy requirements substantially reduce the net production of primary energy. This even applies to seasonal pumped storage where the ratio of required pumping head to useful total head on turbines is unfavourable. Table 3 shows pumping energy requirements, PE, both in terms of GWh, and as percentages of average annual energy, AAE. The latter may be as much as 21 per cent without short-term pumping and almost 60 per cent with short-term pumping, which adds to the fact that the extra generation calculated to be obtained from the assumed short-term pumping is seldom utilised to the full.

The energy generated by the individual seasonal storage schemes varies in quality, depending on reservoir storage and on power station capacity storage which are both determined more or less at random, by the designer. The respective parameters mentioned in Chapter 3 and Table 3 above, i. e. winter share and equivalent utilisation period at maximum output capacity, exhibit substantial variations. In the upper group, winter generation varies between 46 per cent and 79 per cent of the respective AAE, whereas the equivalent pe-

riod of utilisation at maximum output capacity is between 680 h and 1825 h. The winter percentage generated by the schemes situated in the east of Western Austria tends to be higher than in the west, whereas the number of full-load hours tends to be smaller in the younger schemes, which have higher capacity ratings. In spite of these differences, arrangement in order of scheme capacity, ranging from 323 MW to 1114 MW, would bring about practically no change, except for Sellrain-Silz, which would advance to the fourth rank. If the groups of schemes were arranged in order of power range, which is important for system regulation, i. e. the sum of turbine output plus pump output, with a peak value of almost 1700 MW, Sellrain-Silz (D) and Kaunertal (C) would change places and the rest remain the same. Each of these power schemes is a special case and results from attempts to combine in an optimal manner natural site conditions with power system requirements and environmental conditions. The fact that the preservation of environment and landscape has always been an important factor is demonstrated by the vehement discussions held 50 years ago in respect of hydro development planning in the Hohe Tauern mountains (H. Grengg, 1952) and other projects as well as by the records of the water-right licensing proceedings, which treat this problem in great detail. Conservation problems will also be the subject of the following chapter.

As to economic repercussions in the communes, valleys and regions affected by the construction and operation of power schemes, decades of experience have shown that, in the case of the schemes discussed here, interference tends to be limited in space and time and, in the long run, is usually more than outweighed by the beneficial consequences.

Apart from considerable tax receipts for the communes, the creation of skilled jobs for operation and maintenance, involving also trade and industry, as well as contributions and funds paid by many power companies for the improvement of infrastructure have brought lasting economic advantages.

An important factor is the influence on tourist trade. In

the mountain valleys, where our reservoirs are situated, this is usually the only additional source of income apt to counteract rural exodus and as such will help to preserve cultivated land as is typical of the Alpine landscape. Traffic facilities newly provided or improved for the construction of hydro projects are of particular importance for tourist trade, not only by affording easier access to high-lying regions for mountaineers and alpinists, but also by rendering sites of scenic beauty accessible and by creating features of technical interest, which have a great attraction for the public, so as to promote tourist trade within a large radius.

As suggested by the list of power schemes discussed in this article, there are many renowned holiday resorts in the immediate vicinity of such developments, most of which have existed for a long time. Such regions are the Montafon valley, the Tyrolean Paznaun valley, the upper Ziller valley, the Gerlos valley, the upper Pinzgau valley with the Zell am See – Kaprun region, the upper Möll valley, etc. Their popularity has remained unabated and is obviously in no way inferior to that of neighbouring areas, where no power schemes exist.

The development of the population in the Montafon




Fig. 42. Development of population in the Montafon valley since 1837 [based on Strom aus Vorarlberg, 50 Jahre VIW (1924—1974)]

valley since 1837, shown on Fig. 42, demonstrates an impressive rise from a previously distressed area owing to hydropower development and tourist trade.

5. Main Features and Environmental Effects

A. Basic Procedure

It is a well-known fact that hydro development produces no waste, noxious matter, or other emissions. The water driving the turbines is not consumed or polluted and is of unchanged quality and quantity when returned to the riverbed after utilisation. Neither is the heat balance of the earth affected, because the energy utilised for electricity production would otherwise also be converted into heat, through hydraulic friction and the crushing work involved in erosion and bed load breakage. Hydro development primarily causes physical change, which is easily observed or measured by simple means.

Thus it is natural that discussion of environmental effects should be based on the main project features, which, as components hardly affecting one another and roughly alike for all schemes, form our storage schemes in varying combinations.

These are:

1. Storage reservoirs and compensation basins, with dams,
2. Trans-basin diversions and simple stream diversions with intakes and conveyance structures, mainly consisting of free-flow galleries and pipelines,
3. Power stages, consisting of power conduit and power station, the former usually consisting of pressure tunnel, surge tank, and penstock or pressure shaft,
4. Tailrace canals and tailwater compensation basins where necessary.

Discussion of environmental impact will logically consist of two parts, one part treating physical change and one part studying resulting effects of such physical change

on the various spheres of the environment. Fig. 43 is a matrix which has proved expedient in the study of environmental effects. Listed under A, to the left, are main project features. Column B in the middle indicates physical changes caused, whereas the principal spheres of the environment are given in column C to the right, which could be extended and subdivided as necessary. Symbols at the intersections of A and B, or B and C, respectively show expected or apprehended relationships and are mainly intended to prevent important relationships from being overlooked. Relationships and feedback among parameters whose intersection points are not marked by a symbol are regarded as being of minor importance.

Further discussion will be in the same order as the list of physical changes under B in Fig. 43, without going into technical details.

B1. Main Features and their Impact on the Landscape

Reservoirs and dams

The dominating components of storage schemes are the seasonal storage reservoirs with their dams. When sufficiently full, reservoirs can hardly be distinguished from natural mountain lakes, generally considered features of particular charm adding to the beauty of a landscape. Apart from the water level variations, to be discussed later, experience has shown the effects of reservoir lakes to be mainly favourable. The concrete and fill dams forming these lakes, however, are major engineering structures that cannot possibly pass unnoticed in a landscape even if they are most carefully designed and adapted to their surroundings. The degree of interference changes with the local conditions.

Fig. 43. Matrix for determining, in two steps, environmental effects of storage schemes



(b) Gravity dams with curved alignments
Examples: Grosser Mühldorfersee dam (L1), Lünensee dam (B2) as shown in Fig. 45, new Tauernmoossee dam (J2) as shown in Fig. 31.

(e) Earthfill dams with grassy downstream faces




Fig. 46. Kops (A3) — arch dam with thrust block and lateral gravity dam



Fig. 47. Oscheniksee reservoir (K4) with rockfill dam with asphalt facing (released for publication by the BMFLV under ZI. 13080/254 — 1. 6./79)



Fig. 48. Pitzbach stream intake (C) with horizontal coarse rack

Examples: Biel dam (A1) as shown in Fig. 9, with reinforced-concrete core wall,
Längental dam (D2) as shown in Fig. 17, with upstream asphalt facing,
Durlassboden dam (G1) as shown in Fig. 25, with earth core,
Galgenbichl dam (M2) as shown in Fig. 40, with upstream asphalt facing.

(f) Rockfill dams with machine-placed boulders as slope protection on downstream faces

Examples: Gepatsch dam (C) as shown in Fig. 13, with earth core,
Oscheniksee dam (K4), as shown in Fig. 47, with upstream asphalt facing,
Finstertal dam (D1), as shown on Figs. 17 and 63, with asphaltic-concrete core.

There will be no objective answer to the question which dam type blends better with the surrounding landscape. The probability is, however, that a high concrete dam will attract more attention as an engineering feat than a fill dam of the same height would, whose geometric slope shapes, although giving it away as a man-made structure as well, do so less conspicuously.

As our large dams have to withstand the highest loadings among the engineering structures—the Kölnbrein dam must sustain a load from water pressure of almost 4 million t at top water level—, selection of dam type will mainly be governed by engineering and economic appraisal of site topography and geology and availability of local construction materials.

Among the factors considered is the ratio of crest length to height as a characteristic of the valley cross section, as shown in Fig. 44 for Austria's major dams. Whereas arch dams predominate to the left of the bold line, i. e. for crest lengths less than four times the dam height, gravity and embankment dams are preferred for crest lengths greater than four times the dam height. As demonstrated by various examples in Austria and abroad, embankments are increasingly used also for sites at narrow valley sections.

Diversions

The only visible component of a stream diversion is usually the intake, which will in general be an inconspicuous structure. Fig. 48 shows a design preferably used at high-lying sites, with a low submerged weir and with water being taken in through a horizontal coarse rack. The sand trap following downstream is either built against the slope and covered with earth (Fig. 48) or located in the adjacent tunnel. The latter is usually provided where steeply sloping tributary streams are present, so that intakes must mainly be constructed from the tunnels, so as to need no separate access road. In special cases, small concrete dams (Fig. 49) or gated weirs may be built as are often used for low-lying intakes with major catchments.

Diversion conduits usually consist of free-flow tunnels or buried pipelines with the result that the portals and potential piles of tunnel spoil are the only visible features that remain. Arguments that these piles may do harm to the scenery have been proved unfounded by experience. If enough care is used, it is always possible to make dumps of excavation materials blend with the surrounding landscape by adequate shaping and planting.

This is facilitated by improved tunnelling techniques and an increased use of tunnel boring machines, as the higher excavation rates involved allow longer tunnel sections—of 10 km or more—to be excavated from one heading. Thus, for a given length of a tunnel fewer points of attack are required for which it is easier to find suitable dump sites, unless the excavated material is used anyway for embankments and land fill.

This is confirmed by many photographs of project features, which hardly show any visible traces of the large amount of material that had to be moved during construction. An example is Fig. 16, showing the Kühtai area of the Sellrain-Silz group of power schemes (D). Concentrated in a relatively limited area were the sites for two large fill dams, the upper stage between them, involving major excavation volumes for the pressure shaft and the shaft-type power station, two major free-flow tunnels and two diversion pipelines. No dumps, borrow areas or other damage to the landscape are seen.

High-head stages

The above remarks are also true of the power tunnels and surge tanks, which rarely appear at the surface, so that little change to the landscape results.

The impact on the landscape of the steeply descending part of a power conduit between the surge tank, or reservoir, and the turbines will depend on whether this is a pressure shaft, a buried pipeline or above-ground penstock, or a combination of these possibilities.

As can be seen from the plant data listed in Tables I to X and from Fig. 50, which compares longitudinal profiles, pressure shafts and penstocks have been used in approximately equal amounts on the Austrian seasonal storage projects.



Fig. 49. Taschachbach stream intake (C) with concrete dam and frontal inlet

In particularly difficult ground, the excavation of a pressure shaft will have to be preceded by geological and geotechnical investigations extending to major depth to obtain information on in-situ rock mass, although in fact even large-scale preliminary studies do not preclude the possibility of surprises during construction. For example, the highly loaded pressure shaft above the Prutz power station of the Kaunertal scheme (C) had to be driven through rock of extremely poor mechanical properties. It was due to years of preliminary work that it was possible to complete the shaft in time. Fig. 51 is a photograph of the pressure shaft slope. In spite of the adit that had to be provided in this steep area prone to




Fig. 50. Schematic longitudinal profiles of pressure shafts and penstocks for storage schemes



Fig. 51. Power shaft slope of Kaunertal scheme (C) with Prutz power station




Fig. 52. Penstock and power station of Kaprun main stage (H3)

slides, the former construction sites and their access roads branching off the clearly visible public road to Fendels are hardly recognised.

Above-ground penstocks are bound to create rather conspicuous landmarks, especially where several pipes with a permanent inclined hoist form a straight track. At the Kaprun main stage (H3), even four pipes were laid along the hoist (two on either side), as shown in Fig. 52, with the lower one-third being covered by an arch structure and earth fill. The original plan was to cover the pipes with earth between the thrust blocks provided with the concrete caps then in use. This idea was abandoned in view of the problems of corrosion protection involved. The penstocks of the two Reisseck stages (L1 and L2), designed to resist maximum pressures of about 180 bar and 80 bar, respectively (Fig. 37, left), are of the conventional type, except that their lowest sections, crossing a flat talus fan, were laid as buried pipeline without intermediate thrust blocks and expansion joints. Further development led to the omission of the concrete caps on the thrust blocks, as for instance on the Lünensee project (B2). The penstock sections of the power conduit were firmly embedded in the concrete of the thrust blocks by means of supporting rings and struts (see Fig. 53). At the Ausserfragant stage (K6), a simplified method was applied, providing for the longitudinal forces to be transferred through web plates with head bolt anchors welded to the underside of the pipe. A similar technique was used for the two penstocks of the Malta main stage (M2) (Fig. 37, right). With a diameter of 2.5 m each and designed to resist a pressure of 127 bar, these pipes represent superlatives in Austria. The end block (Fig. 55), situated 70 m above the valley floor, called for a special design with heavy steel struts and deep rock anchors to withstand the enormous forces acting upon it.

For the Wurten stage (K3) of the Fragant group of power schemes a construction method without actual thrust blocks was developed. The penstock was concrete-embedded over major lengths in a trench cut in the rock (Fig. 54). This facilitated the adaptation of the penstock alignment to the terrain. Depressions were bridged by above-ground pipe sections mounted on socketed steel columns.

Selection of the type of power conduit for the steep section descending to the turbines will mainly be determined by topographical and geological factors. Insufficient subsoil information may be a reason for precluding the pressure shaft method from consideration.

Power stations, usually located at lower levels, may be of the following types, apart from differences in the location of the main transformers, which can be read off Tables I to X.

1. Detached powerhouses, the most frequently used type, which may be subdivided according to manifold arrangement as follows:
 - (a) with open manifold
 - examples: Vermunt (A2),
 - Achensee (E),
 - Mayrhofen station (F2) of Zemm-Ziller scheme,
 - Rottau power station of Malta main stage (M2) as seen in Fig. 55.




Fig. 53. Penstock thrust block without concrete cap, Lünensee scheme (B2)

(b) with covered manifold

examples: Lünensee (B2) and Rodund I (B3) as seen in Fig. 10, Prutz power station of Kaunertal scheme (C) as seen in Fig. 51, Silz lower stage (D2) of Sellrain-Silz scheme as seen in Fig. 59

2. Powerhouses built against the slope or covered with fill, mainly adopted where little space is available and as a precaution against alpine risks.

Examples: Kaprun main stage (H3) as seen in Fig. 52,

Rosshag power station of the Zemm upper stage (F1) as seen in Fig. 56, Innerfragant power station (K3 and K4) as seen in Fig. 34.

3. Shaft-type power stations, which are selected for schemes with pump-turbines requiring a high supply pressure.

Examples: Rodund II (B4) with crane hall and Kühtai upper stage (D1) of the Sellrain-Silz scheme with open-air gantry crane as seen in Fig. 57.

4. Underground power stations, of which type only a few have been built for seasonal storage schemes.

Examples: Kops (A3) as seen in Fig. 58, Möll pumping station (H1). (The underground power stations of Langenegg [VKW, 74 MW] and Braz [ÖBB, 30 MW] are not for seasonal storage, but also in the high head range.)

Although the above power station types are listed approximately in order of decreasing environmental impact, other factors are much more important in determining the degree of interference with nature resulting from a project. This concerns above all the control buildings, workshops, stores, garages, etc., which are likely to be larger than the powerhouse itself. Then the latter plays a subordinate role in the general appearance. Inevitable facilities are high-voltage switching facilities, which are particularly large in extent where they form a node of the system. In such cases, outdoor switchyards



Fig. 54. Penstock of Wurten stage (K3) — Reinforced-concrete encased steel pipe without thrust blocks




Fig. 55. Rottau power station of Malta main stage (M2)




Fig. 56. Rosshag power station of Zemm upper stage (F1)




Fig. 57. Rodund II (B4) and Kühtai (D1) shaft power stations

will continue to be necessary. But they can only be located on wide valley floors anyway, where they are not exceedingly disturbing, as demonstrated by many examples (Figs. 37, 51 and 59). As the number of outgoing lines is usually small, indoor switching facilities are provided at power station locations in narrow valleys, especially where there is a potential risk of avalanches and rockfall. Examples of indoor switchgears are the Kaprun upper stage (H2) and the Innerfragant power station (K2 and K3), which are equipped with conventional 110 kV facilities, whereas SF₆ indoor installations for a voltage of 220 kV were provided at the Rosshag (F1) and Kühtai (D1) power stations.

Power stages may include tailraces and compensation or surge reservoirs. Where a wide valley floor calls for a long tailrace, a winding alignment (Fig. 59) and construction details designed to suggest a natural water course,

for instance coarse gravel as bank protection and planting with local vegetation, may help to avoid the appearance of an artificial channel.

Greater repercussions may indeed result from the operation of the schemes than from the structures themselves. This particularly applies to the hydrological aspect.

B2. Water Level Variations in Storage and Compensation Reservoirs

It is certainly an uncontested fact that full or nearly full reservoirs are an asset to the landscape as compared with the original condition. Criticism is however aimed at the large water level variations, which are inevitable in seasonal storage reservoirs and which may reach as much as 100 m or more. This undeniable disadvantage is




Fig. 58. Underground power station of Kops scheme (A3) [based on E. Stefko, ÖZE, 23. Jg. (1970), H. 7]

mitigated by the fact that filling proceeds rapidly in the lower reservoir portion, where the surface area is small, and that water level drawdown by some 20 m or 30 m against a background of towering peaks is less badly felt than would be in flat country.

The appearance of a reservoir is determined not so much by the amount of stored water as a percentage of active storage, as given in the statistics, as by the actual height of the water surface. Correct appraisal should be based on water level curves. Fig. 60 is a graph showing annual water level curves at Gepatsch (C) for a 10-year period. This demonstrates that the reservoir surface level is very likely to be sufficiently high from mid-July to the end of November, that is, during the main and after-seasons of tourism, whereas in winter and spring the dry reservoir slopes are covered with snow and ice anyway. Moreover, the upper slope portions of large reservoirs are usually too steep to retain mud depositions, and flat shores are lacking altogether or are limited to the upstream end of a reservoir.

Reservoir filling is faster if more flow is supplied. Any reduction in inflow, for instance by reducing the catchment or increasing the minimum release requirements, slows down the filling process and increases the probability of unsatisfactory conditions occurring, although only temporarily.

In compensation reservoirs, where water level variations are much smaller, a medium level is usually maintained for operational reasons, so that the visible strip of shore does not exceed very much the range of natural water level variations as occur for instance in cirque lakes.

B3. Flow and Water Level Changes in the Affected Streams

Development of the hydro potential by Alpine storage schemes is not possible without stream diversions. This implies that stream flow and, hence, water level down-




Fig. 59. Tailrace and power station of the Silz lower stage (D2)

stream of dams and water intakes are affected. Indicating change in flow, or remaining flow, as a percentage of unaffected flow, or flow in terms of cubic metres per second, is misleading, as it is primarily the water level, or the change in water level, that forms the basis for assessing the effects. Without consulting measuring instruments, the observer will only perceive major water level changes. Therefore, the effects of changes in flow if expressed as percentages tend to be overestimated. The data furnished by the Plangeross gauging station (see Fig. 11) in the Pitz stream, a few kilometres downstream of the diversions for the Kaunertal scheme (C), have been used as a basis for studying the effect of water abstraction on water level. It has been found out




Fig. 60. Water level curves for Gepatsch reservoir (C), 1966 to 1975



Fig. 61. The Pitz stream near the Plangeross gauge during the low-flow period, with its catchment reduced to 15 per cent by flow abstraction for the benefit of the Kaunertal scheme (C)

that, as a result of flow reduction to about 15 per cent, water depth decreases to half in summer and to two-thirds in winter. At the St. Leonhard gauge further downstream, where flow amounts to about 48 per cent of the original value, the remaining water depth ranges between 80 per cent and 90 per cent. Fig. 61 is a photograph showing the Pitz stream at the Plangeross gauge during the low flow period. Although reduced to about one-seventh, streamflow is large enough to cover the whole streambed, so that there is no question of complete drainage.

Even if the entire streamflow is diverted, the severe effects are limited to a short reach downstream of a dam or intake, as tributaries combined with potential underseepage lead to a relatively rapid increase in remaining flow. Where diversions are limited to the preferred height range between elevations of about 1700 m and 2000 m above sea-level, the severely affected reaches are situated somewhere between the virtually virgin high-mountain region and the permanently inhabited settlements. During the winter months, these reaches will hardly be accessible and will practically be invisible under the snow.

Ecological effects of water abstraction from Alpine streams are limited to the streambed proper and its fauna, whereas the utilised catchment as well as the regions furnishing what streamflow remains are completely unaffected. There is certainly no potential risk to landscape ecology beyond the beds of the affected streams as for instance in the form of large-scale drainage or karst.

Detailed investigations have shown that diversion of the cold glacier water from V-shaped valleys tends to be beneficial to tree growth on the banks. Substantial abstraction of flow from the upper course of the Möll has not affected the vegetation on its banks of alders as are common in flat valley floors. Actually vegetation has spread into the streambed, now less claimed by the water.

The impact on the landscape of a reduced streamflow is largely dependent on the local conditions and defies ob-

jective appraisal. There is no doubt that unharnessed streams are a very important factor in an Alpine landscape. But the question whether or to which extent reduction in flow is permissible without impairing the landscape and its quality as a recreational resource is controversial. Criteria for assessing this question are furnished by the seasonal and weather-induced flow variations in natural streams. Actually, the season preferred by many mountaineers, Alpine painters and photographers is the autumn, although flows have substantially decreased and glacier streams can hardly be distinguished from ordinary streams at that time of the year. This renders doubtful any attempt at an academic assessment based on arbitrary assumptions or more or less suggestive inquiries among tourists. Better results will be obtained from site reconnaissance at different flows, and photographic documentation like that shown in Fig. 17, which allow realistic appraisal of the regime of remaining flows. In addition, the eleven groups of storage schemes with more than 20 seasonal storage reservoirs and more than 30 major high-head stages afford ample opportunity to find, for any special problem, comparable conditions, where longstanding experience gathered during operation facilitates realistic appraisal of the effects of hydro power development on the landscape and tourist trade.

B4. Effects on Bed Load Transport

We should distinguish between two different cases. Large reservoirs retain the entire amount of bed load so that the reduced downstream flow is matched by a reduced bed load transport. Downstream of stream intakes, however, bed load production remains unchanged in spite of the reduced flow. According to the classical bed load theory, assuming bed load production and transport capacity to be in balance, disturbance of this natural equilibrium would have to lead to large-scale sedimentation. In actual fact, in the great number of stream diversions that have been in operation for decades, nothing of that kind has happened. Sedimentation if any has remained insignificant.

Ever since R. Müller conducted his fundamental studies on this subject (1955), it has been known that many Alpine streams are in a state of "latent erosion", where bed load transport is much smaller than transport capacity, a theory that used to be difficult to prove in the individual case.

Evaluation of the automatic sand trap flushings carried on for many years on the stream intakes of the Kaunertal scheme (C) has rendered possible for the first time routine measurement of bed load transport in mountain streams and comparison of these measurements with the calculated transport capacity. In the case of the Pitz stream, transport capacity has been found to be ten times as large as the measured bed load production. Main valley stream reaches in a state of latent erosion are largely insensitive to diversion. This also explains why it has been possible to keep bed load production under control by means of occasional cleaning in streams affected by storage schemes. Streams in a state of latent erosion are characterised by very coarse-grained bed load material which is hardly moved even by major floods. This is believed to apply to the greater part of Alpine streams, as is also demonstrated by Fig. 61.

B5 and B6. Effects on Underground Water Conditions

Water contained in joints and fissures of the rock mass may be affected by the excavation of tunnels and shafts, which are likely to cause a drainage effect so as to lower the water table in places. However, groundwater in the Central Alps is a negligible factor, as it emerges, if at all, in deeply incised ravines only and is otherwise substantially below ground level, so that vegetation cannot possibly be influenced by changes in the water table. Whereas groundwater conditions may assume great importance in backwater areas of run-of-river stations, they do so rarely in storage schemes in the Alps. There is usually no connexion between the ground water in the heterogeneous valley fills of tributary ravines and the main stream, so that water level variations, except for floods, hardly influence the ground water. Vegetation on the valley bottoms is in most cases independent of the ground water. Perceptible effects may be felt around outlet works in stream stretches with an insufficient gradient, but these are easy to control, and have practically caused no impairment.

B7. Effects on the Climate

For affecting the macroclimate, Austria's storage reservoirs would have to be by two or three decimals larger in magnitude.

As to the effects on the local microclimate, it is mainly feared that mist may form above intermediate and compensation reservoirs, most of which are situated near villages. As, however, long records of meteorological observations have shown mist to form preferably above land rather than water, and as there is enough movement of air in the tributary valleys of the Alps, such fears have in most cases proved unfounded.

B8. Benefits to Downstream Regions

(a) Flood protection

Flood storage in the large reservoirs is an important flood-risk reducing factor in the valley concerned. The

6. Conclusions

The above analysis of main environmental effects from storage schemes confirms and explains the mainly favourable experience gathered during many decades of operation.

This allows any risk of a profound impact on the ecology to be precluded, as both the developed catchment and undeveloped catchments supplying the remaining streamflow escape the effects except for some insignificant marginal areas. Ecological alterations, if any, are limited to the storage reservoirs and the stream stretches affected by the diversions and do not extend beyond the streambeds and stream biology, whereas no harm is in general caused to the vegetation on the banks. What perceptible effects on nature and landscape are produced will in general be restricted to the




Fig. 62. Effects of storage schemes on the flow of the Inn near the Innsbruck gauge

fact that spillways are practically never in action is evidence that flood frequency downstream of large dams is substantially reduced.

The effect on downstream areas depends on power station operation, which may be inevitable to ensure power supply to the region attained by the flood. As long as the reservoir surface is rising, a favourable effect is produced downstream of the outlet works, although this effect decreases in the downstream direction.

(b) Additional flow during low-flow periods

Additional flow from reservoir operation during low-flow periods benefits even remote downstream areas. Fig. 62 is a graph showing the effect of storage schemes on the flow of the river Inn at Innsbruck. Despite the diversions towards the province of Vorarlberg (A3), low flow during the winter months is appreciably improved. The contribution from reservoir releases amounts to as much as half the natural flow in mid-winter, which is certainly beneficial to water quality, whereas flow retention during the period of abundant flows in the summer months has hardly any adverse effects.

transition zone between the permanently inhabited villages and the high mountain regions proper, the latter even remaining virtually unaffected and unaltered except for a few high-lying cirque lakes.

Most of the regions affected by the storage schemes are in fact no virgin country, but cultivated areas that have long been under the influence of man. In accordance with the respective climatic and economic conditions, and constantly fighting the forces of nature, man has constantly modified these areas for centuries by utilising them as alpine pastures and for forestry and other purposes. This includes intensive mining and metallurgical activities in former times, which have left traces extending to the highest mountain regions, especially in the Hohe Tauern range.



Fig. 63. Finstertal reservoir and embankment dam (D1) in the K  htai winter sports region

Apart from the engineering structures and storage reservoirs, effects on the landscape mainly concern stream reaches affected to a major extent by the diversions. Storage schemes are in a favourable position as compared with other industrial plants in promising constancy in respect of product, process and output. This allows careful construction, maintenance and landscape preservation with a view to a long service life. Modern earthworks equipment and landscaping methods help to fit into the terrain large dams and stream intakes as well as the dumps for surplus excavation material, so that there is now hardly any reason for complaints.

Storage reservoirs are mainly considered as assets to a landscape, as it is only early in summer that the inevitable water level variations become a perceptible nuisance. Flow abstraction from stream beds is mainly felt over the reaches immediately downstream of dams and stream intakes. Especially at the high-lying sites, most stream beds are soon filled by natural affluents further downstream. As suggested by the large flow variations in nature, the appearance of a stream is governed by the water level rather than the actual amount of flow. In fact, the river bed must sufficiently be covered with water. This observation is also borne out by the large natural flow variations.

This is also the reason why in Austria, as in the rest of the Alps, compensation water releases have rarely been required in the case of high-lying storage schemes. The general introduction of minimum release requirements would imply that the same amount of energy production would call for the harnessing of a larger number of streams, so that in actual fact impairment would even be larger.

As to the economic effects it should be mentioned that normally relocation of local population is not necessary

and that cultivated land accounts for only a very small proportion of the areas used for storage schemes. Apart from the construction period, during which the economy of the whole region receives an important impetus, large sums of duties and taxes are derived after the commissioning of the project, usually supplemented by current compensation payments and contributions or funds for financing improvement of the infrastructure.

Tourist trade, next to inevitable in mountainous regions to prevent rural exodus, is in general promoted by the new or improved roads necessary for the construction of hydro projects, as access is provided to hitherto hardly accessible points of scenic beauty and to new sights. Reductions in overnight stays as were in some cases experienced during construction were made up for in no time after completion of the project. At any rate, the fact that all the groups of power schemes described in this article are situated in or next to flourishing tourist regions is evidence that in the long run tourist trade certainly suffers no harm from hydro schemes.

As stated by D. Vischer (1975), the development of hydro power has so far been the only soft technology to be used for large-scale energy production.

Hydro schemes utilise as primary energy the water power continuously available in nature. From this the secondary energy needed by the consumer is generated with minimum conversion loss. In the case of storage schemes, this is valuable peak energy. Attempts made so far to utilise wind and sun for power generation have shown that large scale development of these sources of energy would have much greater environmental impact. The only alternatives to our storage schemes are at present gas turbines and pumped storage plants supplied from thermal base-load plants. Comparison of the environmental repercussions involved should consider not only direct effects of thermal generation, but also the effects of all the production and treatment processes including transports and temporary and final storage necessary for obtaining fuels or fuel elements and for the disposal of nuclear and other waste, which is often neglected.

We are faced almost daily with news about new damage to trees and other nuisance resulting from waste gases, increasing pollution of the oceans through mineral oil, the steadily increasing CO₂ concentration of the atmosphere and the generation of vast amounts of waste heat, with effects on fauna and flora and human health that are difficult to keep track of. Compared to this, the environmental impact from storage schemes is mainly of an esthetic nature and of such negligible magnitude that further application of this soft technology can be advocated and justified before future generations.

Address of the author:

Dipl.-Ing. Dr. techn. Dr. h. c. Harald Lauffer
Gramartstrasse 20
A-6020 Innsbruck, Austria

7. References

ÖZE = Österreichische Zeitschrift für Elektrizitätswirtschaft
EuM = Elektrotechnik und Maschinenbau

Chapters 1 and 2

- Bundeslastverteiler im Auftrag des Bundesministeriums für Handel, Gewerbe und Industrie (BMHGI): Bundesstatistik der Österreichischen Elektrizitätswirtschaft, Betriebsstatistik 1981 and 1983. (Austrian electricity statistics.)
- Götz, A. and G. Schiller: Das Wasserkraftpotential Österreichs, Stand 1982. ÖZE, 35. Jg. (1982), H. 10. (Austria's hydro potential.)
- Grengg, H.: Wasserkraftwerke der Landesgesellschaften. Eine historische Würdigung. ÖZE, 20. Jg. (1967), H. 12. (The history of hydro schemes owned by Provincial Power Companies.)
- Lauffer, H.: Die Talsperren und Flußstauwerke Österreichs und der Wasserkraftausbau. Österreichische Wasserwirtschaft, 29. Jg. (1977), H. 9/10. (Austria's large dams and hydro power development.)
- Various authors: Die Landes-Elektrizitätsgesellschaften in Österreich (Sonderheft). ÖZE, 20. Jg. (1967), H. 12. (Provincial Power Companies in Austria.)
- Various authors: 25 Jahre Verbundkonzern (Sonderheft). ÖZE, 25. Jg. (1972), H. 8. (25 years of Verbund Combine.)

Chapter 3, relative to A + B (VIW)

- Ammann, A.: Die Vorarlberger Illwerke und der Bau des Lünseeewerkes. Schweizerische Wasser- und Energiewirtschaft (1956), H. 2. (Vorarlberger Illwerke and the construction of the Lünsee scheme.)
- Bundesministerium für Verkehr und verstaatlichte Betriebe (editor): Series "Österreichische Kraftwerke in Einzeldarstellungen"
- | | |
|------------------------------|-----------------|
| Werkgruppe "Obere Ill" | Folge 19 (1953) |
| Kraftwerk Latschau | Folge 22 (1955) |
| Kraftwerk Vermunt | Folge 24 (1956) |
| Kraftwerk Obervermunt | Folge 25 (1956) |
| Kraftwerk Rodund | Folge 27 (1956) |
| Kraftwerk Lünsee | Folge 30 (1960) |
- (Austrian power schemes.)
- Neukirchen, H.: Das Lünseeewerk. Österreichische Ingenieur-Zeitschrift, 2. Jg. (1959), H. 8, und Schweizerische Bauzeitung (1960), H. 45/46. (The Lünsee scheme.)
- Stefko, E.: Das Projekt Rodundwerk II, ein neues Pumpspeicherwerk der Vorarlberger Illwerke Aktiengesellschaft. Österreichische Wasserwirtschaft, 22. Jg. (1970), H. 7/8. (The Rodund II power project, a new pumped storage scheme owned by Vorarlberger Illwerke Aktiengesellschaft.)
- Various authors: Das Kopswerk (Sonderheft). ÖZE, 23. Jg. (1970), H. 7. (The Kops scheme.)

Chapter 3, relative to C, D and E (TIWAG)

- Bundesministerium für Verkehr und verstaatlichte Betriebe (editor): Österreichische Kraftwerke in Einzeldarstellungen, Kraftwerk Achensee (Achenseekraftwerk), Folge 26 (1956). (Austrian power schemes.)
- Hamann, F.: Die Dürrachüberleitung zum Achensee. ÖZE, 5. Jg. (1951), H. 12. (The Dürrach diversion to the Achensee lake.)
- Heller, E.: Das Achenseewerk. Zeitschrift des Österreichischen Ingenieur- und Architekten-Vereines, 78. Jg. (1926), S. 509ff. (The Achensee scheme.)
- Lauffer, H.: Das Kaunertalkraftwerk. Österreichische Wasserwirtschaft, 20. Jg. (1968), H. 7/8. (The Kaunertal scheme.)
- Lauffer, H.: Werkgruppe Sellrain-Silz. Vortrag, Wien (1980). (The Sellrain-Silz group of power schemes.)
- Lauffer, H. and W. Pircher: Sinking and supporting of an 80 m deep power station shaft of 30 m diameter. 4th ISRM Congress, Montreux 1979.

Steiner, R.: Wasserkraftwirtschaft in Tirol. Österreichische Wasserwirtschaft, 7. Jg. (1955), H. 8/9. (Hydro power economy in Tyrol.)

Chapter 3, relative to F, G and H (TKW)

- Grengg, H.: Das Großspeicherkraftwerk Glockner-Kaprun, Entwurf und Bauausführung 1938 bis 1945. Österreichische Bauzeitschrift, 7. Jg. (1952), H. 8 und 10, und Schriftenreihe des Österreichischen Wasserwirtschaftsverbandes, H. 23, 1952. (The Glockner-Kaprun large-scale storage scheme; design and construction 1938 to 1945.)
- Jüngling, O.: Das Gerloskraftwerk bei Zell am Ziller. Österreichische Wasserwirtschaft, 2. Jg. (1950), H. 8/9. (The Gerlos power scheme near Zell am Ziller.)
- Various authors: Die Hauptstufe des Tauernkraftwerkes Glockner-Kaprun, Festschrift der TKW 1951. (The main stage of the Glockner-Kaprun scheme.)
- Various authors: Die Oberstufe Glockner-Kaprun, Festschrift der TKW 1955. (The Glockner-Kaprun upper stage.)
- Various authors: Durlaßboden und Kraftwerk Funsingau (Sonderheft). ÖZE, 21. Jg. (1968), H. 8. (Durlaßboden dam and Funsingau power station.)
- Various authors: Zemmkraftwerke (Sonderheft). ÖZE, 25. Jg. (1972), H. 10. (Zemm development.)
- Widmann, R.: Die Zemmkraftwerke. Österreichische Ingenieur-Zeitschrift, 17. Jg. (1972), H. 2. (Zemm development.)
- Widmann, R.: Die Kraftwerksgruppe Zemm-Ziller. Österreichische Wasserwirtschaft, 35. Jg. (1983). (Zemm-Ziller group of power schemes.)

Chapter 3, relative to J (ÖBB)

- Ascher, H.: Das Kraftwert Stubach II. Wasserkraft und Wasserwirtschaft, 33. Jg. (1938), H. 11/12. (The Stubach II scheme.)
- Dvorak, F.: Die neue Tauernmoosperre. ÖZE, 23. Jg. (1970), H. 1. (The new Tauernmoossee dam.)
- Heilbrunner, J.: Aktuelles vom Kraftwerksbau der Österreichischen Bundesbahnen. Eisenbahntechnik (1982), H. 1. (Points of topical interest regarding the construction of power plants by the Austrian Federal Railways.)
- Hruschka, A.: Das Stubachwerk I. EuM, 49. Jg. (1931), H. 22—24. (Stubach scheme I.)
- Wohlgemuth, J.: Ausbau und Erneuerung der Stubachkraftwerke der Österreichischen Bundesbahnen — Die Beileitung Süd. EuM, 88. Jg. (1971), H. 2. (Extension and rehabilitation of the Austrian Railways' Stubach power scheme — South diversion.)

Chapter 3, relative to K (KELAG)

- Kießling, H.: Der Oscheniksee als Winterspeicher. Österreichische Wasserwirtschaft, 6. Jg. (1953), H. 12. (Lake Oschenik as a winter storage reservoir.)
- Kießling, H.: Die Kraftwerksgruppe Fragant. Österreichische Wasserwirtschaft, 31. Jg. (1979), H. 5/6. (The Fragant power scheme.)
- Various authors: Die Kraftwerksgruppe Fragant (Sonderheft). ÖZE, 22. Jg. (1969), H. 10. (The Fragant power scheme.)

Chapter 3, relative to L und M (ÖDK)

- Baustädter, K.: Überblick über Planung und Bau der Kraftwerksgruppe Malta der Österreichischen Draukraftwerke AG. Zement und Beton (1976), H. 5. (Highlights of the design and construction of the Malta group of power schemes owned by Österreichische Draukraftwerke AG.)
- Magnet, E.: Das Maltakraftwerk der Österreichischen Draukraftwerke AG. ÖZE, 24. Jg. (1971), H. 6. (Österreichische Draukraftwerke's Malta development.)
- Steinböck, W.: Planung und Bau des Winterspeicherwerkes Reißbeck-Kreuzeck. Österreichische Wasserwirtschaft, 5. Jg. (1953), H. 5/6. (Design and construction of the Reißbeck-Kreuzeck winter storage scheme.)

- Various authors: Winterspeicherkraftwerk Reißeck-Kreuzeck (Sonderheft). ÖZE, 13. Jg. (1960), H. 6. (The Reißeck-Kreuzeck winter storage scheme.)
- Various authors: Kraftwerksgruppe Malta (Sonderheft). ÖZE, 32. Jg. (1979), H. 1/2. (The Malta group of power schemes.)
- Chapters 4 and 5*
- Grenng, H.: Statistik 1971 der Talsperren, Kunstspeicher und Flußstauwerke. Schriftenreihe "Die Talsperren Österreichs", H. 19. (Statistics 1971 of large dams, artificial reservoirs and run-of-river plants.)
- Gsell, G. and E. Fastner: Die Druckrohrleitung des Kraftwerkes Malta. Der Bauingenieur, 50. Jg. (1975), H. 9. (The penstock of the Malta development.)
- Kießling, H.: Die Druckrohrleitung Wurten als Ergebnis einer neuen Entwicklung. ÖZE, 22. Jg. (1969), H. 10. (The Wurten penstock as a result of a recent development.)
- Lauffer, H.: Die Auswirkungen der Speicherkraftwerke auf die Umwelt. Österreichische Wasserwirtschaft, 27. Jg. (1975), H. 5/6. (The environmental impact of storage schemes.)
- Lauffer, H. and N. Sommer: Studies on sediment transport in mountain streams of the Eastern Alps. 14th ICOLD Congress, Rio de Janeiro 1982, R 28/Q 54.
- Lehmann, K.: Die Wasserkraftnutzung als Vorleistung zur touristischen Erschließung von Alpentälern. Pro Aqua — Pro Vita, Basel 1980, Bd. 8c. (Hydro power development paves the way for tourist development in Alpine valleys.)
- Machura, L.: Wasserkraftwerke als Problem der Landschaftspflege in Österreich. ÖZE, 25. Jg. (1972), H. 11. (Hydro development as a problem of landscape preservation in Austria.)
- Moschen, H.: Der Einfluß der Speicher und Überleitungen auf die Wasserführung des Inn in Tirol. Österreichische Wasserwirtschaft, 29. Jg. (1977), H. 5/6. (The effect of reservoirs and stream diversions on the flow regime of the River Inn in Tyrol.)
- Nyvelt, F.: Wasserkraftausbau und Umweltproblem. ÖZE, 25. Jg. (1972), H. 9. (Hydro development and environmental impacts.)
- Panel discussion: Soll der Wasserkraftausbau in Österreich fortgesetzt werden? Wasserwirtschaftstagung 1975 in Bad Gastein. Österreichische Wasserwirtschaft, 27. Jg. (1975), H. 11/12. (Is hydro development to be continued in Austria?)
- Partl, R.: Statistik 1977 der großen Talsperren und Flußstauwerke Österreichs. Schriftenreihe "Die Talsperren Österreichs", H. 24. (Translation published under the title of "Large Dams in Austria 1977".)
- Pircher, W. and H. Schwab: Monitoring and alarm equipment at the Finstertal and Gepatsch rockfill dams. 14th ICOLD Congress, Rio de Janeiro 1982, R 64/Q 52.
- Radler, S.: Auswirkung von Speichern auf die Umwelt. Wasserwirtschaft, 67. Jg. (1977), H. 7/8. (Environmental effects of storage reservoirs.)
- Rienöbl, K.: Auswirkung der alpinen Speicherkraftwerke auf die Probleme der Wildbachverbauung. Interpraevent-Tagung, Innsbruck 1975, Bd. 1. (Effects of Alpine storage schemes on the problems of torrent control.)
- Schober, W.: Besonderheiten beim Entwurf, bei der Ausführung und im Verhalten österreichischer Staudämme. Österreichische Wasserwirtschaft, 29. Jg. (1977), H. 9/10. (Special features of the design, construction and behaviour of embankment dams in Austria.)
- Schörghofer, W.: Speicherkraftwerke und Fremdenverkehr. ÖZE, 33. Jg. (1980), H. 9. (Storage schemes and tourist trade.)
- Seeber, G.: Neue Entwicklungen für Druckstollen und Druckschächte. Österreichische Ingenieur-Zeitschrift, 18. Jg. (1975), H. 5. (New developments for power tunnels and pressure shafts.)
- Simmler, H.: Wasserwirtschaft und Umweltstruktur. Österreichische Wasserwirtschaft, 27. Jg. (1975), H. 11/12. (Hydro resources management and the environmental make-up.)
- Stefko, E. and R. Widmann: Reservoirs and the environment in the high mountains. 11th ICOLD Congress, Madrid 1973, R 45/Q 40.
- Tollner, H.: Das Problem Umweltbeeinflussung durch alpine Wasserspeicher von Kraftwerken. ÖZE, 25. Jg. (1972), H. 10. (The problem of environmental effects from Alpine water reservoirs of power schemes.)
- Various authors: Strom aus Vorarlberg. 50 Jahre Vorarlberger Illwerke 1924—1974, Festschrift der VIW. (Electricity from Vorarlberg.)
- Vischer, D.: Der Einfluß der Wasserkraftnutzung auf die Umwelt. Österreichische Wasserwirtschaft, 27. Jg. (1975), H. 11/12. (The influence of hydro development on the environment.)
- Widmann, R.: Erfahrungen mit Hochwasserentlastungsanlagen österreichischer Talsperren. Österreichische Wasserwirtschaft, 26. Jg. (1974), H. 5/6. (Experience with flood relief works of Austrian dams.)
- Widmann, R.: Entwicklungen beim Bau österreichischer Staumauern. Österreichische Wasserwirtschaft, 29. Jg. (1977), H. 9/10. (Developments in the construction of concrete dams in Austria.)

TABLE 1. THE SEASONAL STORAGE SCHEMES OF VORARLBERGER ILLWERKE AG (VIW) BREGENZ, Part A
PART 1: CATCHMENTS, RESERVOIRS AND DIVERSIONS

A1 to A4: Part 1

POWER SCHEME (OWNER)		A UPPER ILL SCHEME (VIW)			
1		A1 Obervermunt (Obervermunt) Bludenz (Vorarlberg) 1943 (1950)	A2 Vermunt (Partenen) Bludenz (Vorarlberg) 1930 (1953)	A3 Kops (Partenen) Bludenz (Vorarlberg), Landeck (Tyrol) 1959	A4 Rifa Bludenz (Vorarlberg) 1959
2	Power stage (power station) District (province)				
3	Initial operation (extension)				
4					
5	River basins directly to res. diversions	111 (Rhein) 35 km ²	111 (Rhein) 22 km ²	111 (Rhein), Trisanna, Rosanna (Inn) 7 km ²	111 (Rhein) 0 km ²
6a	Utilised to stage	Bielaltbach 10 km ²	Valzifenbach 8 km ²	Zeinsbach 8 km ²	
6b	Catchments: trans-basin diversions		Vergaldnerbach 13 km ²	Fieberbach 39 km ²	
6c	and		Garnerbach 11 km ²	Larainbach 17 km ²	
6d	upstream		Valtüllabäde 8 km ²	Jambach 36 km ²	
6e	power stations			Kleinvermuntbach 20 km ²	
6f				Rosanna + Fasulbach 34 km ²	from Vermunt (A2) 107 km ²
6g				Verbellabach 9 km ²	from Kops (A3) 170 km ²
6	total	total 45 km ²	total 107 km ²	total 170 km ²	total 277 km ²
7	Reservoir: Name	Silvretta reservoir 2030/2014/1986 m	Vermunt reservoir 1743/1735/1719 m	Kops reservoir 1809/1778/1720 m	Rifa compensation reservoir *
8	Max./mean/min. water level	38,6 hm ³ (110 GWh)	5,3 hm ³ (12 GWh)	44 hm ³ (108 GWh)	1000/---/987,5 m 0,67 hm ³
9	Active storage (stored energy)				
10	Dam: Name	Silvretta dam	Vermunt dam	Kops dam	Rifa artificial basin
11a	Type	gravity	gravity	Arch dam with abutment gravity dam	12,5 m deep, earthfill dam downstream
11b	Height/crest length/crest level	straight 80/432 m/2032 m a.s.l.	straight, angled in plan 53/386 m/1744,7 m a.s.l.	double curvature 122/400 m - 1811 m a.s.l. - 43/214 m	asphaltic concrete facing
12	Volume	407,000 m ³ concrete *	144,000 m ³ concrete	485,000 m ³ concrete	14/700 m ³ /1001,5 m a.s.l.
13	Spillway: Type	overflow + side spillway	overflow + side spillway	overflow spillway in gravity dam	0,3 - 10 ⁶ m ³ earthfill
14	Capacity	36 m ³ /s + 68 m ³ /s for ca. 0,9 m surcharge	129 m ³ /s for 0,8 m surcharge	42 m ³ /s for 0,8 m surcharge	spillway with stone ramp
15					ca. 50 m long, crest 1001,1 m
16a	a) Name (catchment)	Bielaltbach trans-basin div. (6a)	Trans-basin div. of 111 tributaries (6a-c)	Paznaun div. to Jambach junction (6a+b-c)	none
17a	Stream intake: (number) Q _r - type	(1) 5,0 m ³ /s - T	(3) 1,2 + 2,5 + 2,0 m ³ /s - T	(3) 1,2 + 7,0 + 3,0 m ³ /s	
18a	Waterway: type	free-flow tunnel	free-flow tunnel	concrete pipe, free-flow tunnel, 2 sag pipes	
19a	Length/section	1,0 km/3 m ²	11,3 km/5 m ²	2,9 km/0,7 m Ø, 4,9 km/6 + 9 m ² , 1 km/1,4 + 1,6 m Ø	
16b	b) Name (catchment)		Valtüllabä trans-basin div. (6b)	Paznaun div.: Jambach junction (6b)	
17b	Stream intake: (number) Q _r - type		(2) 1,5 m ³ /s	(1) 7,0 m ³ /s	
18b	Waterway: type		pressure tunnel *	steel pipe	
19b	Length/section		6,0 km/2,2 m Ø	0,7 km/1,7 m Ø	
16c	c) Name (catchment)			Paznaun div. from Jambach junction (6c)	
17c	Stream intake: (number) Q _r - type			(1) 2,3 m ³ /s - T with 2P Kleinvermunt (A. 20)	
18c	Waterway: type			1 sag pipe, free-flow tunnel	
19c	Length/section			0,85 km/2,1 m Ø, 5,8 km/4 - 9 m ²	
16d	d) Name (catchment)			Fasul - Rosanna trans-basin div. (6d)	
17d	Stream intake: (number) Q _r - type			(2) 3,0 and 3,5 m ³ /s - T	
18d	Waterway: type			free-flow tunnel	
19d	Length/section			10,7 km/ 7,0 m ²	
16e	e) Name (catchment)			Verbellabä trans-basin div. (6e)	
17e	Stream intake: (number) Q _r - type			(1) 2,0 m ³ /s - T	
18e	Waterway: type			free-flow tunnel	
19e	Length/section			1,7 km/4,0 m ²	
20	(2P) Name (trans-b. diversion)			(2P) Kleinvermunt (16c)	
21	Feeder pumping Q _r /hr			2,3 m ³ /s / 164 m	
22	number of pumps x capacity			2 x 2,2 MW - 4,4 MW	
23a	Footnotes *				
23b	Abbreviations in line 17:				
23c	1.... tyrolean weir with sand trap				
23d					
23e					
23f					
23g					
23h					
23i					
23j					
23k					
23l					
23m					
23n					
23o					
23p					
23q					
23r					
23s					
23t					
23u					
23v					
23w					
23x					
23y					
23z					
23aa					
23ab					
23ac					
23ad					
23ae					
23af					
23ag					
23ah					
23ai					
23aj					
23ak					
23al					
23am					
23an					
23ao					
23ap					
23aq					
23ar					
23as					
23at					
23au					
23av					
23aw					
23ax					
23ay					
23az					
23ba					
23bb					
23bc					
23bd					
23be					
23bf					
23bg					
23bh					
23bi					
23bj					
23bk					
23bl					
23bm					
23bn					
23bo					
23bp					
23bq					
23br					
23bs					
23bt					
23bu					
23bv					
23bw					
23bx					
23by					
23bz					
23ca					
23cb					
23cc					
23cd					
23ce					
23cf					
23cg					
23ch					
23ci					
23cj					
23ck					
23cl					
23cm					
23cn					
23co					
23cp					
23cq					
23cr					
23cs					
23ct					
23cu					
23cv					
23cw					
23cx					
23cy					
23cz					
23da					
23db					
23dc					
23dd					
23de					
23df					
23dg					
23dh					
23di					
23dj					
23dk					
23dl					
23dm					
23dn					
23do					
23dp					
23dq					
23dr					
23ds					
23dt					
23du					
23dv					
23dw					
23dx					
23dy					
23dz					
23ea					
23eb					
23ec					
23ed					
23ee					
23ef					
23eg					
23eh					
23ei					
23ej					
23ek					
23el					
23em					
23en					
23eo					
23ep					
23eq					
23er					
23es					
23et					
23eu					
23ev					
23ew					
23ex					
23ey					
23ez					
23fa					
23fb					
23fc					
23fd					
23fe					
23ff					
23fg					
23fh					
23fi					
23fj					
23fk					
23fl					
23fm					
23fn					
23fo					
23fp					
23fq					
23fr					
23fs					
23ft					
23fu					
23fv					
23fw					
23fx					
23fy					
23fz					
23ga					
23gb					
23gc					
23gd					
23ge					
23gf					
23gg					
23gh					
23gi					
23gj					
23gk					
23gl					
23gm					
23gn					
23go					
23gp					
23gq					
23gr					
23gs					
23gt					
23gu					
23gv					
23gw					
23gx					
23gy					
23gz					
23ha					
23hb					
23hc					
23hd					
23he					
23hf					
23hg					
23hh					
23hi					
23hj					
23hk					
23hl					
23hm					
23hn					
23ho					
23hp					
23hq					
23hr					
23hs					
23ht					
23hu					
23hv					
23hw					
23hx					
23hy					
23hz					
23ia					
23ib					
23ic					
23id					
23ie					
23if					
23ig					
23ih					
23ii					
23ij					
23ik					
23il					
23im					
23in					
23io					
23ip					
23iq					
23ir					
23is					
23it					
23iu					
23iv					
23iw					
23ix					

TABLE 1, PART 2: HIGH-HEAD STAGES AND GENERATION

A1 to A4: Part 2

POWER SCHEME (OWNER)		A UPPER ILL SCHEME (VIW)			
30		A1 Obervermunt (Obervermunt)	A2 Vermunt (Partenen)	A3 Kops (Partenen)	A4 Rifa
T ... generating mode P ... pumping mode Mode of operation Max./mean/min. gross head Max. discharge Q _g (Q _p)		generation 311/279/243 m 14 m ³ /s	generation 727/714/694 m 26 m ³ /s	generation 780/748/690 m 37.5 m ³ /s	pumped storage *) 371.2 / - / 716.1 m 30 m ³ /s (30 m ³ /s)
STAGE	Intake gates	2 butterfly valves 2.2 m Ø not applicable	2 fixed-wheel gates + 1 fixed-wheel gate 2.8 x 4.7 m 3.2 x 3.2 m 2.5 ka/2.8 m Ø concrete	2 butterfly valves 2.6 m Ø 3.66 ka/3.25 m Ø 0.77 ka/3.25 m Ø concrete with internal prestressing gap grouting 4.8 ka/13 bar	1 fixed-wheel gate 5.4 x 4.2 m not applicable
	Power tunnel	not applicable	2.5 ka/4 bar 2-chamber, with orifice 2 penstocks, above-ground not applicable	concrete with internal prestressing gap grouting 4.8 ka/13 bar 2-chamber, with orifice 1 pressur shaft not applicable	1 penstocks, buried 550 m/3.0 m Ø reinforced concrete with plastic foil lining none
	Surge tank	not applicable	buttery valves (2 x 2) 1.7 m Ø	none	300 m/2.85 m Ø reinforced concrete with steel-lining
	Penstock or shaft: type	1 penstock, above-ground 3.27 ka/2.40 - 2.10 m Ø	steel pipe -, water-gas welded & riveted with expansion pieces & concrete thrust blocks above-ground with thrust blocks 72 / bar concrete canal 60 m/12.5 m ²	1227 m/2.6 m Ø steel-lined gap grouting concrete-embedded in pipe gallery, 6 branches 79/87 (exceptional 100) bar free-flow tunnel 200 m/34 m ² 200 m/34 m ²	concrete-embedded & earth-covered, 2 branches 38/53 bar 2 concrete canals 50 m/6 m ²
	Upper part	with expansion pieces & concrete thrust blocks see line 36	Partenen compensation reservoir (B1)	Partenen compensation reservoir (B1)	Rifa compensation reservoir (see line 7)
	Gates	3270/2.40 - 2.10 m Ø steel pipe, riveted with expansion pieces & concrete thrust blocks 1 manifold, buried 29 / 35 bar short tailrace canal	above-ground, steel frame 60 x 18 m, total height 20 m transformers in switchyard (5) horizontal, 500 rpm Pelton turbine, 2 jets 2 rotary valves each 0.6 and 0.7 m Ø (4) 665 m/5 m ³ /s / 29.6 MW (1) 665 m/6 m ³ /s / 36.8 MW 2 gates 5x3.5 m & 5x3.0 m (4) 30 MVA (1) 35 MVA (5) threephase, block-type (4) 30 MVA, (1) 35 MVA, 6/110 kV switchyard 110 kV	underground, concrete lining 70 x 26 m, total height 29 m transformer cavern 5x13 m, 13 m high turbine gates in machine hall (3) horizontal, 500 rpm 2 Pelton turbines, 2x2 jets, each 1 rotary valve 0.9 m Ø each 776 m/12.4 m ³ /s / 84.6 MW stop logs 102 MVA each, ring air cooling (3) threephase, block-type 102 MVA, 12.5/220 kV switchyard 220 kV *)	(2) vertical, 200 rpm 1 Deriaz pump turbine each 1 butterfly valve 1.7 m Ø each 28 m/13.5 m ³ /s / 3.3 MW 29 m/14 m ³ /s / 4.4 MW stop logs 5.6 MVA each, motor generator (2) threephase, block-type 5.6 MVA, 6/110 kV switchyard 110 kV
	Lower part	with expansion pieces & concrete thrust blocks			
	Manifold				
	Tailrace				
	Discharge to				
POWERHOUSE	Type	above-ground, reinforced concrete 30 x 12 m, total height 28 m transformers in open bays			
	Dimensions (without control building)				
	Special features				
	and position of transformers				
	(number) position, speed				
	type				
	upstream gates: type, int. Ø				
	T rating: H/Q/N				
	P rating: H/Q/N				
	downstream gates: type, diams.				
POWERHOUSE	generator: capacity, cooling				
	Transf.: (number) type, arrangement,				
	capacity, voltage ratio				
	Switchplant				
	Plant capacity of T and/or P: max.				
	Annual energy without short-t.pumping (with)				
	Winter share %/full-load h.p.a.				
	Annual P energy without short t.pump. (with)				
	Footnotes *)				

TABLE 11. THE SEASONAL STORAGE SCHEMES OF VORARLBERGER ILLWERKE AG (VIW) BREGENZ, Part B
PART 1: CATCHMENTS, RESERVOIRS AND DIVERSIONS

B1 to B4: Part 1

POWER SCHEME (OWNER)		B RODUND - LÜNERSEE SCHEME (VIW)			
1		B1 Latschau Bludenz (Vorarlberg) 1950 (free-flow tunnel since 1943)	B2 Lünensee 1958	B3 Rodund I 1943 (1952)	B4 Rodund II 1976
2	Power stage (power station)				
3	District (province)				
4	Initial operation (extension)				
5	River basins				
6a	directly to res.	111 (Rhein), Trisama, Rosama (111)	Alvier (111, Rhein)	111 (Rhein), Trisama, Rosama (111)	
6b	diversions	22 ka2	Lünensee		
6c	to stage	Tschambreu- and Valschaviebach 29 ka2	Brandner Gletscher		
6d	Utilised	Unter- Garmere- and Vermielbach 27 ka2			
6e	Catchments:	Suggadin- and Rasafiebach 72 ka2			
6f	trans-basin diversions	Reiltsbach 27 ka2			
6g	and	from Vermunt st. (A2) 107 ka2			
6h	upstream	from Kops st. (A3) 170 ka2			
6i	power stations				
6j	total	total 454 ka2	total 12 ka2		total 466 ka2
7	Reservoir: Name	Partenen compensation reservoir	Lünensee reservoir	Latschau I and II reservoirs *	
8	Max./mean/min. water level	1024,7/1016,1 m a.s.l.	1970/1939/1897 m a.s.l.	592,25/592,25/592,25 m a.s.l.	
9	Active storage (stored energy)	0,133 ha3	78,3 ha3 (255 GWh)	2,3 ha3 (2,5 GWh)	
10	Dam: Name	Partenen artificial basin	Lünensee dam	Artificial basin, 21 m deep	
11a	Type	8,6 m deep, downstream earthfill dam	gravity	West earth dam	
11b	Height/crest length/crest level	facing, 3 bitumen layers	several angles in plan	complete asphalt concrete facing	
12	Volume	10/250 m ³ /1026,0 m a.s.l.	30/380 m ³ /1971,6 m a.s.l.	50/480 m - dam crest 993,7 m a.s.l. - 22/260 m	
13	Spillway: Type	spillway, 20 m long	41.000 m ³ concrete	ca. 1,0·10 ⁶ m ³ earthfill	
14	Capacity	48 m ³ /s for 1,2 m surcharge	side spillway, 50 m long	3 siphon spillways	
15			12 m ³ /s for 0,25 m surcharge		
16a	a) Name (catchment)	111 - trans-basin diversion (6z)	a) Brandner Gletscher trans-basin diversion (6a)	none	
17a	Stream intake: (number) Q _r - type	(1) 7,0 m ³ /s rolling gate with sand trap	Intake under glacier		
18a	Waterway: type	concrete canal	drop shaft		
19a	Length/section	0,2 km/2 m2	free-flow tunnel		
16b	b) Name (catchment)	Tschambreu- & Valschaviebach diversion (6a)			
17b	Stream intake: (number) Q _r - type	(1) 1,0 m ³ /s - TE (1) 5,0 m ³ /s - TE			
18b	Waterway: type	steel pipe	prestr. concrete pipe		
19b	Length/section	0,8 km/1,2 m2	0,9 km/1,2 m2		
16c	c) Name (catchment)	Garmere- & Vermielbach diversion (6b)			
17c	Stream intake: (number) Q _r - type	(1) 4,5 m ³ /s - TE (1) 3,0 m ³ /s - TE			
18c	Waterway: type	concrete canal	pressure tunnel		
19c	Length/section	0,06 km/3,5 m2	0,17 km/1,4 m2		
16d	d) Name (catchment)	Suggadin- & Rasafiebach diversion (6c)			
17d	Stream intake: (number) Q _r - type	(1) 14,0 m ³ /s - TE (1) 5,0 m ³ /s - TE			
18d	Waterway: type	concrete canal, prestr.concr.pipe, reinf.concr.sag pipe			
19d	Length/section	0,16 km/5 m2	0,38 km/1,2 m2		
16e	e) Name (catchment)	Reiltsbach diversion (6d)			
17e	Stream intake: (number) Q _r - type	(1) 5,0 m ³ /s - TE			
18e	Waterway: type	concrete pipe	free-flow tunnel		
19e	Length/section	0,3 km/1,0 m2	2,9 km/4 m2		
20	(2P) Name (trans-basin diversion)				
21	Feeder pumping Q _r /H _g				
22	station: number of pumps x capacity				
23a	Footnotes *				
23b	Abbreviations in lines 17a to e:				
23c	TE Tyrolean weir with sand trap				
23d					
23e					
23f					

re. line 7: reservoirs I & II with connection gallery, separating dam - crest 5,25 m below I.W.L.

TABLE 11, PART 2: HIGH-HEAD STAGES AND GENERATION

TABLE 11, PART 2: HIGH-HEAD STAGES AND GENERATION						81 to 84: Part 2		
POWER SCHEME (OWNER)		B RODUND - LÜNERSEE SCHEME (VIW)						
T ... Power stage (power station) Mode of operation Max./mean/min. gross head Max. discharge Q_T (Q_p)	30	B1 Latschau generation 28/---/11 m 44 m ³ /s	B2 Lünersee pumped storage 975/944/902 m 32 m ³ /s (28 m ³ /s)	B3 Rodund I pumped storage 364/353/330 m 60 m ³ /s (10 m ³ /s)	B4 Rodund II pumped storage 364/354/330 m 90 m ³ /s (67 m ³ /s)			
	31	(2) sluice gates 4,0 x 3,7 m (compens. res. 1. 7) free flow channel 0,82 km 1,15 km covered reinf.-concr. trough concrete canal sag pipe bridges 18,74 km, Q_{max} increasing from 28 to 44 m ³ /s forebay *) T.W.L. 1002,9 m a.s.l. 2 penstocks not applicable gates (downstream of forebay 1. 40) (2) 4,0 x 3,7 m 122 m/2 x 2,85 m 64 m reinforced concrete pipe 58 m steel pipe not applicable direct draft tube outlets Latschau reservoir (83 and 84)	(2) butterfly valves 2,5 m ϕ (140 m downstream of intake) 1. power tunnel Salotien sag pipe 2. power tunnel 3,06 km 1,34 km 2,47 km 3,05 m ϕ 2,6 m ϕ and 2,4 m ϕ 3,05 m ϕ concrete st.-lined shaft, st.pipe concrete *) 6,9 km, 13 bar (sag pipe 34 bar) 2-chamber, with orifice 1 pressure shaft, 1 penstock 482 m/3,20 m ϕ inclined tunnel, steel-lined butterfly valve (valve chamber) (1) 2,50 m ϕ (1) 2,50 m ϕ 1046 m/2,25 m ϕ 916 m/2,15 m ϕ 421 m/2,05 m ϕ steel pipe with steep shaft low-grade section exo. pieces steel-lined steel-lined hanging, in gate ch., 6 branches 97 bar/111 bar (max. 126 bar) short concrete channels T : Latschau reservoir (83 & 84) T*) : Latschau forebay (81, 1. 40)	676 m/3,20 m ϕ 178 m/9,05 m ϕ low-grade section steel-lined steel-lined hanging, in pipe duct, 6 branches 35 bar/43 bar direct draft tube outlets Rodund I basin *) Rodund II basin *) 111, or Mallgau station (constructing)	fixed wheel gate not applicable not applicable 1 pressure shaft not applicable not applicable	122 m/5,0 m ϕ 473 m/4,15 m ϕ 80 m/4,15 & 2,9 m ϕ inclined tunnel steep section low-grade section concrete steel-lined steel-lined not applicable 39 bar/55 bar 60 m/6,6 m ϕ tunnel, concrete lining Rodund II basin *) 111, or Mallgau station (constructing)	bulkhead gates not applicable not applicable 1 pressure shaft not applicable not applicable	
	32	33	34	35	36			
	37	38	39	40	41	42		
43	44	45	46	47a	47b			
48	49	50a	50b	51a	51b			
52	53	54a	54b	55	56			
57	58	59	60	61	62			
63	64	65	66	67	68			
69	re, line 40: with 60 m long side spillway and chute into Latschau reservoir (83 and 84), at the same time pumping water channel) for pumped storage operation of 82						re, line 38: of which 0,66 km prestressed internal ring lining 3,10 m ϕ re, lines 51 and 59: when inflow to forebay is insufficient for pumping, three priming pumps 4,2 to 8,2 m ³ /s each can discharge to forebay	
Footnotes *)						re, line 51a: reservoir level 638,0 + 644,5 m a.s.l. re, line 56: on one unit only, installation possible on a further unit		

TABLE III. THE SEASONAL STORAGE SCHEMES OF TIROLER WASSERKRAFTWERKE AG (TIWAG) INNSBRUCK
PART 1: CATCHMENTS, RESERVOIRS AND DIVERSIONS

C + D + E: Part 1

POWER SCHEME (OWNER)		C KAUNERTAL SCHEME (TIWAG)		D SELLRAIN - SILZ SCHEME (TIWAG)		E ACHENSEE SCHEME (TIWAG)	
Power stage (power station) District (province) Initial operation (extension)	1	C. Kaunertal (Purtz) Landeck (Tyrol) 1964		D1 Upper stage (Kühtal) last (Tyrol) 1980		E Achensee (Jenbach) Schwaz (Tyrol) 1927 (1952)	
	2						
	3						
	4						
River basins	5	Fagge, Pitzbach, Pfunders B., (Inn) Faggenbach 107,3 ka2		Ütztaier Ache (Inn) Finstertaler Seen 6,0 ka2		Isar (Inn) Achensee 105,5 ka2	
directly to res.	6a	Faggenbach 107,3 ka2				Dürrache 55,0 ka2	
diversions	6b	Fischbach (diversion) 11,3 ka2				Kessebach 8,0 ka2	
to stage	6c	Kaunertal tributaries 32,2 ka2				Unterbach 9,0 ka2	
or	6d	Pitzbach, Taschbach 87,4 ka2				Ampelbach 28,8 ka2	
Catchments:	6e	Pfunders Bäche 41,0 ka2				Achenebach 11,8 ka2	
trans-basin diversions	6f						
and	6g						
upstream	6h						
power stations	6i						
	6j	total 279,2 ka2		total 6,0 ka2 *		total 218,1 ka2	
Reservoir:	7	Gepatsch reservoir 1767,0/1733,0/1665,0 m a.s.l.		Finstertal reservoir 2322/2287/2220 m a.s.l.		Achensee (nat. lake surface 929 m a.s.l.) 929,53/923,50/917,28 m a.s.l. 80,6 ha3 (62 6ha)	
Max./mean/min. water level	8	138,3 · 10 ⁶ m ³ (286 6ha)		60,9 ha3 (226 6ha)			
Active storage (stored energy)	9						
Dam:	10	Gepatsch dam rockfill with asphaltic concrete core		Finstertal dam rockfill with inclined asphaltic concrete core		Lake dam 11-bay weir with 9 stop logs and 2 gate leaves	
Name	11a	Gepatsch dam		Finstertal dam			
Type	11b	central earth core		asphaltic concrete core			
Height/crest length/crest level	12	153/600 m/1772 m a.s.l.		149/650 m/2325 m a.s.l.		0,75 m/24 m/929,53 m a.s.l.	
Volume	13	7,1 · 10 ⁶ m ³ fill		4,5 · 10 ⁶ m ³ fill		----	
Spillway: Type	14	bellmouth spillway 12,6 m Ø		side spillway 4,9 m long		over lake dam	
Capacity	15	250 m ³ /s for 2,0 m surcharge		3,0 m ³ /s for 0,5 m surcharge		ca. 100 m ³ /s	
a) Name (catchment)	16a	Fischbach diversion (6a)		Mitterbach trans-basin diversion (6a)		Dürrache trans-basin diversion (6a)	
Stream intake: (number) Q _r - type	17a	(1) 2,3 m ³ /s - TA *		(1) 0,9 m ³ /s - TA *		(1) 9,0 m ³ /s - *	
Waterway: type	18a	free-flow tunnel, drop shaft with cyclone		free-flow tunnel		free-flow tunnel and pressure tunnel + canal	
Length/section	19a	0,1 ka/4,2 m ² 0,2 ka/1,3 m Ø		0,1 ka/4,5 m ² 0,6 ka/0,5 m Ø		8,1 ka/6,5 m ² 1,6 ka/6,0 m ²	
b) Name (catchment)	16b	Blalbach trans-basin diversion (6b)		Stockach - (ZP) and Klambach (6b in part)		Kesselbach diversion (6b)	
Stream intake: (number) Q _r - type	17b	(1) 0,2 m ³ /s		(2) 0,5 m ³ /s and 0,7 m ³ /s - TA *		(1) 3,0 m ³ /s - TA *	
Waterway: type	18b	concrete pipe		concrete pipe		pressing tunnel, discharges into 18a	
Length/section	19b	0,4 ka/0,3 m Ø		concrete pipe		1,4 ka/6,5 m ²	
c) Name (catchment)	16c	Kaunertal Ost (6b)		Kaunertal Ost (6b)		Unterbach diversion (6c)	
Stream intake: (number) Q _r - type	17c	(5) 0,8 to 2,5 m ³ /s - TA *		(2) 0,5 m ³ /s and 0,7 m ³ /s - TA *		(1) 4,0 m ³ /s - T *	
Waterway: type	18c	free-flow tunnel; cast-iron pipe		free-flow tunnel		canal, discharges into 18a	
Length/section	19c	1,7 ka/4,6 m ² ; 0,4 ka/0,5 m Ø; 8,1 ka/5,8 m ²		free-flow tunnel; cast-iron pipe		0,3 ka/2,0 m ²	
d) Name (catchment)	16d	Pitzbach trans-basin diversion (6d)		Horlachbach trans-basin diversion (6e)		Ampelbach trans-basin diversion (6d)	
Stream intake: (number) Q _r - type	17d	(2) 5,4 m ³ /s - TA *		(1) 4,9 m ³ /s - TA *		(1) 3,6 m ³ /s - T *	
Waterway: type	18d	free-flow tunnel		free-flow tunnel		free-flow tunnel + canal with trough bridges	
Length/section	19d	1,8 ka/4,4 m ² 9,3 ka/7,4 m ²		5,5 ka/2,7 m Ø		2,8 ka/3,0 m ² + 4,5 ka/2,8 m ²	
e) Name (catchment)	16e	Radurschl trans-basin diversion (6d)				Achenbach trans-basin diversion (ZP) (6e)	
Stream intake: (number) Q _r - type	17e	(2) 3,0 m ³ /s and 4,4 m ³ /s - TA *				(1) 2,1 m ³ /s	
Waterway: type	18e	free-flow tunnel				riveted steel pipe, discharges into 18d	
Length/section	19e	2,1 ka/5,0 m ² 9,3 ka/6,5 m ²				240 m/1,30 m Ø	
(For abbreviations, see line 23)							
Diversions to stages and trans-basin diversions							
(ZP)	20	Name (trans-basin diversion)		(ZP) Stockachbach (16b)		(ZP) Achenkirch (16e)	
Feeder pumping Q _r /H or number	21			0,5 m ³ /s / 80 m		2,1 m ³ /s / 30 m	
station:	22			5 x 0,2 MW = 1 MW		2 x 0,25 + 1 x 0,40 = 0,90 MW	
Footnotes *	23a	re. line 17d: Taschach arch dam H/L = 12/59 m		re. line 6: reservoir filling by pumping from Längental reservoir (see 02)		re line 17a: Bächental arch dam H/L = 34/70 m	
Abbreviations:	23b	with frontal intake and 2 sand trap chambers					
T Tyrolean weirs	23c						
TA Tyrolean weirs with automatic sand trap flushing	23d						
	23e						
	23f						

TABLE III, PART 2: HIGH-HEAD STAGES AND GENERATION

C + D + E: Part 2

POWER SCHEME (OWNER)		C KAUHETAL SCHEME (TIWAG)	D SELLRAIN-SILZ SCHEME (TIWAG)		E ACHENSEE SCHEME (TIWAG)
T ... generating mode P ... pumping mode Mode of operation Max./mean/min. gross head Max. discharge Q_p (l/s)		C Kauhetal (Prutz)	D1 Upper stage (Küttai)	D2 Lower stage (Silz)	E Achensee (Jenbach)
30		generation only 995/661/793 m 53 m/s	pumped storage 440/394/319 m 80 (66) m/s	generation only 1258/1250/1239 m 48.3 m/s	generation only 396.8/390.7/384.5 m 28 m/s
POWER STAGE	Intake gates	butterfly valves (2) 3.50 m ϕ 8.8 km/4.0 m ϕ 3.4 km/4.0 m ϕ 1.0 km/4.0 m ϕ concrete with thin steel-lining hole grouting gap grouting int. concrete ring 13.2 km/15.7 bar	see lines 44 & 45 no surge tank no power tunnel	drop gates (2) 2.6 x 3.3 m 4.3 km/3.3 m ϕ 0.4 km/3.3 m ϕ concrete concrete with foil prestressing gap grouting 4.7 km/9.2 bar	gate (1) 4.4 x 3.3 m (2) 2.6 x 2.6 m 0.13 km 4.6 km / 2.6 x 2.65 m ϕ inlet section concrete lining caisson 4.6 km/4.5 bar 2-chamber, no orifice (1) pressure shaft
	Penstock or shaft: type	(1) pressure shaft 970 m/3.30 - 3.10 m ϕ steel-lining with gap grouting	(1) pressure shaft 300 m/4.40 m ϕ concrete lining with prestressing gap grouting	(1) pressure shaft 600 m/2.7 m ϕ steel-lining with int. concrete ring gap grouting	(1) pressure shaft
	Upper part	butterfly valve downstream of surge tank (1) 3.30 m ϕ 840 m/3.10 m ϕ 100 m/2.85 m ϕ steel-lining with penstock in gap grouting pipe gallery hanging, in hall, 10 branches	butterfly valves (2) 3.50 m ϕ isolation valves 700 m/4.0 m ϕ 500 m/4.0 m ϕ 300 m/3.0 m ϕ concrete with concrete with steel-lining prestr. gap grouting foil with gap grouting concrete-embedded manifold, 2 branches 49/80 bar	none (power tunnel with reverse gradient) 1700 m/2.6 - 2.2 m ϕ 100 m/2.2 m ϕ steel lining with penstock in gap grouting pipe gallery hanging, in pipe basement, 4 branches 126/150 bar	butterfly valves downstream of surge tank (2) 2.30 m ϕ isolation valves 513 m/2.30 m ϕ 80 m/2.0 m ϕ steel lining with penstock hole grouting in pipe gallery hanging, outdoor, 9 branches 39.7/44 bar
	Lower part	open canal 89.5/98.6 bar 300 m long	2 shafts 89 & 97 m/12.6 m ϕ concrete with foil and prestr. gap grouting Langental reservoir (D2)	open canal 1.2 km at the same time surge basin	open canal, 640 m concrete lining
	Manifold	inn			inn
	Tailrace				
	Discharge to				
	Type	above-ground, reinforced concrete 28 x 110 m (without pipe hall) transformers in outside recesses	shaft powerhouse with outdoor gantry crane 30 m ϕ , 80 m deep transformers in recesses of operat. building	above-ground, reinforced concrete 36 x 70 m (without pipe basement) transformers in outside recesses	above-ground, reinforced concrete & steel transformers in switchyard
	Special features (pos. of transf.)	(5) horizontal, 500 rpm 2 Pelton t., 2 x 2 jets, each 2 rotary valves, 0.85 m ϕ each 810 m/9.6 m/s / 84 MW bulkhead gates 100 MVA, ring air cooling each (5) three-phase, block-type 100 MVA, 10/240 kV switchyard	(2) vertical, 600 rpm 1 pump turbine each 1 rotary valve, 1.55 m ϕ each 418 m/38 m/s / 140 MW 319 m/34 m/s / 124 MW 1 gate, 3.6 x 1.8 m each 116 MVA, ring air cooling (2) three-phase, block-type 176 (=) MVA, 18/250 kV indoor 18 kV & 250 kV	(2) vertical, 500 rpm 1 Pelton turbine, 2x jets, each 2 rotary valves, 1.1 m ϕ , each 1159 m/24 m/s / 242 MW bulkhead gates 352 MVA each, complete water cooling (2) three-phase, block-type 352 MVA, 17.5/250 kV switchyard 250 kV	50 Hz rotary c., (15 2/3 Hz traction current s.l. 69) (2) horizontal, 500 rpm 2 Pelton t., each, 2x2 jets, 2x2 jets 1 sluice valve each, 2 sluice valves and 1 rot. valve 380 m/3.5 m/s/11.3 MW (2) 380 m/7.0 m/s/22.8 MW (1) 380 m/7.1 m/s/23.5 MW none 13 MVA each, fresh-air c. (3) 25 MVA, fresh-air c. (2) 13 MVA, 5.5/110 kV (3) 25 MVA, 5.5/110 kV switchyard 110 kV rot. c. 50 Hz + traction c. 16 2/3 Hz
	Power units	(number) position, speed type and arrangement upstream gates: type, int. ϕ T rating: H/Q/N P rating: H/Q/N downstream gates: type, dim. generator: capacity, type Transf.: (number) type, arrangement, capacity, voltage ratio			none 13 MVA each, fresh-air c. (3) 25 MVA, fresh-air c. (2) 13 MVA, 5.5/110 kV (3) 25 MVA, 5.5/110 kV switchyard 110 kV rot. c. 50 Hz + traction c. 16 2/3 Hz
	Switchplant				
	Plant capacity of I and/or P: max./mean	I: 390/370 MW 620 GWh 59 % / 1590 h	I: 287/230 MW P: 247/235 MW 55.5 (259.7) GWh 84 % / 195 h (75 %/905 h) 64.5 (336) GWh	I: 488/484 MW 459 GWh 42 % / 940 h 1.5 GWh (2P Stockbach)	I: 80 MW 213.5 GWh 53 % / 2700 h 4.1 GWh (2P Achenkirch)
	Annual energy without short-t.pumping (with)				
	Winter share % / full-load h _{max}				
	Annual P energy without short-t.pumping (with)				
Footnotes *		re. lines 62 & 63: can be overloaded to 270 MVA 2-unit service through 1 transformer is possible			re. 1. 54b: 16 2/3 Hz traction current 1. 55 : (3) horizontal, 500 rpm 1. 56 : 1 Pelton turbine, 2 jets, each 1. 57 : 1 jet valve 1. 58 : 380 m/1.9 m/s / 5.9 MW 1. 61 : 5 MVA each, fresh-air cooling 1. 62 & 63: (1) singlephase, 15 MVA, 5.5/110 kV 1. 64 : switchyard 5.5 kV and 110 kV

TABLE IV. THE SEASONAL STORAGE SCHEMES OF TAUKENKRAFTWERKE AG (TKW) SALZBURG, IN THE ZILLER VALLEY
PART 1: CATCHMENTS, RESERVOIRS AND DIVERSIONS

POWER SCHEME (OWNER)			F ZEMM - ZILLER SCHEME (TKW)			G GERLOS SCHEME (TKW)		
1	Power stage (power station) District (province) Initial operation (extension)	F1 Zemm upper stage (Reihag) Schwaz (Tiroi) 1970	F2 Main stage (Mayrhofen) Schwaz (Tiroi) 1971	F3 Ziller upper stage (Häusling) Schwaz (Tiroi) 1986	G1 Gerlos upper stage (Eunsingau) Schwaz (Tiroi) 1967	G2 Gerlos lower stage (Gerlos) Schwaz (Tiroi) 1948		
5	River basins	Zaserbach, Zemmabach, Luchbach (Ziller)	Tuxb., Zemb., Stillupb., Ziller (Ziller)	Ziller, Gerlos (Ziller)	Wilde Gerlos (Ziller), Salzach	Gerlosbach (Ziller)		
6a	directly to res.	Schlegeisgründ	Stillupgründ	Zillergründ	Wilde Gerlos	Gerlosbach		
6b	diversions	57,8 ka2	61,0 ka2	29,8 ka2	43,9 ka2	99,1 ka2		
6c	to stage	8,3 ka2	33,9 ka2			6,0 ka2		
6d	or	Kesselbach (div.)	Untere Zemm + Igentbach	Sunderbach	Oberste Salzach	Mühlbach (div.)		
6e	trans-basin diversions	6,6 ka2	102,4 ka2	12,3 ka2	20,4 ka2	Schwarzachbach		
6f	and	Falscheitenb. + Alelebach	Gungobach	Hundskühlbach	Nadernbach			
6g	upstream	Obere Zemm	Flotte	Schönbach				
6h	power stations	Tuxbühle	Untere Ziller	Wimmerbach				
6i		11,4 ka2	45,4 ka2	4,0 ka2				
6j		11,4 ka2	57,5 ka2					
6k	total	123,4 ka2	389,4 ka2	67,5 ka2	74,6 ka2	103,0 ka2		
7	Reservoir: Name	Schlegeis reservoir	Stillup reservoir	Zillergründl reservoir	Durlaboden reservoir	Günd reservoir *		
8	Max./mean/min. water level	1782/1747,9/1680 m a.s.l.	1120/1113,9/1105 m a.s.l.	1850/1808,1/1740 m a.s.l.	1405/1388/1360 m a.s.l.	1190,2/1187/1176 m a.s.l.		
9	Active storage (stored energy)	127,7 ha3 (320 GWh)	6,9 ha3 (1,4 GWh)	88,8 ha3 (240 GWh)	51,2 ha3 (82 GWh)	0,7 ha3		
10	Dam: Name	Schlegeis dam	Eberlaste dam	Zillergründl dam	Durlaboden dam	Gründ dam		
11a	Type	arch dam	gravelfill with asphaltic concrete core	arch dam	gravelfill	original arch dam		
11b	Height/crest length/crest level	131x125 m/1783 & 1784,3 m a.s.l.	28x480 m/1124,0 m a.s.l.	with elliptic arches	with central earth core	reinforced as arch gravity		
12	Volume	960,000 m3 concrete	0,85,106 m3 fill	186x505 m/1850,7 & 1852,0 m a.s.l.	70x470 m/1409 m a.s.l.	37x69 m/1192,4 m a.s.l. (parapet)		
13	Spillway: Type	lateral bellmouth	lateral bellmouth	side spillway	lateral bellmouth	22,000 m3 concrete overflow		
14	Capacity	200 (324) m3/s for 1,5 (2,0) m surcharge	450 m3/s for 2,6 m surcharge	165 m3/s for 1,35 m surcharge	200 m3/s for 1,65 m surcharge	216 m3/s for 2,00 m surcharge		
15								
16a	a) Name (catchment)	Pitzenbach trans-basin diversion (6a)	Untere Zemm and Igentbach diversion (6a)	South trans-basin diversion (6ac)	Nadernbach trans-basin div. (6c)	Mühlbach trans-basin diversion (6a)		
17a	Stream intake: (number) Q _r - type	(2) 0,6 m3/s - TA	(2) 8,0 m3/s * 0,8 m3/s - TA	(2) 2,5 m3/s * and 3,2 m3/s *	(1) 1,5 m3/s - TA	(1) 0,5 m3/s - T		
18a	Waterway: length/section	discharges into upper chamber of line 40	free-flow t., rock shaft, discharges into	free-flow tunnel	free-flow tunnels, discharges into	free-flow tunnel - pressure tunnel		
19a			1,6 ka/6,2 m2 95 m/1,4 m2 F1 1,50F	4,5 + 2,8 ka/3,0 m Ø ZP see line 20	1,9 ka/4,4 m2	0,14 ka/4 m2, 0,21 ka/2,0 m Ø		
16b	b) Name (catchment)	Kesselbach, Mesendle-Lapenkarb, div. (6ab)	Gungobach diversion (6c)	North trans-basin diversion (6de)	Salzach trans-basin diversion (6b)	Schwarzach trans-basin div. (6b)		
17b	Stream intake: (number) Q _r - type	(3) 1,1 m3/s, 0,6 m3/s, 0,9 m3/s - TA	(1) 3,0 m3/s - TA	(2) 0,8 m3/s - TA 1,2 m3/s - TA	(1) 3,0 m3/s overflow weir	(1) 1,0 m3/s overflow weir		
18b	Waterway: length/section	one steel-lined shaft each	steel-lined shaft, discharges into F1	free-flow tunnel	free-flow tunnel	concrete canal		
19b		0,2x0,3 ka/0,7 m Ø discharges into 1, 37	259 m/0,8 m Ø	4,9 + 1,7 ka/3,0 m Ø	2,3 ka/4,4 m2	0,73 ka/0,54 m2		
16c	c) Name (catchment)	Falscheitenb. + Alelebach trans-b. div. (6c)	Floitenbach diversion (6d)					
17c	Stream intake: (number) Q _r - type	(2) 0,5 m3/s - TA	(1) 8,0 m3/s *					
18c	Waterway: type	free-flow tunnel	free-flow tunnel & shaft discharges					
19c		0,7 ka/4 m2 0,2 ka/6 m2	148 m/1,4 m Ø 0,9 ka/4 m2 into F1 1,50F					
16d	d) Name (catchment)	Oberer Zemm trans-basin diversion (6d)	Bodenbach diversion (6f)					
17d	Stream intake: (number) Q _r - type	(1) 8 m3/s, fixed weir *	(1) 2,5 m3/s - TA					
18d	Waterway: type	free-flow tunnel	free-flow tunnel, discharges into F3					
19d		6,0 ka/5,8 m2	74 m/1,8 m2					
16e	e) Name (catchment)	Luchbach trans-basin diversion (6e)	Untere Ziller diversion (6e)					
17e	Stream intake: (number) Q _r - type	(3) 1,6 m3/s, 0,5 m3/s, 0,5 m3/s - TA	(1) 10 m3/s, overflow weir *					
18e	Waterway: type	free-flow tunnel	free-flow tunnel, discharges into F3					
19e		0,3 + 0,1 + 6,8 ka/5,8 m2	2,9 ka/7,8 m2					
20	(For abbreviations, see line 23)							
21	(ZP) Name (trans-basin div.)			(ZP) Klambühl (6a & b)				
22	Feeder pumping Q _r /H _{gr} or nr. of pumps x capacity			9 m3/s / 70 m 3 x 2,7 = 8,1 MW				
23a	Footnotes *	re. line 17d: overflow weir with lateral inlet and sand trap	re. line 17a, c & e: overflow weir with lateral inlet and sand trap	re. line 17a: overflow weir with lateral inlet and sand trap		re. line 7: bed load diversion through 0,5 km concrete pipe and 0,6 km tunnel 2,0 m Ø		
23b	Abbreviations:					re line 18a: discharges into pressure tunnel line 37		
23c	T Tyrolean weir							
23d	TA Tyrolean weir with automatic sand trap flushing							
23e								
23f								

TABLE IV, PART 2: HIGH-HEAD STAGES AND GENERATION

TABLE IV, PART 2: HIGH-HEAD STAGES AND GENERATION									
POWER SCHEME (OWNER)		F ZEMM - ZILLER SCHEME (TKW)			G GERLOS SCHEME (TKW)			F + G: Part 2	
		F1 Zemm upper stage (Rohlag)	F2 Main stage (Mayhofen)	F3 Ziller upper stage (Häusling)	G1 Gerlos upper stage (Funsingau)	G2 Gerlos lower stage (Gerlos)			
21	Power stage (power station)	pumped storage	generation only	pumped storage	generation only	generation only			
32	T...generating mode P...pumping mode	676/634/560 m	476/470/462 m	744/694/620 m	135/110/90 m	614/611/600 m			
33	Max./mean/min. gross head	50 (36) m ³ /s	92 m ³ /s	65 (50) m ³ /s	25.7 m ³ /s	13.5 m ³ /s			
34	Max. discharge Q _p (l/s)								
35	Intake	sluice gate + fixed wheel gate	fixed wheel gate	butterfly valves	gate	gate			
36	(number) cross section	(2) 2.7 x 2.7 m	(2) 4.5 x 3.8 m	(2) 3.9 m Ø	(1) 2.5 x 2.5 m	(1) 2.5 x 2.5 m			
37	length sections/int. Ø	7.70 km/4.0 m Ø	3.27 km/5.1 m Ø	7.40 km/4.2 ÷ 4.1 m Ø	2.42 km/2.9 m Ø	4.85 km/2.5 m Ø			
38a	lining	concrete	concrete	concrete + seal, foil	concrete + shotcrete	concrete			
38b	total length/max. pressure	borehole grouting	borehole grouting	borehole grouting	prestressing borehole grouting	int. concrete ring			
39	Surge tank	2.77 km / 19 bar	2.36 km / 8 bar	7.76 km / 20 bar	2.54 km / 9 bar	5.98 km / 3.2 bar			
40	Penstock	2-chambers (rev. flow control throttle)	2-chamber (rev. flow control throttle)	2-chamber, rev. flow control throttle	2-chamber	2-chamber with over/low			
41	gates: type, position	butterfly valve downstream of s. t.	butterfly valve downstream of surge tunnel	butterfly valve downstream of surge tunnel	(1) penstock	(1) pressure shaft			
44	or	(1) 3.1 m Ø	(1) 3.2 m Ø	(1) 3.4 m Ø	(1) 2.4 m Ø	(1) 3.0 x 3.2 m			
45	(number) cross section	897 m/3.1 ÷ 2.9 m Ø	892 m/3.9 ÷ 3.7 m Ø	60 m/4.2 ÷ 3.7 m Ø	175 m/2.4 ÷ 2.25 m Ø	1270 m/2.2 ÷ 1.6 m Ø			
46	length sections, int. Ø	339 m/2.9 m Ø	299 m/3.7 m Ø	925 m/3.7 m Ø	steel pipe	low-grade section			
47a	construction	high-grade section	high-grade section	steel-lining	buried	steel-lining			
47b	Manifold	concrete embedded, 2 runs, 4 branches each	hanging, outdoor, 2 runs, 6 branches each	concrete embedded, 2 runs, 2 branches each	end thrust block in p.h. foundation	(2) hanging, in pipe basement			
48	position	75 / 83 bar	48 / 53 bar	80/103 bar	13.5 / 11.5 bar	61 / 65 bar			
49	max. pressure = stat./dyn.	(1) power tunnel, 8.4 km	surge basin J = 0.035 m ² with	(1) power tunnel, 7.7 km	forebay	open canal, 230 m long			
50a	Design, total length	100 m/3.8 m Ø	regulating sill	252 m/4.2 m Ø					
50b	valley-sections/int. Ø	steel pipe in pipe duct	butterfly valve	steel pipe					
50c	crossing	butterfly valve	butterfly valve	butterfly valve					
50d	gates-type, position	(1) 3.8 m Ø	(1) 3.8 m Ø	(1) 4.2 m Ø					
50e	(number) cross sections	2-chamber with orifice *	2-chamber with orifice *	2-chamber with orifice					
50f	surge tank	0.4 km/6.0 m Ø, 3.3 km/15.2 m ² = 2	4.4 km/4.3 m Ø	0.13 km/4.4 m Ø					
50g	pressure sections/int. Ø	concrete	concrete	steel-lining					
50h	tunnel lining	in pipe duct	concrete	concrete					
51	Discharge to	Stillupp reservoir (F2)	Stillupp reservoir (Zemm, Ziller)	Stillupp reservoir (F2)	Gerlosbach (blind reservoir G2)	Gerlosbach (Ziller)			
52	Type	foot of slope, earth-covered, reinf. concrete	above-ground, reinforced concrete	foot of slope, earth-covered, reinf. steel	above-ground, reinforced concrete	at foot of slope, reinforced concrete			
53	Dimensions (without control building)	80 x 27 m, total height 38 m	142 x 28 m, total height 21 m	powerhouse shaft 35 m Ø, 50 m deep		45 x 13 m, total height 22 m			
54a	Special features (pos. of transf.)	transformers in closed	transformer in open	transformers in indoor bays		transformers in open bays in the switchyard			
54b	(number) position, speed	external-wall recesses	external-wall recesses	(2) vertical, 600 rpm		(4) vertical, 600 rpm			
55	type and arrangement	(4) vertical, 750 rpm	(6) horizontal, 375 rpm	Francis turbine + two-stage pump + converter	(1) Francis turbine	(1) Pelton turbine, 2 jets			
56	upstream gates: type, int. Ø	T: rot. valve 1.1 m Ø, P: rot. valve 1.0 m Ø	2 Pelton turbines, 2 x 2 jets, each	1 rotary valve 1.7 m Ø each for T & P	(1) butterfly valve 2.25 m Ø	(1) rotary valve 0.5 m Ø			
57	T rating: H/Q/N	538 m/12.5 m ³ /s / 57.5 MW	2 rotary valves 1.2 m Ø, each	610 m/32.5 m ³ /s / 180 MW	111 m/25.7 m ³ /s / 25.6 MW	(2) 578 m/3.0 m ³ /s / 15.4 MW			
58	P rating: H/Q/N	570 m/9.0 m ³ /s / 60.0 MW	447 m/15 m ³ /s / 59 MW	640 m/25 m ³ /s / 180 MW	---	(2) 578 m/3.8 m ³ /s / 17.7 MW			
59	downstream gates: type, dim.	T: wicket 1.6 m Ø P: butterfly valve 1.6 m Ø	bulkhead gates	1 wicket 2.6 m Ø each for T, 2.4 m Ø for P	bulkhead gate	(1) 22 MVA			
60	generator: capacity, type	motor generator 65 MVA, ring air cooling	65 MVA each, ring air cooling	motor generator 195 MW	(1) 27 MVA, generator	(4) threephase, block-type			
61	Transf.: (number) type, arrangement	2x3 singlephase, block-type for 2 units each	3x3 singlephase, block-type for 2 units each	1x3 singlephase, block-arrang. for the 2 units	(1) threephase, block-type	18.5 MVA, 10/115 kV			
62	capacity, voltage ratio	44 MVA, 10/220 kV	44 MVA, 10/220 kV	134 MVA, 20/220 kV	2718 MVA, 10/1150 kV	switchyard 115 kV			
63	Switchplant	220 kV (SF6)	switchyard 220 kV	indoor 220 kV (SF6)	switchyard 115 kV				
64									
65	Plant capacity of I and/or P: max.	T: 230 MW P: 240 MW	T: 345 MW P: 360 MW	T: 360 MW P: 360 MW	T: 25 MW	T: 65 MW			
66	Annual energy without short-t.pump. (with)	284 (534) GWh	613 GWh	176 GWh (684 GWh)	25 GWh	294 GWh			
67	Winter share % / full-load h _{p.p.}	76 % / 1720 h (59 % / 2320 h)	51 % / 1780 h	91 % / 490 h (56 % / 1900 h)	74 % / 1000 h	45 % / 4920 h			
68	Annual P energy without short-t.pump. (with)	---	(362 GWh)	7 GWh (726 GWh)	---	---			
69	Footnotes *	res. line 50f - h: lower chamber as part of power conduit							

TABLE V. THE SEASONAL STORAGE SCHEMES OF TAUERNKRAFTWERKE AG (TKW) IN THE KAPRUN VALLEY
PART 1: CATCHMENTS, RESERVOIRS AND DIVERSIONS

H: Part 1

POWER SCHEME (OWNER)		H GLOCKNER - KAPRUN SCHEME (TKW)				
1		H1	Möll trans-basin diversion (umping station) Pinzgau (Salzburg), Spittal (Carinthia) 1992	H2	Kaprun upper stage Pinzgau (Salzburg) 1955	
2	Power stage (power station) District (province) Initial operation (extension)	3		4	H3	Kaprun lower stage Pinzgau (Salzburg) 1944 (1951 and 1973)
5	River basins directly to res. diversions to stage or trans-basin diversions and upstream power stations	6		6a		Kapruner Ache, Fuschler Ache (Salzach) Kapruner Ache Zerferbach (div.) Grubbach (div.) Hirzbach 14,5 km ² 4,4 km ² 4,5 km ² 8,1 km ²
6b	Utilised Catchments:	6c		6d		
6e		6f		6g		
6h		6i		6j		
6k		6l		6m		
6n		6o		6p		
6q		6r		6s		
6t		6u		6v		
6w		6x		6y		
6z		6aa		6ab		
6ac		6ad		6ae		
6af		6ag		6ah		
6ai		6aj		6ak		
6al		6am		6an		
6ao		6ap		6aq		
6ar		6as		6at		
6au		6av		6aw		
6ax		6ay		6az		
6ba		6bb		6bc		
6bd		6be		6bf		
6bg		6bh		6bi		
6bj		6bk		6bl		
6bm		6bn		6bo		
6bp		6bq		6br		
6bs		6bt		6bu		
6bv		6bw		6bx		
6b		6c		6d		
6e		6f		6g		
6f		6g		6h		
6g		6h		6i		
6h		6i		6j		
6i		6j		6k		
6j		6k		6l		
6k		6l		6m		
6l		6m		6n		
6m		6n		6o		
6n		6o		6p		
6o		6p		6q		
6p		6q		6r		
6q		6r		6s		
6r		6s		6t		
6s		6t		6u		
6t		6u		6v		
6u		6v		6w		
6v		6w		6x		
6w		6x		6y		
6x		6y		6z		
6y		6z		6aa		
6z		6aa		6ab		
6aa		6ab		6ac		
6ab		6ac		6ad		
6ac		6ad		6ae		
6ad		6ae		6af		
6ae		6af		6ag		
6af		6ag		6ah		
6ag		6ah		6ai		
6ah		6ai		6aj		
6ai		6aj		6ak		
6aj		6ak		6al		
6ak		6al		6am		
6al		6am		6an		
6am		6an		6ao		
6an		6ao		6ap		
6ao		6ap		6aq		
6ap		6aq		6ar		
6aq		6ar		6as		
6ar		6as		6at		
6as		6at		6au		
6at		6au		6av		
6au		6av		6aw		
6av		6aw		6ax		
6aw		6ax		6ay		
6ax		6ay		6az		
6ay		6az		6ba		
6az		6ba		6bb		
6ba		6bb		6bc		
6bb		6bc		6bd		
6bc		6bd		6be		
6bd		6be		6bf		
6be		6bf		6bg		
6bf		6bg		6bh		
6bg		6bh		6bi		
6bh		6bi		6bj		
6bi		6bj		6bk		
6bj		6bk		6bl		
6bk		6bl		6bm		
6bl		6bm		6bn		
6bm		6bn		6bo		
6bn		6bo		6bp		
6bo		6bp		6bq		
6bp		6bq		6br		
6bq		6br		6bs		
6br		6bs		6bt		
6bs		6bt		6bu		
6bt		6bu		6bv		
6bu		6bv		6bw		
6bv		6bw		6bx		
6bw		6bx		6by		
6bx		6by		6bz		
6by		6bz		6ca		
6bz		6ca		6cb		
6ca		6cb		6cc		
6cb		6cc		6cd		
6cc		6cd		6ce		
6cd		6ce		6cf		
6ce		6cf		6cg		
6cf		6cg		6ch		
6cg		6ch		6ci		
6ch		6ci		6cj		
6ci		6cj		6ck		
6cj		6ck		6cl		
6ck		6cl		6cm		
6cl		6cm		6cn		
6cm		6cn		6co		
6cn		6co		6cp		
6co		6cp		6cq		
6cp		6cq		6cr		
6cq		6cr		6cs		
6cr		6cs		6ct		
6cs		6ct		6cu		
6ct		6cu		6cv		
6cu		6cv		6cw		
6cv		6cw		6cx		
6cw		6cx		6cy		
6cx		6cy		6cz		
6cy		6cz		6da		
6cz		6da		6db		
6da		6db		6dc		
6db		6dc		6dd		
6dc		6dd		6de		
6dd		6de		6df		
6de		6df		6dg		
6df		6dg		6dh		
6dg		6dh		6di		
6dh		6di		6dj		
6di		6dj		6dk		
6dj		6dk		6dl		
6dk		6dl		6dm		
6dl		6dm		6dn		
6dm		6dn		6do		
6dn		6do		6dp		
6do		6dp		6dq		
6dp		6dq		6dr		
6dq		6dr		6ds		
6dr		6ds		6dt		
6ds		6dt		6du		
6dt		6du		6dv		
6du		6dv		6dw		
6dv		6dw		6dx		
6dw		6dx		6dy		
6dx		6dy		6dz		
6dy		6dz		6ea		
6dz		6ea		6eb		
6ea		6eb		6ec		
6eb		6ec		6ed		
6ec		6ed		6ee		
6ed		6ee		6ef		
6ee		6ef		6eg		
6ef		6eg		6eh		
6eg		6eh		6ei		
6eh		6ei		6ej		
6ei		6ej		6ek		
6ej		6ek		6el		
6ek		6el		6em		
6el		6em		6en		
6em		6en		6eo		
6en		6eo		6ep		
6eo		6ep		6eq		
6ep		6eq		6er		
6eq		6er		6es		
6er		6es		6et		
6es		6et		6eu		
6et		6eu		6ev		
6eu		6ev		6ew		
6ev		6ew		6ex		
6ew		6ex		6ey		
6ex		6ey		6ez		
6ey		6ez		6fa		
6ez		6fa		6fb		
6fa		6fb		6fc		
6fb		6fc		6fd		
6fc		6fd		6fe		
6fd		6fe		6ff		
6fe		6ff		6fg		
6ff		6fg		6fh		
6fg		6fh		6fi		
6fh		6fi		6fj		
6fi		6fj		6fk		
6fj		6fk		6fl		
6fk		6fl		6fm		
6fl		6fm		6fn		
6fm		6fn		6fo		
6fn		6fo		6fp		
6fo		6fp		6fq		
6fp		6fq		6fr		
6fq		6fr		6fs		
6fr		6fs		6ft		
6fs		6ft		6fu		
6ft		6fu		6fv		
6fu		6fv		6fw		
6fv		6fw		6fx		
6fw		6fx		6fy		
6fx		6fy		6fz		
6fy		6fz		6ga		
6fz		6ga		6gb		
6ga		6gb		6gc		
6gb		6gc		6gd		
6gc		6gd		6ge		
6gd		6ge		6gf		
6ge		6gf		6gg		
6gf		6gg		6gh		
6gg		6gh		6gi		
6gh		6gi		6gj		
6gi		6gj		6gk		
6gj		6gk		6gl		
6gk		6gl		6gm		
6gl		6gm		6gn		
6gm		6gn		6go		
6gn		6go		6gp		
6go		6gp		6gq		
6gp		6gq		6gr		
6gq		6gr		6gs		
6gr		6gs		6gt		
6gs		6gt		6gu		
6gt		6gu		6gv		
6gu		6gv		6gw		
6gv		6gw		6gx		
6gw		6gx		6gy		
6gx		6gy		6gz		
6gy		6gz		6ha		
6gz		6ha		6hb		
6ha		6hb		6hc		
6hb		6hc		6hd		
6hc		6hd		6he		
6hd		6he		6hf		
6he		6hf		6hg		
6hf		6hg		6hh		
6hg		6hh		6hi		
6hh		6hi		6hj		
6hi		6hj		6hk		
6hj		6hk		6hl		
6hk		6hl		6hm		
6hl		6hm		6hn		
6hm		6hn		6ho		
6hn		6ho		6hp		
6ho		6hp		6hq		
6hp		6hq		6hr		
6hq		6hr		6hs		
6hr		6hs		6ht		
6hs		6ht		6hu		
6ht		6hu		6hv		
6hu		6hv		6hw		
6hv		6hw		6hx		
6hw		6hx		6hy		
6hx		6hy		6hz		
6hy		6hz		6ia		
6hz		6ia		6ib		
6ia		6ib		6ic		
6ib		6ic		6id		
6ic		6id		6ie		
6id		6ie		6if		
6ie		6if		6ig		
6if		6ig		6ih		
6ig		6ih		6ii		
6ih		6ii		6ij		
6ii		6ij		6ik		
6ij		6ik		6il		
6ik		6il		6im		
6il		6im		6in		
6im		6in		6io		
6in		6io		6ip		
6io		6ip		6iq		
6ip		6iq		6ir		
6iq		6ir		6is		

TABLE V, PART 2: HIGH-HEAD STAGES AND GENERATION

POWER SCHEME (OWNER)		H GLOCKNER-KAPRUN SCHEME (TKW)		
30		H1 Möll trans-basin diversion (pumping station)	H2 Kaprun upper stage	H3 Kaprun lower stage
T ... generating mode P ... pumping mode Mode of operation Max./min. gross head Max. discharge Q_p (Q_p)	31	only pumping for H2 *	pumped storage 446/364/288 m 36.0 m ³ /s (33.2 m ³ /s)	generation only 89/857/809 m 36.5 m ³ /s
	32	56/12/-20 m (20 m ³ /s)		
	33			
	34			
	35			
POWER CONDUIT OF STAGE (For diversions, see line 6 and line 16)	36	(2) gates 2.5 x 2.5 m (at Möll dam)	(2) butterfly valves 2.8 m ϕ (in pump cavern H1)	(2) butterfly valves 2.8 m ϕ
	37	11.6 m (2.9 - 3.2 m ϕ)	0.4 km/3.5 m ϕ 0.07 km/2.8 m ϕ 3.92 km/3.3 m ϕ	5.4 km/3.34 - 3.2 m ϕ 1.6 km/3.20 m ϕ
	38a	partly concrete, partly shotcrete only	steel pipe (or concrete) steel pipe concrete with shotcrete	concrete with plaster prestressed concrete partly reinf. shotcrete *
	38b		(inlet section) (pumping st.)	7.1 km/11.4 bar
	39	11.6 km/7 bar	4.3 km/11.4 bar	
	40	2-chamber	2-chamber	
	41	not applicable	(1) pressure shaft not applicable	(1) inclined tunnel + (4) penstocks *
	42			613 m/3.0 m ϕ
	43a			steel-lining with caulked joints
	43b			(4) rotary valves + (4) butterfly valves
	44	(1) butterfly valve	(1) butterfly valve (2) rotary valves	1.2 m ϕ 1.4 m ϕ
	45	2.8 m ϕ (in pump cavern)	2.8 m ϕ (below surge tank) 1.7 m ϕ (below low-grade section)	1,200 m (2) 1.30 - 1.15 m ϕ + (2) 1.35 - 1.25 m ϕ
	46		460 m/2.9 - 2.7 m ϕ 180 m/2.5 m ϕ 40 m/2 x 1.70 m ϕ	steel pipe
	47a		steel lining	steel pipe
	47b		high-grade section	with expansion pieces and concrete thrust blocks
	48	P inlet: above-ground with 4 branches	2 manifolds with 2 branches each in pipe basement	4 manifolds (2 branches each), concrete-embedded
	49	P outlet: above-ground with 2 branches		89/99 bar
	50a	pressure tunnel from H2	48/51 & 65 bar	covered concrete channel
	50b	0.4 km/3.5 m ϕ to inlet	(2) steel pipes 2.2 m ϕ	
	51	Hoersboden dam (H2)	concrete-embedded in Linberg dam Wasserfallboden reservoir (H3)	Kapruner Ache
POWERHOUSE	52	underground, east of Drossendamm (H2)	at foot of Linberg dam, reinforced concrete	at foot of slope, earth-covered, reinforced concrete
	53	46 x 17 m, total height 19 m	80 x 30 m, total height 30 m	94 x 35 m, total height 25 m
	54a	inclined shaft for access	transformers in indoor bays	transformers in indoor bays
	54b	power supply through 10 kV cable		
	55	(2) horizontal, 495 rpm	(2) horizontal, 500 rpm	(4) horizontal, 500 rpm
	56	single-stage double-flow pumps	Francis turbine + two-stage pumps	2 Pelton turbines, 2 x 1 & 2 x 2 jets, each
	57	2 needle valves 1.4 m ϕ	T: 1 rotary valve 1.4 m ϕ P: 1 needle valve 1.5 m ϕ	2 rotary valves 0.7 m ϕ & 0.85 m ϕ , each
	58	69 - 30 m/5.5 - 13.5 m ³ /s (6.7 MW)	T: 363 m/18 m ³ /s /57 MW	T (2) 845 m/6 m ³ /s /45 MW
	59	4 rotary valves 1.1 m ϕ	P: 320 m/16.6 m ³ /s /62 MW	P (2) 845 m/9 m ³ /s /66 MW
	60	2 asyn.-motors 16.7 MW	T: 1 rotary valve 1.5 m ϕ P: 1 needle valve 1.4 m ϕ	stop logs
	61	10 kV switchplant in upper stage powerhouse	motor generator 63 MVA	(2) 50 MVA, (2) 70 MVA
	62		(2) three-phase, block-type	(4) three-phase, block-type
	63		63 MVA, 10/110 kV	(2) 50 MVA, (2) 70 MVA, 10/110 kV
	64		indoor 110 kV	switchyard 110 kV and 220 kV
Plant capacity of T and/or P: max. Annual energy without short-t.pumping (with short-t.p.) Winter share % / full load h.p.q. Annual P energy without short t.p. pumping (with)	65	P: 13.4 MW	T: 112 MW P: 130 MW	T: 220 MW
	66		152 GWh (252 GWh)	454 GWh
	67		57 % /1360 h (58 % /2250 h)	85 % /2060 h
	68	15 GWh	(156 GWh)	----
Footnotes *	69	re. line 32: Upper stage (H2) can alternatively be operated as power station from Margaritz reservoir and directly discharge to Wasserfallboden reservoir of main stage (H3)		re. line 38b: Rings made up of precast segments were prestressed according to a wire-wrapping method and grouted after placing. re. line 41: Covered with arcs and earth over their lower portion.

TABLE VI. THE SEASONAL STORAGE SCHEMES ÖSTERREICHISCHE BUNDESBÄHNEN (ÖBB) IN THE STUBACH VALLEY
PART 1: CATCHMENTS, RESERVOIRS AND DIVERSIONS

J: Part 1

POWER SCHEME (OWNER)		J STUBACH SCHEME (ÖBB)			
1		J1	J2	J3	J4
Power stage (power station) District (province) Initial operation (extension)		Aersee - Weißsee (remote reservoir) Pinzgau (Salzburg) 1952 (1959)	Upper stage (I Enzingerboden) Pinzgau (Salzburg) 1929 (1974)	Middle stage (II Schneiderau) Pinzgau (Salzburg) 1940 (1962)	Lower stage (III Uttendorf) Pinzgau (Salzburg) 1948 (1956)
River basins directly to res. diversions to stage or Utilised Catchments: trans-basin diversions and upstream power stations	5 6a 6b 6c 6d 6e 6f total	Stubach (Salzach) Weissenbach Aerbach Salzlattensee Eisbach total 10,7 km ²	Stubach (Salzach), Landeckbach (Isel) Tauernmoosbach Landeckbach Seebach Seetörlbach Schotterbach Hurtbach from Weißsee (J1) 10,1 km ² total 50,1 km ²	Stubach (Salzach) Stubach Wegenbach Hurtbach from Grünsee *) 4,7 km ² from upper stage (J2) 50,1 km ² total 64,1 km ²	Stubach (Salzach) Stubach Schrofenbach Übbach Bödelbach from middle stage (J3) 64,1 km ² total 97,3 km ²
Reservoir: Name Max./mean/min. water level Active storage (stored energy)	7 8 9	Aersee res. Salzlattensee res. Weißsee res. 2279,5/2247 m asl; 2296,5/2261,4 m asl; 250/219,1 m asl 5,6 km ³ (13,3 GWh) 1,1 km ³ (2,6 GWh) 16,0 km ³ (38 GWh)	Tauernmoossee reservoir 2023/2007/1984,5 m a.s.l. 55,3 km ³ (131 GWh)	Enzingerboden compensation reservoir 1463,5/1461,5/1459 m a.s.l. 0,3 km ³	no reservoir --- imounding admissible to 1035,7 m a.s.l.
Dam: Name Type	10 11a 11b 12 13 14 15	Aersee dam Salzlattensee dam Weißsee dam (side dam) gravity gravity gravity straight straight straight 30/162 m 16/88 m 37/235 (8/64) m 20.300 m ³ 5.300 m ³ 59.000 (700) m ³ side spillway overflow overflow/side dam 15 m long 69 m long 23 m ³ /s for 0,7 m surcharge	New Tauernmoos dam gravity dam with hollow space arch action in the uppermost part 250.000 m ³ concrete side spillway, 75 m long 108 m ³ /s for 1,0 m surcharge	Enzingerboden dam gravity straight 29/76 m/1465 m a.s.l. 11.000 m ³ concrete lateral chute, 52 m long 60 m ³ /s for 0,6 m surcharge	Schneiderau weir vertical-lift gate weir with sand trap 3 bays 4,0 m wide each see line 11
a) Name (catchment) Stream intake: (number) Q _r - type Waterway: type Length/section b) Name (catchment) Stream intake: (number) Q _r - type Waterway: type Length/section c) Name (catchment) Stream intake: (number) Q _r - type Waterway: type Length/section d) Name (catchment) Stream intake: (number) Q _r - type Waterway: type Length/section e) Name (catchment) Stream intake: (number) Q _r - type Waterway: type Length/section (for abbreviations, see line 23)	16a 17a 18a 19a 16b 17b 18b 19b 16c 17c 18c 19c 16d 17d 18d 19d 16e 17e 18e 19e	a) North diversion - Aersee to Eisbach (6a) Aersee reservoir free-flow tunnel 1,85 km/6 m ² b) North diversion - Salzlattensee to 18a (6b) Salzlattensee reservoir pressure tunnel free-flow tunnel 0,1 km/3,4 m ² 0,4 km/3,4 m ² c) North diversion from Eisbach (6c) (1) 1,5 m ³ /s - T free-flow tunnel 3,8 km/6 m ² d) South diversion to lower Landeckbach intake (6d) cast-iron pipe in gallery 0,3 km/0,6 m ² discharges into 18b (1) 1,25 m ³ /s, concrete dam free-flow tunnel 6,4 + 0,5 km/5,2 m ² e) Upper Hurtbach diversion (6e) (3) total ca. 1,2 m ³ /s - T free-flow tunnel 2,2 km/6,6 m ²	a) South diversion and power station *) (6a) (1) 1,5 m ³ /s, concrete dam cast-iron pipe 0,4 km/0,6 m ² b) South diversion to upper Landeckbach intake (6b+c) (1) 7 m ³ /s - TA + sec. intakes free-flow tunnel 2,0 km/5,2 m ² c) South diversion to lower Landeckbach intake (6b) (1) 1 m ³ /s - TA with TP (see line 20) cast-iron pipe in gallery 0,3 km/0,6 m ² discharges into 18b d) South div. from upper Landeckbach intake (6d) (1) 1,25 m ³ /s, concrete dam free-flow tunnel 6,4 + 0,5 km/5,2 m ² e) Upper Hurtbach diversion (6e) (3) total ca. 1,2 m ³ /s - T free-flow tunnel 2,2 km/6,6 m ²	a) Hosenbach diversion (6a) (1) 0,7 m ³ /s - T cast-iron pipe 0,24 km/0,2 m ² b) Mittlerer Hurtbach trans-basin div. (6b) (1) 4 m ³ /s - T free-flow tunnel 1,7 km/2,9 m ²	a) Schrofenbach diversion (6a) (1) ca. 0,3 m ³ /s drop shaft b) Übbach trans-basin diversion (6b+c) (2) total 2,2 m ³ /s - T concrete canal 0,9 km/1,3 m ²
	20 21 22	(2P) Landeckbach (s. l. 17c) 1 m ³ /s / 80 m 3 x 0,4 MW = 1,2 MW			
	23a 23b 23c 23d 23e	re. l. 16a and 20: south power station between Seebach and 18b (0,8 m ³ /s / 210 m / 1,2 MW) for power supply to (2P) Landeckbach	re. l. 6f: Grünsee-Enzingerboden power station for station service supply		
Footnotes *) Abbreviations: T Tyrolean weir TA Tyrolean weir with automatic sand trap flushing					

TABLE VI, PART 2: HIGH-HEAD STAGES AND GENERATION

POWER SCHEME (OWNER)		J STUBACH SCHEME (ÜBB)			
30	Power stage (power station) T ... generating mode P ... pumping mode Mode of operation Max./mean/min. gross head Max. discharge Q_1 (Q_p)	J1 Aeressee - Weißsee remote storage for J2 *) 6.0 m ³ /s	J2 Upper stage (I Enzingerboden) generation 558/542/520 m 17.6 m ³ /s	J3 Middle stage (II Schneiderau) generation 428 m 10.5 m ³ /s	J4 Lower stage (III Uttendorf) generation 244 m 15.0 m ³ /s
31	Intake gates	(1) needle valve	(2) butterfly valves 2.0 m ϕ 0.8 km/3.10 m ϕ concrete with prestressing gap grouting 0.8 km/6.4 bar	(2) gates 2.5 x 3.0 m 1.54 km/2.1 \pm 2.5 m ϕ partly concrete partly shotcrete only 1.54 km/2 bar	gates 7.1 km/5.4 m ² free-flow tunnel gallery holding 30,000 m ³ of water (1) penstock ----- ----- ----- rapid closing gate (1) 4.6 x 6.3 m 650 m/1.7 m ϕ steel pipe with expansion pieces and concrete thrust blocks 1 piping run covered channel
32	Power tunnel	0.1 km/1.5 m ϕ steel pipe in gallery (free discharge to Tauernmoos reservoir)	2-chamber (1) pressure shaft ----- ----- ----- none ----- 880 m/2.3 m ϕ 200 m/2.3 - 1.9 m ϕ high-grade section low-grade section steel-lining hanging, outdoor, 6 branches short free-flow channel	2-chamber (2) penstocks 50 m/1.80 m ϕ (1) connection tunnel steel-lined butterfly valves (2) 1.6 m ϕ 1270 m/2 x 1.7 \pm 1.2 m ϕ steel pipe with expansion pieces and concrete thrust blocks 2 piping runs short, partly covered channel	(1) penstock ----- ----- ----- rapid closing gate (1) 4.6 x 6.3 m 650 m/1.7 m ϕ steel pipe with expansion pieces and concrete thrust blocks 1 piping run covered channel
33	Surge tank				
34	Penstock or shaft: type				
35	Upper part				
36	Lower part				
37	Gates				
38	Lower part				
39	Manifold				
40	Tailrace				
41	Discharge to				
42					
43					
44					
45					
46					
47					
48					
49					
50					
51					
52	Type	Tauernmoossee reservoir (J2)	Enzingerboden compensation reservoir (J3)		
53	Dimensions (without control building)		above-ground, reinforced concrete 87 x 13 m, total height 19 m transformers in switchyard traction current 16 2/3 Hz	above-ground, reinforced concrete 58 x 19 m, total height 19 m transformers in switchyard traction current 16 2/3 Hz	above-ground, reinforced concrete 64 x 18 m, total height 18 m transformers in switchyard traction current 16 2/3 Hz
54	Special features		(2) horizontal, 333 rpm 1 Pelton t. w.1 jet each 2 Pelton t. w.2 jets each 1 needle valve 0.8 m ϕ each 2 rot.valves 0.7 m ϕ each 525 m/2.7 m ³ /s / 13 MW 525/6 m ³ /s / 28 MW	(2) horizontal, 500 rpm 2 Pelton t. w.2 jets each 1 Pelton t. w.2 jets each 1 needle valve 0.8 m ϕ each 1 rot.valve 0.8 m ϕ each 420 m/3.6 m ³ /s / 12.1 MW 420 m/3.5 m ³ /s / 11.8 MW	(3) horizontal, 333 rpm 2 Pelton turbines with 2 jets each 1 radial valve 0.6 m ϕ each 227 m/4.9 m ³ /s / 9.0 MW
55	(number) position, speed				
56	type and arrangement				
57	upstream gates: Type, int. ϕ				
58	T rating: H/Q/N				
59	P rating: H/Q/N				
60	downstream gates: type, dia.				
61	generator: capacity, type				
62	Transf.: (number) type, arrangement				
63	capacity, voltage ratio				
64	Switchplant				
65	Plant capacity of T and/or P, max.				
66	Annual energy without short-t.pumping (with)				
67	Winter share % / full-load h.p.a.				
68	Annual P energy without short-t.pumping (with)				
69	Footnotes *)	re. Line 32: Construction of a high-head stage between Weisssee and Tauernmoossee reservoirs (J2) is planned			

TABLE VII. THE SEASONAL STORAGE SCHEMES OF KELAG
PART 1: CATCHMENTS, RESERVOIRS AND DIVERSIONS

K1 to K4: Part 1

POWER SCHEME (OWNER)		K1 to K4 FRAGRANT SCHEME, UPPER REGION WITH SEASONAL STORAGE RESERVOIRS			
1		K1 Zirmsee trans-basin diversion Spittal (Carinthia) 1982	K2 Zirknitz Spittal (Carinthia) 1974	K3 Wurten (Innerfragant) Spittal (Carinthia) 1969	K4 Oschenik (Innerfragant) Spittal (Carinthia) 1968/1980
2	Power stage (power station) District (province) Initial operation (extension)				
3					
4					
5	River basins				
6a	directly to res. diversions	Zirmsee Fließbach Bretsee	Großsee + Hochwurten Schwarzsee Stühle + Gastrop Weißsee	Fließbach, Zirknitzbach, Wurtenbach (Möll) Wurtenbach Feldsee Zirknitzbäche Fließbäche Gutthal, Tauern- and Hoferbach from Zirknitz power stage (K2)	Oscheniksee pumped storage from Wurten stage (K3) and Haselstein stage (K1)
6b	to stage	2,7 km ² 2,0 km ² 1,2 km ²	7,3 km ² 1,7 km ² 3,6 km ² 0,9 km ² 5,9 km ²	7,7 km ² 1,6 km ² 18,5 km ² 21,8 km ² 13,7 km ² 24,1 km ²	1,7 km ²
6c	Utilised				
6d	Catchments:				
6e	Trans-basin diversions				
6f	and				
6g	upstream				
6h	power stations				
6i	total	total 5,9 km ²	total 24,1 km ²	total 87,4 km ²	total 1,7 km ²
7	Reservoir: Name	Zirmsee reservoir (interm. constr. stage)	Großsee reservoir + Hochwurten (1. 23)	Murtenala reservoir + Feldsee remote storage res.	Oscheniksee reservoir
8	Max./mean/min. water level	2529,5/-/2487,0	2417/2398/2330	1695/1688/1675	2391/2348/2245
9	Active storage (stored energy)	8,65 km ³ (32 GWh)	26,7 km ³ (98 GWh)	2,7 km ³ (5,8 GWh)	33 km ³ (82 GWh)
10	Dam: Name	Zirmsee dam	Großsee dam	Wurten dam	Oschenik dam
11a	Type	rockfill with	rockfill	rockfill	rockfill
11b	Height/crest length/crest level	asphaltic concrete facing	with asphaltic concrete facing	asphaltic concrete facing	with asphaltic concrete facing
12	Volume	44/315 m/2524,5 m a.s.l.	46/445 m/255/260 m/2420 m a.s.l.	42/282 m/1699 m a.s.l.	116/730 m/2394 m a.s.l.
13	Soil/Type	0,47-10 ⁶ m ³ fill	0,74-10 ⁶ m ³ + 0,60-10 ⁶ m ³ fill	0,265-10 ⁶ m ³ fill	2,3-10 ⁶ m ³ fill
14	Capacity	trapezoidal or rectangular channel	trapezoidal channel + pipe	bellmouth spillway 11,0 m Ø trapez. channel	trapezoidal channel
15		11,7 m ³ /s for 1,4 m surcharge	6,7 m ³ /s + 21,0 m ³ /s for 1,4 m surcharge	160 m ³ /s for 1,7 m surch. 25 m ³ /s for 1 m surcharge	6,4 m ³ /s for 1,2 m surcharge
16a	a) Name (catchment)	Fließbach diversion (6a)	Schwarzsee trans-basin div. (6a) 2P to 16c	Zirknitzbäche trans-basin div. + K2 (6b + e)	none
17a	Stream intake: (number) Q _r - type	(1) 1,5 m ³ /s - concrete dam	(1) 0,26 m ³ /s - concrete dam	(2) 1,4 m ³ /s and 1,1 m ³ /s - TA	
18a	Waterway: type	pressure tunnel, discharges into 37	plastic pipe, concrete-encased	free-flow tunnel	
19a	Length/section	0,77 km/9,6 m ²	0,75 km/0,4 m Ø	8,62 km/6,71 m ²	
16b	b) Name (catchment)	Bretsee diversion (6b)	Stühle trans-basin diversion (6b) 2P to 16c	Fließbäche trans-basin diversion (6c) to 16a	
17b	Stream intake: (number) Q _r - type	tapping of lake	(6) total 0,6 m ³ /s - T	(2) 1,6 m ³ /s and 1,2 m ³ /s - TA	
18b	Waterway: type	discharges into 37	plastic pipe, concrete-encased	free-flow tunnel plastic pipe	
19b	Length/section	0,37 km/9,6 m ²	0,85 km/0,5 - 0,7 m Ø	5,5 km/6,71 m ² 0,1 km/0,5 m ²	
16c	c) Name (catchment)		Weißsee trans-basin div. (6c+6ab) 2P to 7	Gutthalbach trans-basin diversion (6d) to 16b	
17c	Stream intake: (number) Q _r - type		(1) 1,04 m ³ /s - fill dam	(3) 0,15 to 0,75 m ³ /s - TA	
18c	Waterway: type		plastic pipe, concrete-encased	plastic pipe free-flow tunnel	
19c	Length/section		0,4 km/0,4 m Ø	7,4 km/0,5 m ² 0,5 km/4,5 m ²	
16d	d) Name (catchment)		Kegelsee trans-basin diversion (6d) 2P to 46		
17d	Stream intake: (number) Q _r - type		(1) 0,5 m ³ /s - concrete dam		
18d	Waterway: type		plastic pipe, concrete-encased		
19d	Length/section		0,5 km/0,6 m Ø		
16e	e) Name (catchment)				
17e	Stream intake: (number) Q _r - type				
18e	Waterway: type				
19e	Length/section				
20	(2P) Name (trans-basin diversion)		2P Stühle (16b)	2P Kegelsee (16d)	
21	Feeder pumping Q _r /h _{gr}	0,26 m ³ /s / 41 m	0,6 m ³ /s / 157 m	0,5 m ³ /s / 252 m	
22	station: number of pumps x capacity	(1) 0,13 MW	(1) 1,2 MW	(1) 1,5 MW	
23a	Footnotes *)		reservoir connected in parallel, connection tunnel 1,8 km/6,5 m ²		
23b	Abbreviation in line 17a to e:				
23c	T Tyrolean weir				
23d	TA Tyrolean weir with automatic sand trap flushing				
23e					

TABLE VII, PART 2: HIGH-HEAD STAGES AND GENERATION

K1 to K4: Part 2

POWER SCHEME (OWNER)		K1 to K4 FRAGRANT SCHEME (KELAG), UPPER REGION WITH SEASONAL STORAGE RESERVOIRS			
T ... generating mode P ... pumping mode Mode of operation Max. mean/min. gross head Max. discharge Q_T (Q_p)	30	K1 Zimsee trans-basin diversion	K2 Zirknitz (Zirknitz)	K3 Wurten (Innerfragant)	K4 Oschenik (Innerfragant)
	31	remote storage for K2 (see 1. 69)	generation only 689/670/602 m 11.4 m ³ /s	generation only (see 1. 69) 490/483/470 m 16 m ³ /s	pumped storage (see 1. 69) 1186/1143/1040 m 10 m ³ /s (13 m ³ /s)
Intake (number) cross section length sections/int. ϕ lining Power tunnel total length/max. pressure	35	stop logs (2) 2.2 x 2.0 m 7.0 km/7.7 m ² shotcrete in places	0.62 km/6.5 m ² concrete	1.2 km/4.5 m ² concrete	see 1. 44/45 not applicable
	36	7.0 km partly free-flow tunnel with free discharge	0.62 km/10 bar 2-chamber (1) penstock	1.2 km/10 bar 2-chamber (1) penstock	not applicable (1) pressure shaft 0.5 km/4.0 m ² 0.15 km/1.9 m ϕ concrete prestressing gap grouting butterfly valve
Surge tank Penstock or shaft: type length sections/int. ϕ construction	39	not applicable at present	3.1 km/1.20 x 0.8 m ϕ steel pipe, concrete-encased without thrust blocks & expansion pieces concrete-embedded, 2 branches 69/79 bar free-flow tunnel	butterfly valves (2) 1.80 m ϕ 1.2 km/2.0 x 1.7 m ϕ steel pipe, partly concrete-encased on socketed steel columns, no thrust blocks in pipe hall, partly concrete-embedded, 6 branches 49/62 (exception 75) bar	(1) 1.60 m ϕ 2.1 km/1.70 m ϕ , 0.3 km/1.45 m ϕ , 0.1 km/1.30 m ϕ steel-lining (see also line 69) penstock drainage and gap grouting hanging, in pipe hall, 6 branches 120/148 bar concrete canal, discharges into 37 of K6 0.3 km/7.3 m ²
	40				stage K2, or Innerfragant reservoir
Upper part for diversions, see line 6a	41				
	42				
Gates (number) cross section length sections/int. ϕ construction	43a				
	43b				
Lower part	44				
	45				
Manifold position max. pressure - stat./dyn.	46				
	47a				
Tailrace Discharge to	47b				
	48				
	49				
	50a				
	50b				
	51	Großsee reservoir (K2)	Zirknitzbach trans-basin diversion (16a of K3)	stage K2, or Innerfragant reservoir	as K3
Type Dimensions (without control building) Special features	52		above-ground, reinforced concrete 32 x 14 m	above-ground, reinforced concrete 116 x 26 m in common with K4 transformers against external wall	
	53				
(number) position, speed type and arrangement upstream gates: type, int. ϕ T rating: H/Q/N P rating: H/Q/N	54a				
	54b				
downstream gates: type, dia. generator: type, capacity Transf.: (number) type, arrangement capacity, voltage ratio	55		(2) horizontal, 600 rpm 1 Pelton turbine, 2 jets, each 1 rotary valve 0.6 m ϕ each 667 m/2.84 m ³ /s / 16 MW	(2) horizontal, 500 rpm 2 Pelton turbines, 2 x 2 jets, each 2 rotary valves 0.8 m ϕ each 485 m/7.0 x 8.8 m ³ /s / 36 + 40 MW	(3) horizontal, 750 rpm 1 pelton turbine, 2 jets, each + 1 storage pump 1 1 rot. valve 0.7 m ϕ each + 1 P rotary valve 1143 m/2 x 3.0 + 1 x 4.2 m ³ /s / 2 x 33 + 1 x 42 MW see line 69
	56				
Switchplant	57				
	58				
Plant capacity of I and/or P: max. Annual energy without short-t. pumping (with) Winter share % / full-load h.p.a. Annual P energy without short-t. pumping (with)	59		stop logs 1 synchr. generator 16 MVA each (2) three-phase (1) 55 MVA, 10.5/115 kV (1) 16 MVA, 10.5/21 kV 10.5, 21 and 115 kV (SFG) - indoor	stop logs 1 synchr. generator each 32 & 40 MVA (2) three-phase, block-type 40 MVA, 10.5/115 kV 115 kV indoor	T - stop logs P - rotary valve 1.0 m ϕ 1 motor generator 2 x 33 + 1 x 42 MVA, each (3) three-phase, block-type 1 x 33 MVA 1 x 40 MVA 1 x 42 MVA 115 kV indoor
	60				
Footnotes *)	61				
	62				
	63				
	64				
	65				
	66				
	67				
	68				
	69	re. line 32: Construction of a high-head stage, Zimsee (Zirknitz), with separate penstock parallel to existing penstock of K2 is planned		water abstraction for pumped storage in Oschenik stage (K4)	re. line 47a: (1) rotary valve 1.3 m ϕ at downstream end of pressure shaft re. line 59: storage pump rating 1 x from K3: 670 m/4.3 m ³ /s / 28 MW 1 x from K5: 870 m/3.3 m ³ /s / 29 MW 1 x from K3: 670 m/5.5 m ³ /s / 31 MW

TABLE VIII. THE SEASONAL STORAGE SCHEMES OF KELAG
PART 1: CATCHMENTS, RESERVOIRS AND DIVERSIONS

K5 to K7: Part 1

POWER SCHEME (OWNER)		K5 to K7 FRAGMENT SCHEME (KELAG), MIDDLE AND LOWER REGION			
1		K5 Haselstein (Innerfragant) Spittal (Carinthia) 1968	K6 Ausserfragant Spittal (Carinthia) 1968 (1982)	K7 Wölla upper stage (Wölla) Spittal (Carinthia) 1982/1984	
2	Power stage (power station) District (province) Initial operation (extension)				
3					
4					
5	River basins				
6a	directly to res.				
6b	diversions				
6c	to stage				
6d	or				
6e	trans-basin diversions				
6f	and				
6g	upstream				
6h	power stations				
6i	total				
7	Reservoir: Name				
8	Max./mean/min. water level				
9	Active storage (stored energy)				
10	Dam: Name				
11a	Type				
11b	Height/crest length/crest level				
12	Volume				
13	Spillway: Type				
14	Capacity				
15					
16a	a) Name (catchment)				
17a	Stream intake: (number) Q_r - type				
18a	Waterway: type				
19a	Length/section				
16b	b) Name (catchment)				
17b	Stream intake: (number) Q_r - type				
18b	Waterway: type				
19b	Length/section				
16c	c) Name (catchment)				
17c	Stream intake: (number) Q_r - type				
18c	Waterway: type				
19c	Length/section				
16d	d) Name (catchment)				
17d	Stream intake: (number) Q_r - type				
18d	Waterway: type				
19d	Length/section				
16e	e) Name (catchment)				
17e	Stream intake: (number) Q_r - type				
18e	Waterway: type				
19e	Length/section				
20	(ZP) Name (trans-basin diversion)				
21	Feeder pumping Q_r/H or				
22	station: number of pumps x capacity				
23a	Footnotes *)				
23b	Abbreviations:				
23c	T Tyrolean weir				
23d	TA Tyrolean weir with automatic				
23e	sand trap flushing				

re. line 18c: concrete-encased, discharges into line 48,
? butterfly valves, 1,6 m ϕ , upstream

a) Drabnitzbach trans-basin diversion (6a)
(2) 1,5 m³/s, 2,5 m³/s - TA
buried pipeline, free-flow tunnel
2,0 km/0,6 and 1,2 m ϕ , 7,0 km/3,5 m ϕ
b) Lamnitzbach trans-basin diversion (6b)
(2) 1,0 m³/s and 1,5 m³/s - TA
buried pipeline, free-flow tunnel
1,9 km/0,5 - 0,9 m ϕ , 4,1 km/3,5 m ϕ
c) Wölla trans-basin diversion (6c)
(1) 2,5 m³/s - TA
buried pipeline
0,3 km/0,9 m ϕ

a) Oschenik- and Wöllnitzbach diversion (6a)
(2) 0,5 m³/s and 1,0 m³/s - TA
1 free-flow tunnel each, discharge into 37
0,08 km/6,7 m² 0,53 km/4,2 m²
b) Murtbach trans-basin diversion (6b)
(1) 4,1 m³/s - TA
concrete canal
0,25 km/5,1 m²
c) Wölla diversion with K7 (6a+g)
(1) 4,0 m³/s - TA bzw. 6,0 m³/s from K7
concrete canal, free-flow tunnel, pressure pipe *)
0,7 km/6,7 m²; 6,5 km/3,5 m ϕ ; 1,7 km/1,5 - 1,4 m ϕ
d) Gron- and Klonbach diversion (6g)
(2) 0,7 m³/s - TA
free-flow tunnel
0,2 km/3,5 m² discharges into 18c

a) Großfragant diversion (6a)
(1) 1,5 m³/s - TA
steel pipe, connected to 41
2,8 km/7,0 m ϕ
b) Kleinfragant trans-basin diversion (6b)
(1) 1,25 m³/s - TA
steel pipe
0,15 km/0,7 m ϕ

a) Name (catchment)
Stream intake: (number) Q_r - type
Waterway: type
Length/section
b) Name (catchment)
Stream intake: (number) Q_r - type
Waterway: type
Length/section
c) Name (catchment)
Stream intake: (number) Q_r - type
Waterway: type
Length/section
d) Name (catchment)
Stream intake: (number) Q_r - type
Waterway: type
Length/section
e) Name (catchment)
Stream intake: (number) Q_r - type
Waterway: type
Length/section

(For abbreviations, see line 23)

Wölla reservoir
1542/1539,5/1534,5 m a.s.l.
0,01 ha3 (+ 0,08 ha3 in tunnel)
artificial basin
tunnel debris fill
asphalt concrete membrane
0,105,10⁶ m³ material movement
concrete channel
10,0 m³/s for 0,82 m surcharge

Innerfragant reservoir
1201/1198/1193 m a.s.l.
0,175 ha3
artificial basin, 8,0 m deep
talus material dam downstream
asphalt concrete membrane
0,105,10⁶ m³ material movement
bellmouth spillway
26,0 m³/s

Haselstein reservoir
1470,5/1467/1458 m a.s.l.
0,04,10⁶ m³
artificial basin, 12,5 m deep
talus material dam downstream
asphalt concrete membrane
0,05,10⁶ m³ material movement
spillway
2,8 m³/s

Haselstein reservoir
1470,5/1467/1458 m a.s.l.
0,04,10⁶ m³
artificial basin, 12,5 m deep
talus material dam downstream
asphalt concrete membrane
0,05,10⁶ m³ material movement
spillway
2,8 m³/s

Wölla, tributaries (Wöll and Drau)
Drabnitzbach (Drau) 22,8 ka2
Lamnitzbach (Wöll) 10,3 ka2
Wölla 12,7 ka2

Fragantbach, tributaries (Wöll and Drau)
0 ka2
Oschenik (rest) + Wöllnitzbach (diversion) 9,8 ka2
Murtbach (rest) 4,3 ka2
from Murtbach stage (K3) 87,4 ka2
from Oschenik stage (K4) 1,7 ka2
from Haselstein stage (K5) 21,5 ka2
from Wöll upper stage (K7) 45,8 ka2
Wölla-, Gron- and Klonbach (diversion) 13,4 ka2
total 183,9 ka2

Fragantbach (Wöll)
0 ka2
Großfragant (diversion) 13,0 ka2
Kleinfragant 8,5 ka2
pumped storage
from Ausserfragant (K6)
total 21,5 ka2

Haselstein reservoir
1470,5/1467/1458 m a.s.l.
0,04,10⁶ m³
artificial basin, 12,5 m deep
talus material dam downstream
asphalt concrete membrane
0,05,10⁶ m³ material movement
spillway
2,8 m³/s

TABLE VIII, PART 2: HIGH-HEAD STAGES AND GENERATION

POWER SCHEME (OWNER)		K5 to K7 FRAGRANT SCHEME (KELAG), MIDDLE AND LOWER REGION		
T ... generating mode P ... pumping mode Note of operation Max./mean/min. gross head Max. discharge Q_T (Q_P)	30	K5 Haselstein (innerfragrant)	K6 Ausserfragrant	K7 Wölla upper stage
	31	pumped storage *) 276/766/756 m 1.74 m ³ /s (+1.72 m ³ /s)	generation only *) 488/485/480 m 23 m ³ /s	generation only 326/324/319 m 6.0 m ³ /s
POWER CONDUIT OF STAGE	35	Intake gates (number) cross section (length sections/int. ϕ) lining total length/max. pressure	0.5 km/5.8 and 7.3 m ² 5.0 km/6.0 m ² 0.1 km/2.6 m ϕ steel lining concrete canal	see Times 44 & 45
	36	Surge tank	5.1 km/6 bar 2-chamber, partly steel pipe, concrete-encased 2 penstocks	1 penstock
POWER CONDUIT OF STAGE	37	Penstock or shaft: type	(2) x (2) butterfly valves 1.80 m ϕ	(2) butterfly valves 1.5 m ϕ
	38a	Upper part	1.48 km/2 x 1.8 \div 1.5 m ϕ steel pipes with expansion pieces thrust blocks without concrete caps 1 pipe run with 6 branches, partly concrete-embedded 49/56 bar open canal concrete lining No. 11	2.06 km/1.5 \div 1.4 m ϕ steel pipe concrete-embedded concrete canal
POWER CONDUIT OF STAGE	38b	Gates	(1) butterfly valve buried	
	39	Lower part	332 m/1.50 m ϕ 630 m/1.10 m ϕ steel pipe partly concrete-embedded buried	
POWER CONDUIT OF STAGE	40	Manifold	directly to 37 of K6	
	41	Tailrace		
POWER CONDUIT OF STAGE	42	Discharge to	K2 stage, or innerfragrant reservoir	Wölla diversion 16c of K6
	43a	Type	above-ground, reinforced concrete 13 x 10 m	above-ground, reinforced concrete
POWER CONDUIT OF STAGE	43b	Dimensions (without control buildings)		
	44	Special features	(1) horizontal, 1007 rpm two-stage pump turbine 1 rotary valve 0.6 m ϕ 266 m/1.74 m ³ /s /4.0 MW 266 m/1.72 m ³ /s /5.0 MW 1 follower-type gate valve 0.9 m ϕ 1 asyn. motor generator 6 MVA 10.5 kV cable connection to innerfragrant power station (K3 and K4)	(1) vertical, 1000 rpm Francis turbine 326 m/6.0 m ³ /s /17 MW stop logs synchron. generator 20 MVA (1) 3-phase, block-type 20 MVA, 6.3/115 kV 115 kV indoor
POWER CONDUIT OF STAGE	45	(number) position, speed type and arrangement		
	46	upstream gates: type, int. ϕ		
POWER CONDUIT OF STAGE	47	P rating: H/Q/N		
	48	downstream gates: type, dim.		
POWER CONDUIT OF STAGE	49	generator: type, capacity		
	50	Transf.: (number) type, arrangement, capacity, voltage ratio		
POWER CONDUIT OF STAGE	51	Switchplant		
	52	Plant capacity of T and/or P: max./mean	T: 96 MW 236 GWh 49 $\frac{\text{h}}{\text{a}}$ / 2460 h (after commissioning of K7)	T: 17 MW 40.3 GWh 25 $\frac{\text{h}}{\text{a}}$ / 2370 h
POWER CONDUIT OF STAGE	53	Annual energy without short-t. pumping (with)		
	54	Winter share $\frac{\text{h}}{\text{a}}$ / full-load h.p.a.		
POWER CONDUIT OF STAGE	55	Annual P energy without short-t. pumping (with)		
	56	Footnotes *)		
POWER CONDUIT OF STAGE	57	water abstraction for pumping in Haselstein stage (K5)		
	58			
POWER CONDUIT OF STAGE	59			
	60			
POWER CONDUIT OF STAGE	61			
	62			
POWER CONDUIT OF STAGE	63			
	64			
POWER CONDUIT OF STAGE	65			
	66			
POWER CONDUIT OF STAGE	67			
	68			
POWER CONDUIT OF STAGE	69			
	70			

TABLE X. THE SEASONAL STORAGE SCHEMES OF ÖDK - MALTA SCHEME
PART 1: CATCHMENTS, RESERVOIRS AND DIVERSIONS

M: Part 1

POWER SCHEME (OWNER)		M MALTA SCHEME (ÖDK)			
1		M1 Malta upper stage (Galgembichl) Spittal an der Drau (Carinthia) 1978	M2 Malta main stage (Rottau) Spittal an der Drau (Carinthia) 1978	M3 Malta lower stage (Möllbrücke) Spittal an der Drau (Carinthia) 1978	
River basins directly to res. diversions to stage or Utilised Catchments: trans-basin diversions and upstream power stations	5	Malta, Kölnbreinbach	Malta (remaining catchment) Gödkar Gödkar south tributaries Gödkar north tributaries Malta south tributaries Malta north tributaries (see l. 23) Lieser from upper stage M1	Malta and Lieser (Drau) Möhl 1081,3 km ²	
	6a				
	6b				
	6c				
	6d				
	6e				
	6f				
	6g				
	6	total	51,3 km ²	total	128,6 km ² from main stage 128,6 km ² total 1209,9 km ²
Reservoir: Name Max./mean/min. water level Active storage (stored energy)	7	Kölnbrein reservoir 1902/1854,2/1730 m a.s.l. 200 hm ³ (577 GWh)	A. Galgembichl reservoir 1704/1695,6/1680 m a.s.l. 4,4 hm ³ (11,2 GWh)	B. Gödkar reservoir 55/270 m/1707,4 m a.s.l. 1,8 hm ³ (4,6 GWh)	Rottau compensation reservoir 598/597,3/596,5 m a.s.l. 0,5 hm ³
	8				
	9				
	10	Kölnbrein dam arch	Galgembichl dam gravel fill dams with asphaltic concrete facing	Gödkar dam	Rottau weir & power station (see line 20) vertical lift gate weir with 2 bays 15 m wide each 25/46 m/600,5 m a.s.l. 26,000 m ³ concrete 2 radial gates with flaps, 15 x 13,7 m 930 m ³ /s with full gate opening
	11a				
	11b				
Height/crest length/crest level Volume Spillway: Type Capacity	12	200/626 m/1002,7 (1904 *) m a.s.l. 1,35-10 ⁶ m ³ concrete side spillway, 30 m long 138 m ³ /s for 1,9 m surcharge	50/115 m/1706,9 m a.s.l. 6700 m ³ concrete 0,165-10 ⁶ m ³ fill side dam, 40 m overflow bellmouth spillway, 9,5 m ø 196 m ³ /s for 1,7 m surcharge 96 m ³ /s for 1,3 m surcharge	55/270 m/1707,4 m a.s.l. 0,531-10 ⁶ m ³ fill bellmouth spillway, 9,5 m ø 96 m ³ /s for 1,3 m surcharge	
	13				
	14				
	15				
	16a	none	a) Gödkar south diversion to 7 B (3) 1,0 - 1,5 m ³ /s - TA free-flow tunnel 4,1 km/8,0 m ²		none
	17a		b) Gödkar north diversion to 7 B (1) 0,75 m ³ /s - TA steel pipe 1,1 km/0,5 m ø		
Diversions to stages and trans-basin diversions (for abbreviations, see line 23)	17b		c) Malta south trans-basin diversion to 7 A (5) 0,5 - 6,0 m ³ /s - TA free-flow tunnel 6,6 km/9,0 m ²		
	17c		d) Malta north trans-basin diversion to 7 A (5) 0,6 - 1,5 m ³ /s - TA (see line 23) free-flow tunnel 10,2 km/9,0 m ²		
	17d		e) Lieser trans-basin diversion to 16d (1) 5,0 m ³ /s - TA free-flow tunnel 3,7 km/9,0 m ²		
	17e				
	18a				
	19a				
(ZP) Feeder pumping Q _h /h station: number of pumps x capacity	20	none	none	none	Rottau weir power station 5 m ³ /s / 14 m 1 x 0,6 MW
	21				
	22				
	23a	re. line 12: top of parapet	re. lines 6e and 17d: minimum release of 140 l/s required at certain times for Melnikbach stream intake (catchment = 6,1 km ²)		
	23b				
	23c				
	23d				
	23e				
Footnotes #7 Abbreviations: T Tyrolean weir TA sand trap flushing					

TABLE X, PART 2: HIGH-HEAD STAGES AND GENERATION

M: Part 2

POWER SCHEME (OWNER)		M MALTA SCHEME (ÜDK)		M3 Malta lower stage (Mellbrücke)	
T ... generating mode P ... pumping mode Mode of operation Max./min. gross head Max. discharge Q_p (l/s)	30	M1 Malta upper stage (Gallenbichl)	M2 Malta main stage (Rottau)		
	31	pumped storage 222/158.6/46 m 44 to 70 (32 to 76) m ³ /s	pumped storage 1102.5/1093.4/1078.5 m 80 (23.2) m ³ /s	generation only 45/44.3/43.5 m 110 m ³ /s	
Intake (number) cross section length sections/int. ϕ lining total length/max. pressure	35	butterfly valves (2) 3.80 m ϕ 0.3 km/4.70 m ϕ concrete	A. Gallenbichl reservoir butterfly valve (1) 4.00 m ϕ 0.4 km/4.0 m ϕ concrete with steel-lining	B. Gößlar reservoir butterfly valves * (2) 4.00 m ϕ 8.8 km/4.9 m ϕ , 0.8 km/4.7 m ϕ , 0.1 km/4.4 m ϕ concrete & bore segment steel-lining hole grouting steel-lining	
	36	2.0 km/4.70 m ϕ	2.6 km/4.24 bar	bulkhead (emergency weir) gates 15 x 13 m 2.5 km headrace 79 m ² asphaltic concrete	
Penstock on shaft: type Length sections/int. ϕ construction	37	see line 37 to 40	none	none	
	38a	2.6 km/4.24 bar	2-chamber with reverse-flow control throttle (1) pressure shaft (2) penstocks	1.61 km/6.6 m ϕ concrete	
Upper part type, position (number) cross section length sections/int. ϕ construction	41	concrete-embedded in gallery, 2 branches 25/32 bar	at end of manifold butterfly valves downstream of manifold (1) x (1) 2.60 m ϕ 1.8 km/2 x (2.6 - 2.5) m ϕ steel pipe with expansion pieces thrust blocks without concrete caps	5/6.5 bar open canal, 82 m long	
	42	pressure tunnel 0.15 km/5 m ϕ concrete, end section is steel-lined Gallenbichl reservoir (M2 A)	(2) hanging, above-ground, 3 branches each 110.3/127 bar T - (4) concrete canals, 40 m long P - (2) steel pipes, 50 m/2.8 m ϕ forebay of Rottau compensation reservoir	1 steel manifold, concrete-encased	
Lower part position max. pressure - stat./dyn.	43a	Discharge to		Draw	
	43b				
Tailrace Discharge to	44				
	45				
Type Dimensions (without control building) Special features	46				
	47a				
(number) position, speed type and arrangement upstream gates: type, int. ϕ T rating: H/Q/N P rating: H/Q/N downstream gates: type, dia. generator: type, capacity Trans.: (number) type, arrangement, capacity, voltage ratio	47b				
	48				
Switchplant	49				
	50a				
Plant capacity of T and/or P: max. Annual energy without short-t.pumping (with) Winter share % / full-load h.p.e.a. Annual P energy without short-t.pumping (with)	50b				
	51				
Footnotes *	52				
	53				
Type Dimensions (without control building) Special features	54a				
	54b				
(number) position, speed type and arrangement upstream gates: type, int. ϕ T rating: H/Q/N P rating: H/Q/N downstream gates: type, dia. generator: type, capacity Trans.: (number) type, arrangement, capacity, voltage ratio	55				
	56				
Switchplant	57				
	58				
Plant capacity of T and/or P: max. Annual energy without short-t.pumping (with) Winter share % / full-load h.p.e.a. Annual P energy without short-t.pumping (with)	59				
	60				
Footnotes *	61				
	62				
Type Dimensions (without control building) Special features	63				
	64				
(number) position, speed type and arrangement upstream gates: type, int. ϕ T rating: H/Q/N P rating: H/Q/N downstream gates: type, dia. generator: type, capacity Trans.: (number) type, arrangement, capacity, voltage ratio	65				
	66				
Switchplant	67				
	68				
Plant capacity of T and/or P: max. Annual energy without short-t.pumping (with) Winter share % / full-load h.p.e.a. Annual P energy without short-t.pumping (with)	69				
	70				
Footnotes *	71				
	72				
Type Dimensions (without control building) Special features	73				
	74				
(number) position, speed type and arrangement upstream gates: type, int. ϕ T rating: H/Q/N P rating: H/Q/N downstream gates: type, dia. generator: type, capacity Trans.: (number) type, arrangement, capacity, voltage ratio	75				
	76				
Switchplant	77				
	78				
Plant capacity of T and/or P: max. Annual energy without short-t.pumping (with) Winter share % / full-load h.p.e.a. Annual P energy without short-t.pumping (with)	79				
	80				
Footnotes *	81				
	82				
Type Dimensions (without control building) Special features	83				
	84				
(number) position, speed type and arrangement upstream gates: type, int. ϕ T rating: H/Q/N P rating: H/Q/N downstream gates: type, dia. generator: type, capacity Trans.: (number) type, arrangement, capacity, voltage ratio	85				
	86				
Switchplant	87				
	88				
Plant capacity of T and/or P: max. Annual energy without short-t.pumping (with) Winter share % / full-load h.p.e.a. Annual P energy without short-t.pumping (with)	89				
	90				
Footnotes *	91				
	92				
Type Dimensions (without control building) Special features	93				
	94				
(number) position, speed type and arrangement upstream gates: type, int. ϕ T rating: H/Q/N P rating: H/Q/N downstream gates: type, dia. generator: type, capacity Trans.: (number) type, arrangement, capacity, voltage ratio	95				
	96				
Switchplant	97				
	98				
Plant capacity of T and/or P: max. Annual energy without short-t.pumping (with) Winter share % / full-load h.p.e.a. Annual P energy without short-t.pumping (with)	99				
	100				
Footnotes *	101				
	102				
Type Dimensions (without control building) Special features	103				
	104				
(number) position, speed type and arrangement upstream gates: type, int. ϕ T rating: H/Q/N P rating: H/Q/N downstream gates: type, dia. generator: type, capacity Trans.: (number) type, arrangement, capacity, voltage ratio	105				
	106				
Switchplant	107				
	108				
Plant capacity of T and/or P: max. Annual energy without short-t.pumping (with) Winter share % / full-load h.p.e.a. Annual P energy without short-t.pumping (with)	109				
	110				
Footnotes *	111				
	112				
Type Dimensions (without control building) Special features	113				
	114				
(number) position, speed type and arrangement upstream gates: type, int. ϕ T rating: H/Q/N P rating: H/Q/N downstream gates: type, dia. generator: type, capacity Trans.: (number) type, arrangement, capacity, voltage ratio	115				
	116				
Switchplant	117				
	118				
Plant capacity of T and/or P: max. Annual energy without short-t.pumping (with) Winter share % / full-load h.p.e.a. Annual P energy without short-t.pumping (with)	119				
	120				
Footnotes *	121				
	122				
Type Dimensions (without control building) Special features	123				
	124				
(number) position, speed type and arrangement upstream gates: type, int. ϕ T rating: H/Q/N P rating: H/Q/N downstream gates: type, dia. generator: type, capacity Trans.: (number) type, arrangement, capacity, voltage ratio	125				
	126				
Switchplant	127				
	128				
Plant capacity of T and/or P: max. Annual energy without short-t.pumping (with) Winter share % / full-load h.p.e.a. Annual P energy without short-t.pumping (with)	129				
	130				
Footnotes *	131				
	132				
Type Dimensions (without control building) Special features	133				
	134				
(number) position, speed type and arrangement upstream gates: type, int. ϕ T rating: H/Q/N P rating: H/Q/N downstream gates: type, dia. generator: type, capacity Trans.: (number) type, arrangement, capacity, voltage ratio	135				
	136				
Switchplant	137				
	138				
Plant capacity of T and/or P: max. Annual energy without short-t.pumping (with) Winter share % / full-load h.p.e.a. Annual P energy without short-t.pumping (with)	139				
	140				
Footnotes *	141				
	142				
Type Dimensions (without control building) Special features	143				
	144				
(number) position, speed type and arrangement upstream gates: type, int. ϕ T rating: H/Q/N P rating: H/Q/N downstream gates: type, dia. generator: type, capacity Trans.: (number) type, arrangement, capacity, voltage ratio	145				
	146				
Switchplant	147				
	148				
Plant capacity of T and/or P: max. Annual energy without short-t.pumping (with) Winter share % / full-load h.p.e.a. Annual P energy without short-t.pumping (with)	149				
	150				
Footnotes *	151				
	152				
Type Dimensions (without control building) Special features	153				
	154				
(number) position, speed type and arrangement upstream gates: type, int. ϕ T rating: H/Q/N P rating: H/Q/N downstream gates: type, dia. generator: type, capacity Trans.: (number) type, arrangement, capacity, voltage ratio	155				
	156				
Switchplant	157				
	158				
Plant capacity of T and/or P: max. Annual energy without short-t.pumping (with) Winter share % / full-load h.p.e.a. Annual P energy without short-t.pumping (with)	159				
	160				
Footnotes *	161				
	162				
Type Dimensions (without control building) Special features	163				
	164				
(number) position, speed type and arrangement upstream gates: type, int. ϕ T rating: H/Q/N P rating: H/Q/N downstream gates: type, dia. generator: type, capacity Trans.: (number) type, arrangement, capacity, voltage ratio	165				
	166				
Switchplant	167				
	168				
Plant capacity of T and/or P: max. Annual energy without short-t.pumping (with) Winter share % / full-load h.p.e.a. Annual P energy without short-t.pumping (with)	169				
	170				
Footnotes *	171				
	172				
Type Dimensions (without control building) Special features	173				
	174				
(number) position, speed type and arrangement upstream gates: type, int. ϕ T rating: H/Q/N P rating: H/Q/N downstream gates: type, dia. generator: type, capacity Trans.: (number) type, arrangement, capacity, voltage ratio	175				
	176				
Switchplant	177				
	178				
Plant capacity of T and/or P: max. Annual energy without short-t.pumping (with) Winter share % / full-load h.p.e.a. Annual P energy without short-t.pumping (with)	179				
	180				
Footnotes *	181				
	182				
Type Dimensions (without control building) Special features	183				
	184				
(number) position, speed type and arrangement upstream gates: type, int. ϕ T rating: H/Q/N P rating: H/Q/N downstream gates: type, dia. generator: type, capacity Trans.: (number) type, arrangement, capacity, voltage ratio	185				
	186				
Switchplant	187				
	188				
Plant capacity of T and/or P: max. Annual energy without short-t.pumping (with) Winter share % / full-load h.p.e.a. Annual P energy without short-t.pumping (with)	189				
	190				
Footnotes *	191				
	192				
Type Dimensions (without control building) Special features	193				
	194				
(number) position, speed type and arrangement upstream gates: type, int. ϕ T rating: H/Q/N P rating: H/Q/N downstream gates: type, dia. generator: type, capacity Trans.: (number) type, arrangement, capacity, voltage ratio	195				

Run-of-River Plant in Austria

By R. Fenz*

The purpose of this report is to present a description of run-of-river plants existing at the turn of the year 1984–85, and to demonstrate the importance of this type of power station for Austria's electricity supply. While, for the sake of clearness, the scope of plant discussed here will be limited in terms of power station capacity (i.e. stations with a maximum capacity less than 10 MW will be precluded from consideration), the series of power stations on Austria's main rivers will be described in greater detail to make due allowance for their importance in the overall generating system. In this respect, this report is largely based on an inventory of run-of-river plants, made up under the title of "Flußstauwerke in Österreich" (R. Fenz, Österr. Wasserwirtschaft, Jahrgang 29, Heft 9/10) in 1977, and should be regarded as an updated version of this inventory.

The importance of hydro power for electricity generation is very much a function of the geographical, hydrological and topographical conditions of a country and, hence, varies considerably. The hydraulic share of total electricity production is for instance 12 per cent in the U.S.A., 68 per cent in Canada, 19 per cent (mean value) in Europe. In Austria the contribution of hydro towards total electricity production, about 50 per cent in 1918, increased to more than 80 per cent in the years 1932 to 1938 and then decreased to less than 60 per cent by the years 1971 and 1972. At present, the percentage of hydro varies between 68 per cent and 72 per cent. Even in dry years, hydro accounts for almost two-thirds of total generation. In Europe, larger hydro shares are found only in Norway (99.7%) and Iceland, whereas Austria and Switzerland can be regarded as almost equally entitled to the attribute of "hydro power country". Although these two countries, both situated in the Alps, are similar in many respects, there are some important differences. Austria's developable hydro potential is 53700 GWh and, thus, some 50 per cent larger than that of Switzerland. The resulting hydro resources per inhabitant are 25 per cent larger. Still, related to the area of national territory, Austria's "hydro density" is 25 per cent lower than that of Switzerland (Table 1). This implies that the area percentage required for the higher per capita share of hydro energy in Austria is in fact lower than that of Switzerland. Further comparison with neighbouring Switzerland, the classical and traditional Alpine hydro power country, reveals that Austria owes her high hydro potential mainly to her run-of-river plant — existing and planned — as this accounts for some two-thirds of the total potential, whereas in Switzerland high-level storage plant predominates. The developed share of the developable potential is at present 93 per cent in Switzerland and approximately 60 per cent in Austria.

In 1983, total electricity generation was about 42.6 TWh (i.e. 42000 GWh), of which 30.6 TWh (or 71.8 per cent) came from hydro stations and 12.0 TWh (28.2 per cent)

Table 1. Comparison of Alpine hydro power countries Switzerland–Austria

	I Inhab- itants (10 ⁶)	A Area 10 ³ km ²	I/A	P Hydro- potential GWh/a	Spec. potential P/I kWh/a/I	P/A GWh/ a/km ²
Switzerland (CH)	6.1	41	149	35 100	5 760	0.86
Austria (A)	7.5	84	90	53 700	7 160	0.64
Comparison (A/CH)	+ 23%	+ 105%	– 40%	+ 53%	+ 25%	– 25%

from thermal stations. The above 30.6 TWh of hydro generation falls into 21.3 TWh from run-of-river stations and 9.3 TWh from storage schemes. The 21.3 TWh of run-of-river energy thus accounted for 50 per cent of the total generation (hydro and thermal) of 42.6 TWh. For the sake of completeness, 4.4 TWh of imported electricity must be added, which brings the total energy to 47 TWh, of which 7.9 TWh was exported and 39.1 TWh was used for domestic consumption.

Out of the total of 21.3 TWh of run-of-river energy, 19.7 TWh, or 92.5 per cent, was generated by the seven series of power stations on the rivers Danube, Drau, Enns, Inn, Mur, Salzach and Traun, and 1.6 TWh, or 7.5 per cent, by other run-of-river stations.

Austria's dense population, especially in the wide river valleys, and the topographical and civilisational conditions in this country allow practically no major impoundment, because the resulting flooding of river banks would involve considerable relocations and loss in cultivated land and cultural assets. The commonest type of run-of-river power station works under a limited head of between 8 and 16 m and, in reaches of very favourable topography, under heads of up to 20 or 25 m. A few power stations are of the diversion type with long tunnels, representing in fact a transitional type between run-of-river station and alpine high-head station. Apart from their primary activity of energy generation, many run-of-river projects in Austria carry out a number of subsidiary activities. This is particularly true of the development of the Danube as a high-capacity waterway. But other run-of-river projects, too, may be called multi-purpose, especially with respect to flood protection for the banks, prevention of natural river bed degradation, and measures for handling sewage problems so as to contribute towards water pollution control and, as a consequence, to the creation of recreational resources.

It has already been mentioned that the greater part of run-of-river power comes from series of power stations. Although in many cases isolated projects were initially planned, it was soon realised that continuous series of power projects were desirable for reasons of power economy and river morphology. The individual river ba-

* Dipl.-Ing. Dr. techn. Baurat h. c., retired Executive Director of Österreichische Donaukraftwerke Aktiengesellschaft (DoKW), President of the Austrian Association on Water Resources Management (Österreichischer Wasserwirtschaftsverband).

sins with their series of power projects will be described in the following. Except for a few cases, which will be mentioned, practically all the run-of-river schemes are situated in the river and some provide storage. In very few cases, power stations were constructed on diversions in the form of tunnels or channels.

Table 2. Austria's series of run-of-river stations, 1985 (power stations of more than 10 MW capacity)

River	AAE Energy GWh/a	MC Max. capacity MW	Number of p. st. incl. boundary st.
Danube	11 696	1924	8 + ½
Drau	2 474	504	8
Enns	2 373	518	14
Inn	1 959	333	2 + 5 × ½ + ¼
Mur	803	147	10
Salzach	660	156	3
Traun	526	103	4
	(655)	(121)	(6)*
	20 491	3 685	49 + 7 = 56

* see 7. Traun

Table 2 is a list of the seven river basins mentioned above, arranged in order of average annual energy in terms of gigawatt-hours p. a. (AAE). Also shown in the table is maximum capacity (MC) in terms of megawatts. Both values refer to the year 1985 (in respect of commissioning). For the rivers Inn and Danube, only Austria's share of the output produced by boundary stations has been allowed for. The following description of individual river basins will be in the same order as shown in the table.

1. Danube (see Table: Danube)

The Danube, Europe's largest river, crossing eight countries along its path from West to East, has not only been a factor of great historical and cultural consequence, but has for many centuries been a boundary and oftener still a link for Europe. Above all, however, the Danube has always been a traffic route and will in a few years constitute an essential part of the Rhine-Main-Danube trans-European waterway. Along its course through Austria, the Danube is characterised both by a considerable gradient and by an abundance of water, resulting from the substantial flows contributed by the river Inn at Passau. Whereas the reach immediately upstream, in Germany, has a gradient of only 0.2‰, and the almost 1900 km-long reach east of Austria down to the Black Sea drops at about 0.06‰, except for the gorge developed by the Djerdap power station (Iron Gate), the Austrian reach, more than 350 km in length, has a gradient of 0.4‰. This involves not only a high energy potential for this country, but also a small channel depth due to the high flow velocities, especially during low flows. A multi-purpose plant on the Danube thus provides the required improvement of navigation as well as valuable and clean domestic energy production.

The great diversity of contributing catchments (Central Alps, foothills) ensures a most favourable distribution of

river flow, so that the ratio of winter production to summer production by the Austrian power stations on the Danube is about 43 per cent to 57 per cent. In wet years (for instance in 1981), this may even be 49 per cent to 51 per cent. All the power stations on the Austrian Danube are multi-purpose installations which, although planned, designed and constructed by an electricity-supply company, constitute an essential factor in the improvement of the waterway. This implies that allowance is made for navigation requirements by providing locking facilities, and that on the other hand the government authorities responsible for the waterway pay a share of the total cost (20 to 25 per cent).

Development of the Austrian Danube was commenced when the demand was consistent with the large energy potential available, which actually was not the case until the period after the Second World War. Only some preliminary studies and isolated projects had been prepared before that time. This led to the most welcome result that, prior to the construction of the first power project at Jochenstein, a master plan covering the whole Austrian reach of the Danube was available. Although this was subsequently modified in some respects to allow for the progress of technology — in particular, the number of planned power stations was reduced from fifteen to twelve by combining projects for reasons of economy — the Danube Master Plan continues to be used as a general guide. Its stage-wise implementation has been in progress ever since 1953, i. e. for 30 years, and has been characterised by an almost perfect continuity with respect to both time and especially staff. Concentration of planning and design, construction supervision, operation and administration in a single company and the continuity that has partly been accomplished in the execution of construction items and supplies have allowed extraordinary cost savings and reduction in construction time.

Among the power projects shown on the Master Plan (Fig. 1), the first (viewed in the direction of flow of the Danube) is Jochenstein, jointly owned by Austria and the Federal Republic of Germany, its output being shared between the two countries. The remaining eleven power projects are owned, or planned to be constructed, by Österreichische Donaukraftwerke AG (DoKW) in Vienna.

The power stations (including half of Jochenstein) shown on the Master Plan, which covers a river length of 350 km and a head of approximately 150 m, are capable of a total power of 2574 MW and a total energy of 15 478 GWh p. a. As can be seen from the graph on Fig. 1, the power stations at Jochenstein, Aschach, Ottensheim-Wilhering, Abwinden-Asten, Wallsee-Mitterkirchen, Ybbs-Persenbeug and Melk as well as at Altenwörth and Greifenstein are completed, whereas construction of Hainburg is planned to be started in 1985. The energy at present supplied by the Danube in Austria is 11 696 GWh p. a. (1924 MW) and meets as much as about 29 per cent of an estimated domestic consumption of about 41 000 GWh in 1985.

Whereas Jochenstein, Aschach and Ybbs-Persenbeug are situated at narrow valley sections which the Danube has cut through the granitic gneisses of the Bohemian Massif, all the other stations, that is, from Ottensheim down to Greifenstein and Hainburg, are situated in flat lowlands, where it was possible and expedient in each




Fig. 1. Masterplan for Danube-powerstation, 1984 (by Österreichische Donaukraftwerke AG)

* MIT 1/2 ANTEIL VON JOCHENSTEIN

case to locate the main structure lateral to the natural river channel. The advantage of such an arrangement is that the whole project, consisting of powerhouse, spillway and lock, is constructed speedily in a single pit, safe from floods and interference from navigation, obviating the need for provisions to handle floods during construction. In the case of the former group of power projects, the narrowness of the sites allowed only stage-wise construction in several successive construction pits. The resulting increase in flood water depth during construction was tolerable there.

Construction sites in the lowlands, with the main structure located besides the natural river channel, compared very favourably in terms of construction time and cost with the sites at the narrow valley sections. Another essential difference concerns the effect of floods in the backwater areas. Whereas between the high banks the entire flows remain within the river channel even during floods, large-scale flooding is an essential characteristic of the riverine lowlands. In order to maintain this for ecological reasons, and for its flood retarding effect on downstream reaches as well as for economic reasons, overflow sections were provided at all the lowland stations except for Melk. For this purpose, some of the flanking embankments were constructed lower and designed so as to allow floods in excess of a given magnitude to flow out into the areas that used to be attained by the floods prior to development of the river. This prevents aggravation of the flood situation in downstream reaches. During an extreme flood wave, as much as 20 per cent of the total flow may pass over the overflow sections, and as this drains off in the areas outside the dykes to return to the main river downstream of the power station, spillway design can be limited to 80 per cent of the maximum flood.

A fundamental difference between high-bank and low-land power stations on the Danube lies in the geological conditions. Whereas Jochenstein, Aschach and Ybbs-Persenbeug are founded on granitic gneiss, the lowland stations had to be built mainly on sediments, mostly "schlier", a local variety of shale, covered by alluvial material about 10 to 14 m in thickness. Special foundation measures were required in places to prevent slope caving and to transfer horizontal forces safely into the schlier. At Melk, the structure was founded on densely packed sands, requiring a continuous cutoff, whereas Greifenstein had to be built on flysch of varying mechanical properties.

In the following paragraphs, some special design characteristics of the main features (lock, spillway, powerhouse and dykes) will be discussed in greater detail.

1.1 Locks


The dimensions of the locks to be provided to allow shipping on the river have been laid down by the International Danube Convention. This provides that twin locks 24 m in width and 230 m in effective length be built within the Austrian reach of the Danube.

In order to allow major trains of barges as are planned in the Eastern countries to go up to Vienna (and to the Korneuburg shipyard), one of the two lock chambers will be 34 m wide and 275 m in effective length at Hainburg and probably also at Vienna.

In spite of the different heads (between 9 and 16 m), depending on the respective river topography, and the resulting differences in lock filling flow, it is considered desirable that all the locks be designed for a uniform filling time of approximately 15 minutes so as to accomplish a uniform capacity of about 40 million t of annual naviga-

tion for each scheme on the river. It is only at Jochenstein and Ybbs that locks are filled from the upper approaches and emptied to the lower approaches, through the lock gates. Since the construction of Aschach in 1962, locks have been filled from the impounded headwater and emptied to the tailwater, but outside the approaches, so as to afford greatly improved navigation conditions. The locks including training and quay walls along the approaches cover a length of more than 1000 m in the direction of flow and account for 50 or 60

per cent of the total concrete volume needed for a power project. Lock chamber walls (Fig. 2) are comparable to concrete dams as to their statical function, with vertical side walls being a requirement and with the two faces of the middle wall alternatively acting as "upstream" and "downstream" faces in terms of statics. Crest height (in general, 2 m above water level) from lowest foundation is 30 m and 30.5 m, respectively, at Aschach and Altenwörth. Wall thicknesses vary between 10.5 m and 15 m. As the gravel present in the riverbed is



Stauziel: storage-level
Füll- und Entleerungskanäle:
filling and emptying system

Fig. 2. Danube: Locks

an excellent concrete aggregate, attempts to replace the gravity type by a different design have given no economical results. Rationalisation efforts have been aimed at using a cement-saving concrete by careful mix design and by allowing for the moisture contents of all the aggregate components to minimise the water-cement factor.

Lock walls founded on rock are statically independent of the chamber floors and are designed to resist unilateral water or earth pressure and ice pressure (maximum pressure, 5 t/m). For structures founded on the schlier (lowlands), the whole lock cross section (three walls, two floors) is regarded as an articulated chain, so as to include the chamber floors as supporting elements and above all to ensure safety against sliding with the chamber empty or partly empty. For this purpose, joints are grouted after the end of the setting process, as is practised in high concrete dams.

Similarly, the extremely high pressures from the mitre gates are absorbed not only by the abutment blocks but also by the adjoining lock wall elements, which are bonded by joint grouting to form a statical unit. In addition, components subjected to major horizontal loadings (such as water pressure), as for instance the upper gate blocks, are tightly keyed in the schlier foundation by means of a kind of concrete studs so as to be safe from shear, as in situ shear tests had shown the schlier to have only a limited capability of withstanding horizontal forces along the foundation contact.

Another important statical factor is the location of the main structural axis relative to the lock, which passes across the upper gate at Jochenstein and Ybbs and across the lower gate at all the other power stations on the Danube.

The walls of lock located in the tailwater (Jochenstein or Ybbs) will be pushed outwards during chamber filling, whereas the walls of a lock situated in the headwater will be pushed inwards when the chamber is empty. Concrete is better suited to meet the requirements of the latter design, which also allows the chamber floor to be included as a supporting element, which is especially desirable where the foundation is prone to sliding.

The overall concept of the power schemes on the Danube provides for the locks to be used besides the spillways for the passage of catastrophic floods, as navigation is stopped anyway in the case of large flows for reasons of flow velocity, clearance under bridges etc. The additional cost incurred for the lock, especially for the steel hydraulics gates, is only a small proportion of what additional spillway bays would cost.

1.2 Spillways

The spillway is intended to handle flows in excess of the maximum turbine flow. Overflow over the lowered gates occurs rarely and than will at first be of a small magnitude. It is only in extreme cases that the spillway bays are used more or less for the discharge of floods. Up to 1974, all the spillways on the Danube (Fig. 3) were




Fig. 3. Danube: Weirs

equipped with mechanically driven hook-type double leaf gates. Oil hydraulic driven tainter gates with flaps on top have been used since the construction of Altenwörth. All the spillways have a uniform bay width of 24 m, i. e. the same as the lock chambers. An exception is Ybbs with a bay width of 30 m. The uniform width of 24 m allows the application of stop logs both in locks and spillways and exchange among the power stations. Maximum hydraulic loading is highest at Aschach, equal to $11\,000/7 \times 24 = 66 \text{ m}^3/\text{s}/\text{m}$, or $11\,000/6 \times 24 = 77 \text{ m}^3/\text{s}/\text{m}$, depending on whether the maximum design flood is assumed to be handled by (n) or (n-1) spillway bays. Piers, especially those founded on bedrock, are designed as single structures. Measures are taken in the spillway floors to ensure uplift relief in the case of unwatering for maintenance and repair. At the lowland stations founded on the schlier, spillway bays and piers are either combined to form frames or designed as drop-in girders. A massive concrete key under the weir sill of each station accommodates an inspection gallery which also serves for potential subsequent grouting, as an instrument gallery and for relief and observation of pore pressures, especially at the foundation contact. At Altenwörth, the key connects to a concrete trench cutoff 10 m deep to prevent seepage. Similar provisions had to be made at Melk. In the longitudinal direction, piers are shaped as stepped blocks with subsequently grouted joints. At the piers equipped with tainter gates, pivot bearing forces are transmitted to the upstream through prestressing elements.

Cut granite stone facings were first applied over the whole spillway bays (stilling basins) and piers, but were then reduced from project to project. At present, hard-aggregate or high-quality concrete facing is used almost exclusively. End sills are steel-lined. Due to the fairly continuous development of the Danube and main tributaries (Inn and Enns) by series of power stations, bed load transport through the spillways is expected to occur only under extreme conditions.

Apart from Jochenstein, whose spillway is curved in plan and not equipped with a crane runway, all the dams on the Danube are provided with a 120 to 220 t capacity gantry crane running across powerhouse, spillway and locks. This serves for erection and for lowering stop logs upstream of the spillway. Crane girders, first of the steel box type, have been of reinforced concrete since Wallsee. The same is true of the intra-plant roadway bridges taken across the pier tops.

The piers, up to 41 m high above lowest foundation and only 6.0 to 7.5 m wide, are outstanding features requiring solid keying in the bedrock, or by studs in the "schlier" to resist the substantial water load. In addition, they have to withstand high linear loads where hook-type double leaf gates are present, and concentrated loads in the case of tainter gates, with prestressing anchorage fixtures being used in the latter case.

1.3 Powerhouse

Power station design on the Danube has undergone changes in two respects, although the nine projects have been constructed in relatively rapid succession, between 1952 and 1984. One essential change relates to the selection of the type and number of turbines; these are in chronological order: five at Jochenstein, six at

Ybbs, four at Aschach, six at Wallsee, all vertical-shaft Kaplan turbines; since 1970 (commencement of work at Ottensheim), nine horizontal-shaft Kaplan turbines (bulb turbines) each. It should be pointed out right away that, despite this variety and the very different heads involved, it has been possible to maintain a largely uniform inlet and outlet width so as to ensure universal use of stop logs. The single-part inlets and outlets of the stations equipped with horizontal-shaft turbines are of a width corresponding to half the width of the inlets and outlets (divided into two) of the stations equipped with vertical-shaft Kaplan turbines, as for instance Ybbs, Aschach, Wallsee.

Partly due to the choice of turbines as described above — governed by economic aspects, especially in the structural sector — and partly as a result of the basic projekt idea, a second development took place in the form of a substantial reduction in powerhouse height (Fig. 4) above the impounded water level. Whereas this is as much as 22.40 m at Jochenstein, the only plant with a crane provided in the powerhouse hall, powerhouse height is only 10.50 m at Aschach, 9.30 m at Ybbs and as little as 5.00 m at Wallsee, which does not even exceed the height of powerhouses equipped with horizontal-shaft turbines. It should be pointed out in this context that the level of the powerhouse roof, which serves as a runway for the universal gantry crane described in connexion with the spillway, is dependent to a high degree on the position of the main axis of the power station relative to the lock. Where the main structural axis crosses the lock at the upper gate, as at Jochenstein and Ybbs, the required clear height of 8.00 m above the impounded water level will have an important bearing on the choice of the roof level. At all the other stations, the lock is crossed at the lower gates, where the water level is lower. This also avoids the unfavourable visual effect of a lock wall towering over the tail-water level in its full height. The statical aspect of the lock structure in this respect has been discussed above. Naturally, powerhouse statics is largely a function of the foundation conditions. As a feature common to all the power stations, there is a structural unit, separated from the adjoining blocks by joints, for each power unit; in this context, reduction of block width from a maximum of 32 m (Aschach) to a value between 17 m and 18 m for the bulb turbines has not only been a great advantage in terms of statics, but has helped to overcome construction problems and avoid cracking. In some cases, the joint separating the power unit blocks is deliberately connected to the adjacent water pressure.

Viewed in the direction of flow, powerhouses equipped with verticalshaft units show a structural division into inlet, middle block and outlet, mainly to answer the geometrical requirements of spiral casing and draft tube bend. Mutual statical support between the three powerhouse elements is ensured. In the powerhouses equipped with bulb turbines, the inlet structure, much shorter in this case, directly passes into the middle part, which houses the power units.

This is an essential advantage of this arrangement. Only the outlet structure is constructed as a separate element but then made to form a statical unit with the whole powerhouse cross section by means of joint grouting. It should finally be mentioned that it has lately been made a rule to place gravel fill on the draft tube for




Fig. 4. Danube: Powerstations


ballast. At the power stations founded on the schlier, deep excavations (Wallsee) first presented some difficulties from slides; this gave rise to the development of keying structures in the form of concrete-filled wells acting as "studs" projecting downwards from the base of the structure. In addition, large-area excavation, especially in the powerhouse area, called for special precautions to protect the schlier, which tends to heave when exposed and later settles again when covered.

By way of summary, one may say that structural design has gradually been simplified, especially in respect of erection bay and auxiliary room requirements and, around the time of constructing the Ottensheim project (1970), developed into what may be called the "Danube construction method". Its outstanding feature is the gantry crane installation that extends over the whole plant, servicing the powerhouse, the spillway and the lower gates of the locks. Another characteristic is the systematic transition to bulb turbines. This allows the construction of low buildings, which are felt to blend well with the surrounding riverine lowlands.

1.4 Dykes

It would be very much beyond the scope of this report to mention even the most important problems, their solution and the structural measures taken in the backwater areas above the power stations on the Danube. Therefore, discussion will be limited to the embankments in the backwater areas on the Danube. Whereas very few dykes were provided at the high-bank power sites, Jochenstein, Aschach and Ybbs, they constituted a very important structural and cost item at the power stations in the lowlands.

Having to retain the impounded water so as to protect low-level country behind (riverine lowlands or cultivated land), dykes have to answer high stability standards and must ensure watertightness both within the structure and more or less also in the foundation. In addition, waterside facings of new dykes must meet the requirements of a navigable river as well as the requirements resulting from ice formation, water level variations and ecological and biological needs. A special case are the overflow sections mentioned earlier in this report.



Schmalwand:
thin diaphragm

Raumschlitz:
piling channel

Spundwand:
sheet pile

Leichtspundwand:
light-weight sheet

Bitumenleiste:
bitumen strip

Steinwurf:
riprap

Einmischdichtung:
mix of gravel and sand

Ausand
riverside sand

Überströmstrecke:
„overflow“-embankment

Fig. 5. Cross-sections of dykes

The development of dyke cross sections (Fig. 5) reflects technological and economic progress made in recent construction methods. A decisive feature is obviously dam height above ground level. Fill volumes at lowland power stations vary between 5.0 and 12.0 million m³ and may well compete with large dam projects in terms of volume of earth moved.

At the first lowland power station, Wallsee, imperviousness was achieved by two light-weight sheet walls (35 to 40 kg/m²). The lower one was vibrated into position from ground level down to the impervious schlier. Then a strip of bitumen was placed at the head of the sheet wall and the dam fill deposited on top. The second sheet wall was then carefully sunk by vibration through the dam fill and into the bitumen strip. In some very low dykes, impervious cores consist of a special mix of sandy gravel and riverside sand. Bank protection is by riprap everywhere on the Danube.

In the construction years 1970 to 1973, more economical methods were developed for the Ottensheim project. These included the use of thin diaphragm cutoffs, which will be described in connection with the development of the river Drau. In addition, bituminous concrete was used for the first time on the Danube for sealing a water-side slope. This was however limited to a bank length of 5.6 km, where site conditions allowed a gently sloping fill of natural gravel to be placed in front, which saved riprap and accomplished a flat bank of great biological value. For the rest, the development of impervious core material (gravel/sand mix) from natural sources, its processing and continuous test measurement during construction were systematically pushed ahead.

At Altenwörth, involving the largest amount of dyke fill, the above-mentioned 12 million m³, thin diaphragms were the only foundation cutoffs used. For low embankment heights, the diaphragm was connected to an impervious core. Where major fill heights were concerned, reaching a maximum of 12 m above ground level at Altenwörth, the thin diaphragm was arranged at the water-side toe and connected to a bituminous slope facing carried to a level above the top water level. This facing, serving as a sealing and bank protection element, was applied in a single 8 cm layer and, in the area of potential berthing impacts, in two 8 cm layers. Upwards from a berm provided on the bitumen facing below top water level, the facing was covered with riprap as a protection against wave action from navigation and potential damage from ice, as well as to allow man and animals to climb up and down, and above all to answer the requirements of stream biology in the important uppermost, light-filled, water layer; the latter is an important factor enhancing the self-purifying capacity of the dammed-up river.

From the economic point of view, the above mentioned bituminous slope facing was not acceptable for fill heights less than 8 or 10 m. Another important economic criterion is the availability within easy haul distance of quarries for the large riprap stone requirements. At Altenwörth, almost 1.8 million t of stones were placed in the main structure and in the backwater area, within a period of about two years.

Foundation cutoffs are carried down to the impervious schlier (some 10 to 14 m below ground level) only where the impounded water level is at least 3 or 4 m above ground level, or near towns and villages. Otherwise a

short cutoff extending into the gravel foundation is sufficient to prevent seepage flow from reaching unacceptable magnitudes. An important element in dyke structures is the landside drainage channel (bottom some 1.0 m below mean water level, original condition), serving to maintain the inland water table at the original level or to control it as desired; special water release structures (inlets to convey stored water to riverside plains) are provided for this purpose.

A special design is required in the so-called overflow sections of the flanking embankments. Whereas all the other dykes at the power stations on the Danube are not overflown even during maximum floods and have unpaved landside slopes sown with grass seed, overflow sections allow part of flood water to flow out into the hinterland. For this reason, the heavy riprap protection is not limited to the waterside slope, but covers the crest, the landside slope and a widened channel along its toe, serving as a stilling basin. A lightweight sheet wall in the middle of the dyke, extending from the crest down to the gravel foundation or below the channel bottom prevents scouring within and below the riprap. Dyke cross section and stone size were tested and determined on hydraulic scale models.

As overflow sections are rarely in action (approximately every two or three years) and, if so, practically never over their whole lengths, landside riprap-protected slopes are covered with riverside sand and seeded. Otherwise they would look barren and ugly. It has even been found out that this grass serves as an additional slope and crest stabilisation. The risk of potential destruction during floods is accepted.

By way of winding up, it should be mentioned that in special cases plastic foil has lately been used as a sealing element in permanent embankments on the Danube. This development was spurred by the excellent experience made with sealing of construction-pits up to 1.4 km² in area by providing thin diaphragm cutoffs in the foundation and plastic foil in the fill. This method has completely replaced the former steel sheet piling, which took long to construct and was high in cost, and has contributed a great deal towards accelerating and rationalising the construction process.

2. Drau (see Table: Drau)

The river Drau, flowing through East Tyrol and Carinthia in an easterly direction, collects the greater part of the run-off from the southern flank of the main ridge of the Alps and from the Southern Calcareous Alps. With a catchment area of 11000 km² and a mean flow of 275 m³/s, it leaves Austrian territory near Lavamünd. Its adjoining reach in Yugoslavia is also developed for electricity production. Development completed to date on the Austrian Drau encompasses an about 105 km-long reach between the town of Villach and the national border, with a head of 144 m. Development of the fairly flat reach upstream of Villach, up to Möllbrücke (outlet of Malta lower stage) near Spittal an der Drau is in process, with the Villach station in operation, Kellerberg under construction and three further projects in the design stage. This Upper Drau section is about 50 km long and develops a head of 67.5 m.

Independently of these reaches of the Drau in Carinthia, construction of a run-of-river scheme at Strassen-Am-lach was started in 1984, in East Tyrol. This will be a diversion-type power station (22 km tunnel) utilising a high-grade reach with a head of 370 m between Tassenbach and Lienz. With a capacity of 60 MW, Strassen-Am-lach will generate an energy of 233 GWh p. a.

For chronological reasons, the description of power stations given in the following paragraphs will be against the direction of flow, proceeding in an upstream direction from the Austro-Yugoslav border. The series of developments on the lower and middle Drau (Lavamünd to Rosegg) comprises seven power stations with a total capacity of 480 MW and generating 2367 GWh p. a. Addition of the Villach station on the upper Drau brings the total installed capacity to 504 MW and the annual energy to 2474 GWh, which make this the second largest series of run-of-river stations in a river basin in Austria.

Five power stations are barrages, with spillway and powerhouse forming a single structure. The uppermost station, Rosegg—St. Jakob, has a separate weir structure, a headrace 3.4 km long capable of a discharge of 430 m³/s, and a powerhouse located on the river bank. The most downstream station, Lavamünd, was constructed as a pierhead power station (Grenng-Laufer) in 1942. This is equipped with one 8.3 MW-capacity vertical-shaft Kaplan turbine in each of the three weir piers. The same design was applied for power stations following downstream, on the Yugoslav reach (as for instance Dravograd and Maribor).

Heads attain a maximum of 26 m, which implies that the water level is raised substantially. This calls for dykes up to 24 m high along the backwater reaches. Recent dykes are almost uniformly of the gravelfill type with bitumen facings (concrete at Edling) on the waterside slope (inclined at 1:1.75) and with thin diaphragm and cast in situ walls as cutoffs in the foundation as impervious elements (Fig. 5). Construction of a thin diaphragm consists of vibrating an I-beam some 20 m deep into alluvial material (gravel/sand) with a cement-flour-bentonite mix being injected as the beams are gradually withdrawn, so as to form an impervious diaphragm several centimetres in thickness.

Weir piers and powerhouse structure (Fig. 6), designed in accordance with the surface level of the impounded water, attain heights of 40 m. Some of the power stations are founded on rock and those situated in flat valley reaches on conglomerates, which called for deep cutoffs, Annabrücke on sand-gravel layers, for instance a grid of thin diaphragms. At almost all the stations, there are inspection galleries in the weir sill and below the turbine inlet, rendering possible subsequent grouting.

Whereas Lavamünd and Schwabegg were constructed during the war, between 1939 and 1944, development was continued from 1959 and terminated with the completion of Annabrücke in 1981. It may be worth mentioning that the first two stations are equipped with hook-type double-leaf gates and all the following stations with tainter gates on the spillway structures and that concrete volumes in general vary between 130 000 m³ and 170 000 m³ for heads of between 20.5 m and 24.0 m. It is only the Lavamünd pierhead power station, with a head of 9.0 m, which required not more than 52 000 m³ of concrete.




Fig. 6. Drau: Weir and powerstations at Ferlach

The above mentioned dykes on the banks of the backwater reaches along the Drau, 6 m to 24 m in maximum height, have fill volumes of between 0.4 and 5.0 million m³, depending on the topography.

Following extensive study of different project possibilities and problems of regional planning, construction was started on the Upper Drau series of power stations in 1981. This includes 5 power stations. Proceeding in an upstream direction, these are Villach, Kellerberg, Paternion, Mauthbrücken and Spittal, the latter two having heads of 18 or 19 m, the former three of about 10 m. The series of power stations will have an installed capacity of 3 × 24 MW and 2 × 49 MW, that is a total of 170 MW, and will generate 675 GWh p. a. Villach has been in operation since 1984. Kellerberg is scheduled for completion and initial operation in 1985/86. Further development is planned to continue in an upstream direction, to be finished between 1992 and 1995.

The Villach, Kellerberg and Paternion stations are pier-head power stations with two power unit piers and three spillway bays each, whereas the two stations with higher heads, Spittal and Mauthbrücken, are planned to be built in an artificial widening of the river bed. Except for the Villach station, which is located on a ridge of rock, the remaining four stations have to be founded on fine-grained, little consolidated post-glacial lake deposits, so that here too the main structures have to be placed on foundation grids of thin diaphragms as a precaution against potential earthquake risks.

Backwatering along this series of power stations has to be confined to the original width of the river, as the valley floor in this area is intensively cultivated. Except for the Villach station, whose backwater area is situated between high banks, continuous dykes have to be built

on both banks almost everywhere. They will even be continued as flood protection dams beyond the upstream ends of the backwater areas so as to connect to a ground, natural or artificial, that is high enough to be safe from floods. Dykes are mainly of gravelfill. Imperviousness is accomplished by thin diaphragms in the foundation and stone-covered asphaltic concrete facings on the embankments. Flood protection afforded by the power projects is evidence of the multi-purpose character of these stations.

All the power stations of the above two series in Carinthia are operated by Österreichische Draukraftwerke AG (ÖDK) in Klagenfurt. Except for Schwabegg and Lavamünd, they were also designed and constructed by this company. The existing stations are operated on a pondage basis in accordance with the demand. The flow regime during the winter months is greatly enhanced by valuable contributions from upstream storage schemes (Reisseck, Fragant, Malta), so that winter energy accounts for 37 per cent and summer energy for 63 per cent of total annual generation.

The above mentioned Strassen-Amlach station on the Drau is situated in the most upstream reach of the Drau, in East Tyrol, and is being constructed by Tiroler Wasserkraftwerke AG (TIWAG) in Innsbruck. The Drau will be diverted near the Austro-Italian border by a two-bay weir and a daily storage basin, from which a power tunnel some 22 km in length (design cross section ranging from 3.20 to 3.40 m) will lead to a surge tank, pressure shaft and above-ground powerhouse in the vicinity of Amlach near Lienz. With a rated discharge of 20 m³/s and working under a head of 370 m, the station will have a capacity of 60 MW and produce an annual energy of 233 GWh (67 per cent in summer and 33 per cent in winter). This station is planned to be placed into service in 1988. The 60 km reach of the Drau between the outlet works near Amlach and the upstream end of the Spittal backwater reach is the subject of general development studies. It should finally be mentioned that the Malta lower stage, also to be considered as a run-of-river scheme (41 MW and 114 GWh), joins the Drau as a tributary at the upstream end of the Spittal backwater reach.

3. Enns (see Table: Enns)

Rising in the northern part of the Alps (Niedere Tauern), the Enns is the only major river (catchment area is 6 100 km² and mean flow is 220 m³/s) to flow on Austrian territory over its whole length. The main part of this river, that is its middle and lower course about 130 km in length and with a substantial fall, down to its mouth in the Danube, is developed by a continuous series of power stations. It is only near the town of Steyr that a reach about 3 km long has remained unaffected. In this manner, a total gross head of 324 m is utilised by fourteen power stations with a total capacity of 518 MW and generating 2373 GWh p. a. This also includes the most upstream Hiefalau, a diversion-type power station with an about 6 km-long tunnel and a combined surge tank and daily storage reservoir at Waag, developing the steep gradient of a gorge named Gesäuse.

This pilot power station is followed by stations at Landl, Krippau and Altenmarkt. These have weirs equipped with small turbines for water release to the reach from which flow is abstracted, as well as power tunnels and power stations (of which two are underground) equipped with one power unit each. This group of four power stations, situated along the Styrian reach of the river Enns, were placed into operation between 1955 and 1967 by Steirische Wasserkraft und Elektrizitäts AG (Steweag) in Graz. All the stations are located within a narrow valley the Enns has cut through limestone and dolomite formations. No unusual foundation problems were encountered, except for foundation treatment in the weir areas to ensure imperviousness.

Downstream follow ten power stations with different layouts to suit local conditions. Schönaue, Losenstein, Ternberg, Rosenau, Staning and Mühlradung show the usual side-by-side arrangement of spillway and powerhouse, with 3 to 5 spillway bays and 2 to 4 turbines. Narrowness of valley section at Weyer and additional difficulties from the presence of a railway line and a road called for a concept with 2 spillway bays and a power unit pier in between and with a second power unit located at the end of a short tunnel in the river bank about 1 km downstream of the weir site. At Grossraming, a symmetrical arrangement was adopted with a two-bay spillway in the middle and one power unit on each bank. At Garsten, the power station was built in a cut across a river bend, with a small turbine catering for water delivery to the dead branch. St. Pantaleon is a diversion-type power station with a 9 km-long asphalt-lined headrace, a powerhouse equipped with two power units and a downstream tailrace canal ending in the Danube. A remarkable feature of the two vertical-shaft Kaplan turbines in the St. Pantaleon powerhouse is the so-called spiral casing outlet. This consists of a gate device provided in the rear wall of the spiral casing. The gate opens when the unit is stopped, so as to prevent surge from developing in the long headrace. A remarkable feature is the fact that one Kaplan unit each at Weyer and St. Pantaleon is designed for 16 ⅔ HZ traction current. These ten power stations of the Enns are operated by Ennskraftwerke AG (EKW) in Steyr.

Development of the river Enns was started in 1941 and terminated in 1972. The characteristics of river course, geology, population pattern and traffic routes led to a multitude of interesting solutions. Many of the experiences gathered in this way have subsequently been used in other run-of-river developments. It should be mentioned in this context that the middle reach of the river Enns was the subject of discussions that went on for years. Besides the multi-stage project finally realised, an alternative was considered which provided for a single-stage scheme with a dam about 100 m high. The advantage of a large energy reserve, which would also benefit downstream power stations, conflicted with adverse effects on inhabited areas, railway lines and roads. In fact, almost 30 years ago, the problems created by a large reservoir with fluctuating water levels in an inhabited region in the foothills of the Alps (about 400 m a. s. l.) were already felt, perhaps even subconsciously, and the decision then taken appears to have been the right one in the light of our present consciousness of environmental impact.

The power and energy of the continuous series of power stations on the Enns, i. e.

Steweag	140 MW,	681 GWh
EKW	378 MW,	1692 GWh
total	518 MW,	2373 GWh

has been available to the Austrian electricity supply since 1972, that is for more than 12 years. Nearness of these power stations to the Upper Austrian and Styrian industrial area affords considerable advantages, additional benefit resulting from pondage operation carefully scheduled to meet the requirements as they arise during the day. This past decade has also shown that nature and man have willingly accepted the inevitable changes involved. The scenic appearance of the backwater areas along the river is anything but that of destroyed nature. The river Enns is a very good example of how wrong it would be to assess environmental effects on the basis of the planning and design stage. It should also be mentioned in this context that hydro development was accompanied by the construction of roads and sewage treatment plants and the provision of recreation and sports facilities. In the long abstraction reach downstream of the weir diverting flow to the headrace of St. Pantaleon, a separate weir was constructed only to maintain the water level in the river bed.

4. Inn (see Table: Inn)

Apart from the Danube, the Inn is the largest river in Austria. Its uppermost catchment area lies in south-eastern Switzerland. Then it flows through Austria over a length of 220 km, from the Tyrolean-Swiss boundary near Pfunds (Hochfinstermünz) to the boundary with Germany (Federal Republic) near Kufstein. It is only after a further length of 150 km in Germany that, from its junction with the Salzach coming from the central Alpine region in Austria, it forms the Austro-German boundary and then, near Passau, discharges in the Danube, which at this point is divided between Germany and Austria. Catchments and mean flows at the above mentioned points along the Austrian boundary are as follows:

Boundary	Catchment	Q_m
(a) Switzerland/Austria	2700 km ²	75 m ³ /s
(b) Austria/Germany	9400 km ²	320 m ³ /s
(c) Germany/Austria (incl. Salzach)	22900 km ²	700 m ³ /s
(d) Germany/Austria (Passau) .	26000 km ²	750 m ³ /s

The 220 km-long upper course of the Inn (Tyrolean Inn) is at present utilised for energy production by not more than two power stations, Prutz-Imst and Kirchbichl. Both are isolated power stations owned by Tiroler Wasserkraftwerke AG (Tiwag), Innsbruck, described later in this report.

In the German reach of the river Inn, systematic development was carried on, with some interruptions, ever since construction of a diversion-type power station was started at Töging as far back as 1919, and was finally completed with the commissioning of Nussdorf in 1982. This developed reach comprises 10 power stations — one diversion-type power station and nine stations in the river bed — of which the youngest and most upstream station, Nussdorf, is situated entirely on German territory (Bavaria), whereas backwatering partly extends into

the right-hand bank area, which is Austrian, so that Austria's share of this station's output accounts for 23.5 per cent. Upstream of Nussdorf follows the site of the Oberaudorf project, also jointly owned (one half each) by Germany and Austria, with the powerhouse and backwater area being situated along the Upper Boundary Inn, which extends as far as Kufstein. Commencement of construction of this project is envisaged for 1986.

In the boundary section ("Grenz-Inn"), covering a length of 70 km between the mouth of the tributary Salzach and the junction with the Danube, development as a continuous series of power stations was started in 1939 and completed in 1965. Five power stations with heads of between 9.70 m and 11.60 m were constructed. A fairly uniform general concept was maintained, in particular on the projects realised between 1951 and 1965, Braunau-Simbach, Schärding-Neuhaus and Passau-Ingling. Together with the Ering-Frauenstein and Eggfling-Obernberg power stations, constructed in the years of war 1939 to 1944, this group develops about 80 km of river length with a head of about 53 m, with a generating capacity of 435 MW and an annual energy of 2470 GWh made available in equal shares to the Federal Republic of Germany and Austria.

The joint development of the Boundary Inn can be regarded as the very example of successful intergovernmental cooperation in the field of hydro development and power economy as well as in solving the technical, administrative and financial problems arising in planning, design, construction and operation.

The importance of the Inn in terms of water resources and energy potential is illustrated by the following characteristic values of the Inn at its junction with the Danube near Passau, where it substantially exceeds the Danube in flow:

	Inn	Danube
Catchment area	26 100 km ²	48 200 km ²
Annual volume of flow	23×10^9 m ³	21×10^9 m ³
Q_{min}	195 m ³ /s	165 m ³ /s
Q_m	750 m ³ /s	630 m ³ /s
Q_{max}	7400 m ³ /s	3700 m ³ /s

All the power stations along the Boundary Inn are equipped with vertical-shaft Kaplan turbines (14 to 24 MW each) and show a completely uniform design for reasons of economy. The same applies to the spillways, which consist of five bays of 23 m width and 6 m-wide piers, all closed by hook-type double-leaf gates, at four power stations alike (Fig. 7). Only Ering has six 18 m-wide spillway bays and 5 m-wide piers. All the stations are founded on schlier locally called "flinz", except for Passau-Ingling, which is founded on granitic gneiss. The flinz present in the Inn basin is a very stable, impervious and ultra-fine grained sediment perfectly capable of withstanding the structural loads involved. The statical system of the spillways consists partly of a continuous slab with piers placed on top and partly of independent spillway bays and piers (on the granite at Passau-Ingling). In the latter case, bays are fixed with rock anchors to absorb uplift forces. The spillway and powerhouse structures are provided with sheet piling cutoffs and/or appropriate keys. Concrete volumes are all between 150 000 m³ and 180 000 m³ per power station. All the power stations were constructed in the original river bed in two successive pits, with diversion of part of the river




Fig. 7. Inn: Weir at Passau-Ingling

flow. Pit-enclosures consisted of caisson walls as well as gravelfill dams with sheet piling cores or partly anchored sheet piling or sheet pile cofferdams.

The structural design of the whole development is called "Inn-type" and is characterised by flat buildings serviced by a main gantry crane moving over the whole installation.

Structural measures in the backwater areas included dykes up to 9 or 10 m high, especially at Braunau-Simbach and Schärding-Neuhaus. Waterside slopes (1:1.75) are protected with poured in-place concrete blankets with breakwaters on top and sheet piling at the toes (Fig. 5). This shows that construction of thin diaphragms, later to be applied on the Danube and on the Drau, was not used before 1960. Recipient and drainage channels and, where required for topographical reasons, pumping stations had to be provided outside the dykes. As mentioned above, Nussdorf, the second power stations downstream of Kufstein, near the boundary, has been in operation since 1982; this is of the pierhead type. The foundation is made up of largely impervious fine sand. Sheet piling and a heavy spillway floor safe from uplift were required. Dykes received concrete blankets on the slopes and thin-diaphragm foundation cutoffs as impervious elements. Nussdorf is capable of 48 MW and generates 226 GWh p. a. Austria's share accounts for 23.5 per cent (i. e. 11.3 MW and 53 GWh p. a.).

The planned Oberaudorf station will be fairly similar to Nussdorf, except that horizontal-shaft Kaplan turbines (bulb turbines) will be provided in the powerhouse piers. Generation from this power station will be divided in equal shares between Bavaria and Austria.

By way of summary, it can be said that the almost completed development of the Austrian-German Boundary Inn is evidence of successful technological efforts and, as a uniform whole serves international utilisation. Development after the Second World War was undertaken by the Österreichisch-Bayerische Kraftwerke AG (ÖBK) in Schärding.

The Prutz-Imst station, mentioned at the beginning of this chapter, is situated between the Swiss boundary and Innsbruck and was completed in 1956. It utilises the fall of the river Inn near Landeck by cutting across a large river bend by means of a 12.3 km-long tunnel. The station is designed for a discharge of 75 m³/s, the developed head is approximately 140 m. The weir is situated at a narrow valley section near Prutz, the site of the large Kaunertal power station with the Gepatsch seasonal-storage reservoir, and consists of three bays arranged

polygonal in plan to allow hydraulically favourable discharge, and closed by hook-type double-leaf gates. A sand catching installation next to the weir forms the transition to the power tunnel; the power station, accommodated in a cavern, is equipped with three Francis turbines with a total capacity of 82 MW. Annual energy, enhanced by the storage effects from the Kaunertal scheme and from reservoirs in the upper river course in Switzerland, is 537 GWh.

The second power station on the Inn, Kirchbichl, was constructed as a run-of-river station between 1938 and 1941. Its headrace canal, 1020 m in length, cuts across a pronounced river bend upstream of Kufstein. With a capacity of 23 MW and an annual generation of about 134 GWh, this station is of no more than local importance. The four-bay weir structure, equipped with hook-type double-leaf gates, is capable of discharging a Q_{\max} of about 1200 m³/s. Next to it is the turbine inlet admitting 250 m³/s; head is 8.10 m. Foundation of the weir on coarse gravel called for a large amount of sheet piling. At present, the Austrian electricity supply derives from the utilisation of the river Inn, that is, 50 per cent in the lower Boundary Inn (Braunau to Passau), 23.5 per cent at Nussdorf, as well as Kirchbichl and Prutz-Imst, $217 + 11 + 105 = 333 \text{ MW}$ and $1235 + 53 + 671 = 1959 \text{ GWh p. a.}$ of run-of-river power. The above-mentioned Oberaudorf boundary station will presumably be constructed in the near future. Planned projects for the Tyrolean reach of the river Inn include a diversion-type power station utilising the 160 m head of the Austrian-Swiss boundary section and the adjacent purely Austrian section down to Prutz, as well as several run-of-river stations.

5. Mur (see Table: Mur)

The river Mur rises on the southern flank of the main ridge of the Alps (Niedere Tauern). It first flows in an easterly direction, then continues southward, passing through the city of Graz, and finally reaches the Austro-Yugoslav boundary zone. Its catchment area is approximately 10000 km² and its mean flow 158 m³/s. Development of this river began before 1904, then was carried on at large intervals and is now nearing completion in the middle reach upstream and downstream of Graz. Over the last few years, development has been started in the uppermost reach, which is partly on Salzburg territory. Thus, projects are under construction at Einach (28 MW, 125 GWh) and St. Georgen; Bodendorf has been in operation since 1982. The latter two, however, have capacities less than 10 MW. Over the last two decades, development has proceeded stage-wise, mainly in the reach between Graz and Spielfeld (where the Boundary Mur begins). All the projects are run-of-river stations with three-bay spillways and adjacent powerhouses equipped with 2 bulb turbines each. Development of the reach upstream of Graz, up to the Dionysen station, dates back to the period between 1908 and the time of the Second World War. In accordance with the state of engineering at that time, these power stations are mainly of the diversion type, with long open headrace canals, which allowed heads of up to 19 m to be accomplished. Construction and operation is in the hands of two companies, Steirische Wasserkraft- und Elektrizitätsgesellschaft (Steweag), Graz, and Steiermärkische Elektrizitäts AG (StEG), Graz.

The five major power stations (of more than 10 MW each) situated upstream of the provincial capital, Graz, at Dionysen, Pernegg, Lauffnitzdorf, Peggau and Weinzödl, have a total capacity of 76 MW and generate 429 GWh p. a. In some time, this total output will substantially be increased by existing minor power stations and projects under construction, especially in the upper course of the river. — Downstream of Graz, the power stations at Mellach, Gralla, Gabersdorf, Obervogau and Spielfeld have about the same total output, i. e. 71 MW and 373 GWh; reconstruction of a minor station at Lebring will add another 14 MW and 60 GWh.

As mentioned before, almost all the stations in the upper reach of the river are of the diversion type equipped according to the state of engineering at the time of their construction: vertical-lift gates, roller drum gates and hook-type double-leaf gates; concrete-lined trapezoidal channels; powerhouses equipped with Francis turbines, some of which have meanwhile been replaced by Kaplan turbines. The Weinzödl power station, completed in 1982, is equipped with two Straflo units, where the generators are arranged around the turbines.

With about 150 MW and approximately 800 GWh p. a., the series of power stations on the river Mur, although counting among the smaller developments, is interesting in conveying an idea of hydro development in Austria over the past 80 years. Many a valuable impetus has come from engineering feats accomplished on the Mur, both in the past and in our time. Substantial hydro reserves are still available, both in the upper course and along the reach forming the boundary with Yugoslavia over a length of about 36 km with a fall of about 50 m.

6. Salzach (see Table: Salzach-Traun)

The Salzach drains the northern flank of the Hohe Tauern mountains and flows over almost its whole length of 225 km (source to junction with the river Inn) on the territory of the province of Salzburg. It is only over its lowest reach of 59 km that it forms the boundary between Bavaria (Federal Republic of Germany) and Salzburg and then Upper Austria. At its junction with the Inn it has a catchment area of 6734 km². In spite of the substantial energy potential of this river, only a small station of about 3 MW capacity was constructed in 1928 for a paper mill at Hallein. It is only after the construction of the Glockner-Kaprun group of storage schemes that the reach with the highest gradient, between Bruck and Golling, below the mouth of the tributary Kapruner Ache, was developed. The Schwarzach power station, constructed on the Salzach between 1953 and 1958, is a special case in that it resembles the Prutz-Imst station in enjoying the advantage of an increased streamflow during the winter season from upstream reservoirs, which belong in the Glockner-Kaprun group of storage schemes and the schemes owned by the Austrian railways in the Stubach valley. — Schwarzach has in fact often been called the "lower stage of Kaprun".

The three-bay weir, capable of discharging a maximum flood flow of about 900 m³/s, diverts a maximum flow of 90 m³/s. After passing through sand traps (of the Dufour type), this is conveyed through a tunnel 16.9 km in length and 5.50 m in diameter, which ends in a daily-storage reservoir with a capacity of 1.5 million m³,

allowing generation to be scheduled in accordance with the demand. The power station is located downstream of the reservoir and is equipped with four Francis turbines of 30 MW capacity each. The Schwarzach power station generates 480 GWh p. a.

It was for the construction of the long and large-diameter power tunnels of the Prutz-Imst (1953—56:) and Schwarzach (1954—58) power stations that the most outstanding progress in modern tunnel engineering was achieved, now universally known as the New Austrian Tunnelling Method. This is based on the principle of immediate application of the tunnel lining using shotcrete and rock bolting or anchorage, so as to include the rock mass surrounding the opening as a load-bearing element. This method can even be applied in rock of poor mechanical properties.

Operation of the seasonal-storage schemes on the tributaries of the river Salzach (Kaprun and Stubach) bring a substantial increase in streamflow during the mid-winter months (for instance from 11 m³/s to 27 m³/s in February, from 15 m³/s to 30 m³/s in March), but also an about 10 per cent decrease during the mid-summer months.

Following the Schwarzach power station, study of a great number of project possibilities led to the selection of a Middle Salzach series of six power stations covering a length of about 20 km and affording a head of 61 m, to be constructed in several phases. Work was started on the two power stations in the middle, of which Bischofshofen has been in operation since 1984—85. The Urreiting power station immediately upstream, of practically equal design, is under construction and will be placed into operation in 1986. By that time, more than one-third of the planned total of 90 MW and 418 GWh p. a. (30 per cent in winter and 70 per cent in summer) will be completed. Each station consists of a powerhouse block with horizontal-shaft bulb turbines and an adjacent low three-bay spillway block (Fig. 8). The relatively low dykes have an asphalt facing overlain by dry stone pitching and a thin diaphragm cutoff extending almost 20 m into the foundation for imperviousness. The next stations to be built are those at Grafenhof and St. Johann (upstream of the Urreiting power station), followed by Kreuzberg-Maut and Pfarrwerfen (downstream of Bischofshofen).

In the much flatter reach between Golling and the river's junction with the Inn, a single power station, Urstein, has so far been built. It was completed in 1971. With a rated discharge of 250 m³/s it has a capacity of 20 MW and generates 107 GWh p. a. A special feature of this power station is the inclined bulb turbines in the low powerhouse block. In terms of stream engineering, Urstein has to fulfil the additional function of preventing further degradation of the river bed. A similar project is planned to be realised in the near future some 5.5 km further upstream, at Hallein.

For several decades, plans have been considered which provide for the construction of a series of power stations in the reach downstream of the city of Salzburg, below the mouth of the tributary Saalach, where the Salzach forms the boundary with Bavaria. Construction would be in conjunction with Bavaria as practised on the projects in the Boundary Inn. A definite date for the implementation of this project is not known.

At present, the river Salzach with its three power sta-




Fig. 8. Salzach: Weir and powerstation at Bischofshofen

tions, Schwarzach, Bischofshofen and Urstein, affords a capacity of 156 MW and 660 GWh p. a. of run-of-river energy, which will be brought to 173 MW and 740 GWh p. a. with the completion of Urreiting.

Whereas Schwarzach, as a lower stage to the Kaprun scheme, was constructed and is operated by Tauernkraftwerke AG (TKW) in Salzburg, development of the middle course of the Salzach is jointly undertaken by TKW and SAFE (Salzburger AG für Elektrizitätswirtschaft, Salzburg), Urstein by SAFE alone. The river Salzach still offers substantial reserves upgraded by the winter releases from the storage reservoirs in the Hohe Tauern mountains.

7. Traun (see Table: Salzach-Traun)

Rising in the Aussee and Dachstein region in the Salzkammergut, the river Traun flows through the Hallstättersee and Traunsee lakes. Leaving Traunsee at Gmunden, it flows through the lowlands near Wels for a length of 75 km and discharges in the Danube right below Linz. The water power offered by this river has for

a long time been used to advantage by local industries. In fact, development at several points began already before 1900, first by crafts, later by larger enterprises, in particular by the paper industry. First small hydro stations were built near Steyrermühl, Laakirchen and Lambach. All of them had relatively low heads and rated discharges, and hence limited capacities. Subsequent reconstruction, however, rendered possible the installation of larger power units. The Traunleiten power station owned by the Wels electricity supply company was substantially enlarged as recently as 1970. Between 1969 and 1982, major run-of-river stations were commissioned on the Traun. These are Gmunden, (Traunfall, however of only 8.8 MW capacity), Marchtrenk and Traun-Pucking constructed by Oberösterreichische Kraftwerke AG (OKA) and Kleinmünchen by the second provincial company of Upper Austria, ESG, in Linz. Further hydro stations — partly to replace existing small plant — are planned to be built in accordance with a master plan that has been prepared for the river Traun. The Salzkammergut reach of the Traun, including Traunsee, is not utilised by major power facilities. The catchment area above the lake outlet near Gmunden is




Fig. 9. Austria, location of run-of-river plants




Fig. 10. Chronological table of run-of-river plants

approximately 1400 km² and mean flow is 72 m³/s. The lakes in the upper course, especially Traunsee, have an equalising effect on the flow regime. Over the 75 km reach down to the junction with the Danube, the catchment area increases to 4300 km² and mean flow to 138 m³/s.

An interesting fact from the engineering point of view is the installation, for the first time in Austria, of two bulb turbines, in an inclined position, at the Gmunden power station. The recent stations in general have 3-bay spillway structures and adjacent powerhouses. It is only at the most downstream station, Kleinmünchen, that an open headrace canal, some 5.7 km in length, was constructed. Impounding by the three lower power stations has greatly improved the groundwater conditions in the Welser Heide plain and the whole area extending between Wels and Linz, where unacceptable river bed degradation had occurred. In addition, development of this reach of the river Traun gave the decisive impetus for tackling the severe waste water problems mainly caused by the paper and cellulose industries on the Traun, Krems and Ager. The development of the Traun demonstrates that run-of-river power projects may very well fulfil several functions at the same time.

Electricity generation on the Traun, in the four power stations at Gmunden, Marchtrenk, Pucking and Kleinmünchen, is 526 GWh p. a., with a capacity of 103 MW. Addition of the two stations of slightly less than 10 MW capacity, Traunfall and Traunleiten (Wels), would bring this to 655 GWh and 121 MW. Including the small industrial power stations, the river Traun produces slightly more than 700 GWh p. a. This will substantially be increased when the master plan is realised.

8. Other Run-of-River Plant

As mentioned above, the bulk of Austria's run-of-river power is supplied from the power stations on the country's seven main rivers. In addition, there are a number of run-of-river stations with or without daily storage which have capacities greater than 10 MW. Together, they account for about 7.5 per cent of total run-of-river energy. This corresponds to about 5.5 per cent of the developed hydro potential or 4 per cent of total electricity production. Not included is total generation by minor power stations (of less than 10 MW), which are almost exclusively of the run-of-river type.

Table 3 presents "other run-of-river plant" of more than 10 MW capacity, listed in geographical order from west to east. 3 stations owned by Österreichische Bundesbahnen (ÖBB) and schemes operated as daily-storage reservoirs are listed separately. In total, these power stations correspond to 425 MW and 1760 GWh p. a. Classified in terms of water engineering, there are four stations acting as lower stages to existing storage schemes, i. e. Walgau as part of the Illwerke group, Braz as part of the Spullersee scheme, Uttendorf as part of the Stubach group, and Malta lower stage as part of the Malta and Reisseck groups. The Klaus power station on the Steyr is a true dam power station, where head is created by impoundment only. All the other stations utilize downgrade sections with more or less high heads. They were mainly built to meet local requirements of communes and industries in an early phase of water power development, especially between the two world wars. Having tunnels between power intakes and power stations, almost all these stations are of the diversion

Table 3. Other run-of-river plants

Power Station	Owner	Energy (AAE) GWh/a			Capacity (MC) MW			
		R.*	dst.**	ÖBB***	R.*	dst.**	ÖBB***	
Walgau Andelsbuch Gampadels Braz	VIW VKW VKW ÖBB	356	47 26	100	86	14 12	30	Vorarl- berg
Wiesberg Oberes Sillwerk Unteres Sillwerk Weißhaus-Reutte Bösdornau Kalserbach	DoCh EWJ EWJ EWR TKW TiWag	80 94 135 72 64	61		17 13 28 13 25	12		Tirol
Uttendorf Bärenwerk Rauris-Kitzloch Klammstein-Lend	ÖBB SAFE SAG SAG	57 97 114		75	12 14 21		27	Salzburg
Ober-Vellach Malta-Unterstufe Schütt	ÖBB ÖDK Kelag	114 64		75	41 14		15	Kärnten
Klaus	EKW	73			20			OÖ.
Opponitz	WstW	56			11			NÖ.
		1376	134	250	315	38	72	
		1760 GWh			425 MW			

* R. = run-of-river station

** dst. = daily storage

*** ÖBB = Austrian railway

type. Heads vary between about 30 m (Opponitz and Schütt) and 400 m (Gampadels). Naturally, the stations termed above as "lower stages" have their hydro potential considerably upgraded by the presence of upstream storage reservoirs.

Summary

(Map of Austria, Fig. 9)

The preceding chapters have presented a description of run-of-river plant on the main rivers in Austria as well as other isolated stations of more than 10 MW capacity. Tables at the end of this report list in the direction of flow the individual units of the series of power stations, their main plant data such as rated discharge, head, capacity and annual energy, as well as their technical details and general arrangements. The tables also indicate owners and/or operating companies as well as years of initial operation. Details for these lists have been made available by the electricity undertakings concerned, for which thanks are due to them.

By way of summary, it can be stated that run-of-river power in Austria, as mentioned at the beginning of this report, meets a large proportion of total electricity requirements, in general more than half the domestic requirements. As demonstrated by Table 4, the seasonal pattern of flow availability is surprisingly favourable for an Alpine country.




Table 4. Annual pattern of mean monthly generation by total run-of-river plants

Figure 10 is a chronological table of run-of-river stations. Construction periods are shown only schematically for the sake of clearness. No allowance has been made for partial or phase-wise placing into service of individual power units. The chronological table also presents increases in the annual run-of-river energy produced on the seven rivers; these clearly show two distinct periods. Annual generation by run-of-river plant in these river basins rose from 290 GWh in 1940 to 3200 GWh in 1955, which corresponds to an average increase of 200 GWh p. a. In the following 30 years to 1985, annual generation rose to 20500 GWh, corresponding to an annual increase of about 560 GWh. This has mainly been

rendered possible by the development of the rivers Danube, Drau and Enns. For the sake of completeness, the increase in storage hydro plant should be entered on this chronological table. Here too, the main development has taken place these past 30 years, from 1955.

I must insist on emphasising that river basin development planning should be aimed at the eventual provision of continuous series of power stations, as this is the only way of finding optimal solutions to the effects of river basin development on river morphology and ecology. An example of this is the complete development of the Boundary Inn, the whole Enns series, the lower and middle Drau, and above all the Danube. In the latter case, additional advantage is afforded to navigation, for which an alternation of backwater areas and free flow reaches is to be avoided by all means. This fact has always been taken into account in the preparation of master plans.

Lately, however, further development of water power, especially run-of-river power, has increasingly been rendered difficult or impossible, especially by conservationist movements, although energy production from water power is the cleanest conversion of a natural resource into service energy, without using primary energy. There are no emissions, and impact on the environment is minimal. In the particular case of the Danube, an additional benefit is afforded by the improvement of navigation, a means of transport that exhibits the lowest specific energy demand and thus also contributes towards air pollution control. Moreover, other hydraulic engineering problems besides power generation have always been allowed for in run-of-river power project planning. These may concern for instance sewage, river bed degradation, local flood control, the provision of traffic routes and recreation areas. The fact that backwater areas above the power stations in the river Inn have been classified as nature reserves because of their flora and fauna demonstrates that run-of-river power and ecology or nature conservation are compatible factors, provided though that all the parties concerned will contribute their cooperation as well as constructive, not only conservationist, thinking to the solution of the problems involved. It is the vital service to the population, rather than pursuit of profit, that has been the purpose of water power development during the past decades. Supplying our country with the necessary electricity is of equal priority as food and water supply. After all, agriculture, too, has altered what once was virgin landscape, and it has done so with much more consequence than is necessary in water power development. It is hoped that in future the problems linked with further water power development in general and the construction of run-of-river stations in particular will not be tackled with emotions but with objectivity and expert knowledge. It is only by such an approach that our activities will be appreciated by future generations. An epoch is not judged by what it has prevented, but by what well-considered feats it has achieved.

Baurat h. c. Dipl.-Ing. Dr. techn. Robert Fenz
Martinstrasse 83
A-1180 Wien

Vocabulary

for the Tabela (7 riversystems)

(Bau) (constr.)
T. Sp. daily storage

Gates:

Dpl. Haken hook-double leaf
Segment (Segm.) tainter
Klappe flap
Staubalken (concrete) beam
Grundschild bottom gate
Oberschild top leaf
Schütztafel leaf
Hubschütze lifting gate

Conduit

Stollen tunnel
OW-Kanal headrace canal
UW-Kanal tailrace canal

Powerhouse

hoch high
mittel medium
nieder low
flach flat
Pfeiler KW pierhead station
Kaverne underground station

Table: Danube










Power station	Jochenstein	Aschach	Ottensheim- Wilhering	Abwinden- Asten	Wallsee- Mitterkirchen	Ybbs- Persenbeug	Melk	Altenwörth	Greifenstein	Hainburg	
Owner	DKJ	DoKW	DoKW	DoKW	DoKW	DoKW	DoKW	DoKW	DoKW	DoKW	
Operation since	1955	1963	1973	1979	1968	1957	1982	1976	1984	Projekt	
Stationing	2 203,3	2 162,7	2 146,7	2 119,5	2 093,6	2 060,4	2 038,0	1 979,8	1 949,2	1 883,1	
Storage level	290,3	280,0	264,0	251,0	240,0	226,20	214,0	193,5	177,0	152,0	
Q _{mean}	1 430	1 450	1 450	1 600	1 730	1 750	1 807	1 830	1 882	1 915	
Flow Q _{max}	8 900	8 900	8 900	9 500	11 100	11 100	11 170	11 170	10 750	10 300	
Q _{Rated}	1 750	2 000	2 250	2 475	2 600	2 100	2 700	2 750	3 150	3 150	
Head H _{mean}	10,20	15,30	10,70	9,30	10,90	11,0	8,4	14,80	12,6	15,17	
Capacity (MC)	(132) 66	286	179	168	210	200	187	335	293	360	
Energy (AAE)	(850) 425	1 648	1 143	1 028	1 320	1 282	1 180	1 950	1 720	2 075	
Layout											
Spillway/Weir											
Bays x width	6 × 24	5 × 24	5 × 24	5 × 24	6 × 24	5 × 30	6 × 24	6 × 24	6 × 24	6 × 24	
Pier width/height	5–6/31	7,10/41	7,50/37	6,0/37	7,50/37	7,50/34	6,0/31	7,0/37	6,0/31	7,0/37	
Q max ₁₀₀	8 900	8 900	5 940	8 450	8 600	11 100	11 170	9 785	8 650	8 850	
Gates	Dpl.- Haken	Dpl.- Haken	Dpl.- Haken	Segm. + Klappe	Dpl.- Haken	Dpl.- Haken	Segm. + Klappe	Segm. + Klappe	Segm. + Klappe	Segm. + Klappe	
Powerhouse											
Construction, type	hoch	mittel	nieder	nieder	nieder	mittel	nieder	nieder	nieder	nieder	
max height	52	53	39	40	42	42	39	46	44	49	
Turbines, number and type	5 Kaplan ↓	4 Kaplan ↓	9 Kaplan →	9 Kaplan →	6 Kaplan ↓	6 Kaplan ↓	9 Kaplan →	9 Kaplan →	9 Kaplan →	9 Kaplan →	
Backwater area											
Length	27	40	16	27	26	33	22	32	31	44	
Overflow flood	–	–	2 960	1 050	2 500	–	–	1 385	2 100	1 550	

Table: Drau











Power station	Strassen- Amlach	Kellerberg	Villach	Rosegg- St. Jakob	Feistritz- Ludmannsdorf	Ferlach- Maria Rain	Annabrücke	Edling	Schwabegg	Lavamünd	
Owner	TIWAG	ÖDK	ÖDK	ÖDK	ÖDK	ÖDK	ÖDK	ÖDK	ÖDK	ÖDK	
Operation since	1988 (Bau)	1985 (Bau)	1984	1973	1968	1975	1981	1962	1942	1944	
Stationing	253/230	130 (85)	119 (96)	100/93 (115/122)	78 (137)	69 (146)	54 (161)	30 (185)	13 (202)	7 (208)	
Storage level	m	505,3	495,6	485,5	461,5	437,5	416,4	390,8	369,0	348,7	
Q _{mean}	m³/s	151	154	220	220	225	231	260	269	274	
Flow	m³/s	1 690	1 700	2 300	2 300	2 300	2 450	2 700	2 700	2 700	
Q _{rated}	m³/s	320	320	430	420	450	440	440	405	405	
Head H _{mean}	m	9,7	10,1	22,7	23,7	21,0	25,6	21,1	20,5	9,0	
Capacity (MC)	MW	24	24	80	80	75	90	70	60	25	
Energy (AAE)	GWh	103	107	370	390	336	416	375	340	140	
Layout											
Spillway/Weir											
Bays width	m	3 × 16	3 × 16	4 × 15	3 × 15	3 × 15	3 × 18	3 × 15	4 × 19	4 × 24	
Pier width/height	m	20/24,5	20/25	4,3/22	2,4/39	4,6/40	5,0/40	5,7/36	5,0/33	16/17	
Gates	Segm. + Klappe	Segm. + Klappe	Segm. + Klappe	Segm. + Klappe	Staubalken Segm. + Klappe	Segm. + Klappe	Segm. + Klappe	Segm. + Klappe	Dpl.-Haken	Dpl.-Haken	
Power conduit	Stollen 22	–	–	OW-Kanal 3,4	–	–	–	–	–	–	
Powerhouse											
Construction, type	hoch	Pfeiler-KW	Pfeiler-KW	hoch	hoch	hoch	hoch	hoch	flach	Pfeiler-KW	
max height	m	34	27,5	44	47	42	40	38	34	28	
Turbines, number and type	2 Francis	2 Kaplan	2 Kaplan	2 Kaplan	2 Kaplan	2 Kaplan	2 Kaplan	2 Kaplan	3 Kaplan	3 Kaplan	
Backwater area											
Length	km	1	10,6	10,1	15	9	15	24	17	6	

Table: Enns



Power station	Hieflau	Landl	Krippau	Altenmarkt	Schönnau	Weyer	Großraming	Losenstein	Ternberg	Rosenau	Garsten	Stanning	Mühlradring	St. Pantaleon
Owner	Steweag	Steweag	Steweag	Steweag	EKW	EKW	EKW	EKW	EKW	EKW	EKW	EKW	EKW	EKW
Operation since	1955/56	1967/68	1965/66	1960/61	1972	1969	1950	1962	1949	1953	1967	1946	1948	1965
Stationing	km	114/111	108/101	98/91	86	77,5/76,5	64,4	55,7	47,9	40,2	34,3	20,0	13,8	8,1
Storage level	m	564,5	479,0	425,0	400,5	388,0	371,0	346,5	331,0	315,0	302,0	283,2	268,3	260,0
Q_{mean}	m ³ /s	78	94	126	129	148	156	162	163	164	166	208	208	209
Q_{max}	m ³ /s	1 000	1 100	1 400	1 400	1 900	2 000	2 100	2 120	2 130	2 150	3 000	3 000	3 000
Q_{rated}	m ³ /s	90	120+(20)	120+(45)	106+(18)	280	280	280	280	280	280+15	315	315	315+10
Head H_{mean}	m	78,4	21,4 (15,3)	23,0 (14,0)	23,9 (13,4)	15,7/16,1	23,5	14,8	15,0	12,7	12,3	14,2	8,0	18,8
Capacity (MC)	MW	63	25	29	23	37	65	38	40	28	32	37	21	54
Energy (AAE)	GWh	269	123	153	136	163	246	166	168	134	143	190	101	264
Layout														
Spillway/Weir														
Bays width	m	3 × 12	3 × 12	3 × 12	3 × 12	2 × 18	2 × 22,5	3 × 13,5	3 × 16	4 × 16	3 × 14	5 × 17	5 × 17,2	4 × 14
Pier width/height	m	4,4/19,5	4,7/21,0	4,1/20,0	3,0/19,2	18,0/35,0	4,0/37,0	5,2/31,0	5,7/32,2	5,5/28,0	4,0/23,0	5,0/26,0	4,8/23,0	4,0/21,5
Gates		Segm. + Klappe	Segm. + Klappe	Segm. + Klappe	Segm. + Klappe	Segm. + Klappe	Klappe Grundschütz	Dpl.-Haken	Klappe Grundschütz	Dpl.-Haken	Segm. + Klappe	Oberschütz Segm. Schütz	Dpl.-Haken	Segm. + Klappe
Power conduit	km	Kanal 0,5 Stollen 5,6	Stollen 2,6	Stollen 4,4	Stollen 2,4	Stollen 1,0	—	—	—	—	—	—	—	Ka-OW 6,8 nal UW 2,2
Powerhouse														
Construction, type		hoch	hoch	Kaverne	Kaverne	Pfeiler-KW Kaverne	hoch	nieder	hoch	mittel	hoch	hoch	mittel	hoch
max height	m	29,5	34,3	32,0	33,5	35,0/35,0	45,3	36,6	36,5	32,0	37,4	31,0	24,0	42,6
Turbines, number and type		3 Francis	1 Kaplan + 1 Kaplan	1 Kaplan + 1 Kaplan	1 Kaplan + 1 Francis	1 Kaplan + 1 Kaplan	2 Kaplan	2 Kaplan	2 Kaplan	2 Kaplan	2 Kaplan + 1 Kaplan	3 Kaplan	4 Kaplan	2 Kaplan + 1 Francis
Backwater area														
Length	km	2,0	2,5	3,0	2,9	7,0	12,1	8,7	7,8	7,7	5,9	10,0	6,2	5,7










Table: Inn

Power station	Prutz- Imst	Kirchbichl	Oberaudorf	Nußdorf		Braunau- Simbach	Ering- Frauenstein	Eggfing- Oberberg	Schärding- Neuhaus	Passau- Innling				
Owner	TIWAG	TIWAG	ÖBK	IWAG 53 % ÖBK 47 %	Deutscher Inn-Abschnitt: IWAG L = 123 km, H = 104 m 9 Kraftwerke: Rosenheim bis Stammham 296 MW, 1781 GWh	ÖBK	IWAG	IWAG	ÖBK	ÖBK				
Operation since	1956	1941	1988 (Projekt)	1982		1953	1942	1944	1961	1965				
Stationing	387/360	233/230	211	198		61	48	35	19	4				
Storage level	858,5	497,0	477,4	464,4		348,5	336,2	325,9	314,9	303,0				
Q _{mean}	80	320	320	320		706	715	721	732	746				
Flow Q _{max}	600	1 800	2 400	2 400		6 200	6 400	6 600	6 800	7 400				
Q _{rated}	80	250	580	550		1 000	1 040	990	1 000	1 000				
Head H _{mean}	145,0	8,1	12,5	11,6		11,6	9,6	10,5	11,2	10,0				
Capacity (MC)	82	23	(58) 29	(48) 11		(96) 48	(72) 36	(84) 42	(96) 48	(86) 43				
Energy (AAE)	537	134	(262) 131	(226) 53		(554) 277	(428) 214	(468) 234	(540) 270	(480) 240				
Layout														
Spillway/Weir														
Bays width	3 × 13	4 × 20	3 × 16	3 × 18		5 × 23	6 × 18	5 × 23	5 × 23	5 × 23				
Pier width/height	5–1/16	5/17	20/35,3	25/30,4		6/30	5/31	6/28	6/25	6/27				
Gates	Dpl.- Haken	Dpl.- Haken	Segm. + Klappe	Segm. + Klappe		Dpl.- Haken	Dpl.- Haken	Dpl.- Haken	Dpl.- Haken	Dpl.- Haken				
Power conduit	Stollen 12,3	OW-Kanal 1,1	–	–		–	–	–	–	–				
Powerhouse														
Construction, type	Kaverne	hoch	Pfeiler-KW	Pfeiler-KW		flach	flach	flach	flach	flach				
max height	30	37	35	30		34	34	27	32	32				
Turbines, number and type	3 Francis	3 Kaplan	2 Kaplan →	2 Kaplan ↓		4 Kaplan ↓	3 Kaplan ↓	6 Kaplan ↓	4 Kaplan ↓	4 Kaplan ↓				
Backwater area														
Length	3	9	11	13		14	13	13	17	15				

Table: Mur

Power station	Dionysen	Pernegg	Laufnitz- dorf	Rabenstein	Peggau	Weinzödl	Mellach	Gralla	Gabersdorf	Obervogau	Spiefeld
Owner	Steweag	Steweag	Steweag	StEG	StEG	StEG	Steweag	Steweag	Steweag	Steweag	Steweag
Operation since	1944	1927	1931	1987 (Bau)	1908	1982	1985	1964	1974	1977	1982
Stationing	244,2/239,9	229,6/226,7	222,7/214,8	207,5	205,2/200,8	184,0	159,1	147,6	142,2	137,6	132,3
Storage level	504,3	467,3	448,3	418,8	410,0	363,0	305,5	281,0	271,5	262,0	254,0
Q_{mean} Flow Q_{max} Q_{rated}	80 1 200 85	105 1 500 140	108 1 500 110	115 1 250 180	115 1 250 110	115 1 250 180	124 1 250 180	135 1 250 200	135 1 250 220	140 1 250 240	157 1 500 240
Head H_{mean}	16,5	16,7	18,6	8,2	14,4	9,0	9,6	8,3	8,2	7,1	7,0
Capacity (MC)	12	18	17	13	13	16	16	14	15	13	13
Energy (AAE)	70	105	108	62	78	68	84	71	74	68	76
Layout											
Spillway/Weir											
Bays width	3 × 15	3 × 15	2 × 25	3 × 15,5	2 × 14/3 × 12	3 × 16,5	3 × 15,0	3 × 15	3 × 15	3 × 20	3 × 22
Pier width/height	3,8/15,5	5,0/27,0	5,0/13,5	3,0/18,0	2,0/11,0	3,0/18,0	2,5/19,8	4,0/17,0	4,0/18,0	2,4/18,5	2,4/18,5
Gates	Dpl.- Haken	Dpl.- Haken	Walzen	Segm. + Klappe	Schützen- tafel	Segm. + Klappe	Segm. + Klappe	Segm. + Klappe	Segm. + Klappe	Segm. + Klappe	Segm. + Klappe
Power conduit	OW 3,7 Kanal UW 0,4	OW 2,3 Kanal UW 0,3	OW 7,0 Kanal UW 0,2	—	Kanal 2,1 Stollen 1,0	—	—	—	—	—	—
Powerhouse											
Construction, type	hoch	hoch	hoch	hoch	hoch	hoch	hoch	hoch	hoch	hoch	hoch
max height	33	32	31,4	20,4	17,0	23,0	27,0	29,9	25,7	26,0	26,0
Turbines, number and type	2 Kaplan ↓	3 Francis ↓	2 Kaplan ↓	2 Kaplan ↓	2 Kaplan ↓	2 Kaplan Straflo →	2 Kaplan →	2 Kaplan ↓	2 Kaplan →	2 Kaplan →	2 Kaplan →
Backwater area											
Length	1,5	5,3	4,0	4,0	2,5	1,2	3,4	3,8	5,4	4,6	5,3

Table: Salzach – Traun

Power station	Schwarzach	Urreiting	Bischofs- hofen	Hallein	Urstein	Gmunden	Marchtrenk	Traun- Pucking	Klein- münchen
Owner	TKW	SAFE/TKW	SAFE/TKW	SAFE	SAFE	OKA	OKA	OKA	ESG
Operation since	1958	1986 (Bau)	1985	1987 (Bau)	1971	1969	1979	1982	1978
Stationing	154/135	124	120	80	75	72	24	14	8/2
Storage level	738,0	559,2	547,8	440,7	434,0	422,6	309,5	289,3	262,5
Q_{mean}	60	103	106	154	174	72	128	128	138
Flow Q_{max}	1 100	1 320	1 356	2 200	2 730	950	1 500	1 500	1 500
Q_{rated}	90/110	186	202	220	250	150	200	200	124
Head H_{mean}	132	10,8	9,7	6,7	8,9	10,3	20,2	26,8	10,1
Capacity (MC)	120	16	16	12	20	12	38	42	11
Energy (AAE)	480	80	73	66	107	48	181	222	75
Layout									
Spillway/Weir									
Bays width	3 × 10	3 × 10	3 × 10	4 × 25	3 × 16	3 × 22,5	3 × 13	3 × 13	3 × 18
Pier width/height	3,5/15,0	3,0/21,7	3,0/21,7	1,5/18,6	4,5/21,0				
Gates	Segm. + Klappe	Segm. + Klappe	Segm. + Klappe	Klappen	Segm. + Klappe	Klappen	Segm. + Klappe	Segm. + Klappe	Hub-schützen
Power conduit	Stollen 17	–	–	–	–	–	–	–	Kanal 5,8
Powerhouse									
Construction, type	hoch	flach	flach	flach	flach	flach	nieder	nieder	hoch
max height	25,0	27,3	27,3	29,0	26,0				
Turbines, number and type	4 Francis ↓	2 Kaplan →	2 Kaplan →	2 Kaplan →	2 Kaplan ↘	2 Kaplan ↘	2 Kaplan ↓	2 Kaplan ↓	2 Kaplan →
Backwater area									
Length	1,5	4,5	4,7	2,4	5,3	Traunsee 14	8	10	6

Austria's Contribution Towards the Development of Water Power

By H. Lauffer*

1. Introduction

After mentioning several outstanding Austrian scientists and engineers who played an important rôle in the history of water power development, the author will discuss several innovations which, devised to solve particular problems presented by the Austrian development possibilities, have come to be successfully applied in general hydro development practice. In doing so, the author claims neither exhaustiveness nor originality, as in fact similar solutions, unknown to him, may have been found in other countries to problems discussed in this article.

2. Pioneers in Relevant Sciences and Special Fields

Among the great number of Austrians that have done pioneer work in the sciences and special fields relevant to the development of water power are the following:

In the field of engineering hydraulics,

Philipp Forchheimer (1852 to 1933) should be named. He developed the complete hydraulic basis for water power development already before the First World War.

As a great master in engineering geology,

Josef Stini (1880 to 1958) gave his expert opinion and advice on the greater part of Austrian hydro projects for many decades. His manner of cooperating with construction engineers was exemplary and was to be continued and developed by others, in particular by Eberhard Clar.

The founder of soil mechanics,

Karl von Terzaghi (1883 to 1963), was an expert at introducing engineering considerations where the theoretical knowledge available did not suffice to allow satisfactory judgement of foundation problems.

Among those who continued his work was

Arthur Casagrande (1902 to 1981), who had an important influence on embankment dam construction all over the world.

Among the first pioneers of rock mechanics is

Leopold Müller, who founded the "Salzburger Kreis" ("Salzburg Circle") and the GEOMECHANICS COLLOQUY, first held in 1951, thus creating a singular meeting-place where construction engineers were able to discuss rock problems in theory and practice with geologists, geophysicists and mining engineers.

The fundamentals of sediment transport and scour prevention were studied by

Armin Schoklitsch (1888—1969), mainly in connexion with hydro power projects.

The development of diaphragm walls using bentonite suspension is due to

Christian Veder (1907 to 1984), who thus rendered possible the construction of deep cut-offs.

The utilisation of minor heads was greatly facilitated by the invention of a new turbine by

Viktor Kaplan (1876 to 1934). Power stations equipped with Kaplan turbines account for more than half the hydro generation in Austria.

The development of water power in Austria certainly received its strongest impetus from

Hermann Grengg (1891 to 1978), by a lifetime's work carried out in several functions: first, that of an executive director responsible for design and construction of hydro power projects in Styria, in the Hohe Tauern mountains and along the lower course of the river Drau, which included the introduction in Austria of the arch dam type and the realisation of the first pier-head power stations; then, that of a university teacher, giving incitement to many young engineers; and finally that of an expert and consultant, putting his stamp on a great number of hydro projects.

The following paragraphs will first deal with the dams and waterways of storage power schemes in mountainous regions, and then discuss the low head run-of-river plants developing Austria's rivers. The References at the end of this article are arranged in the same order.

3. Innovations and Progress in the Construction of Large Dams in Austria

In the field of large dams forming storage reservoirs, there has been an intensive exchange of experience within the International Commission On Large Dams (ICOLD). Such exchange is carried on to an even greater extent among the Alpine countries owing to their neighbourly relations. Therefore, most of the innovations in large dam construction discussed in this article are adjustments to the local conditions and possibilities of power sites.

The first example concerns the gravity dam, which is not only the oldest, but also the most frequently used dam type in Austria. The *gravity dams*, 46 m in maximum height, of ÖDK's¹ *Reisseck scheme*, have, directly above their foundation contacts, large base galleries with cross sections designed to follow the lines of force. Ensuring the same amount of stability, this design allowed concrete savings of some 10 %, which were particularly appreciated in view of the difficult access to the dam sites situated at elevations more than 2300 m above sea-level.

The same design was used for the 48 m-high *Neue Tauernmoos dam*, owned by ÖBB² and completed in 1973. The alignment of the right-hand lateral dam consists of

* Dipl.-Ing. Dr. techn. Dr. techn. h. c. Baurat h. c., retired Executive Director of Tiroler Wasserkraftwerke Aktiengesellschaft (TIWAG), Honorary Chairman of the Austrian National Committee on Large Dams.

¹ Österreichische Draukraftwerke AG, Klagenfurt.

² Österreichische Bundesbahnen, Generaldirektion, Vienna.

reverse curves following the rocky ridge on which it is founded. In the main dam portion which spans the valley cutting through the ridge, joints were grouted, which made it the first *economy type of gravity dam with arch action* ever to be built.

Since the end of the Second World War, preference has in general been given to arch dams. Among these, the 53 m-high *Hierzmann dam*, owned by STEWEAG³, is remarkable for its particular shape designed to fit an extremely *unsymmetrical valley cross section* without calling for major correction of the slopes.

As variable curvature of horizontal sections is an advantage in wide-span arch dams, *conic sections* are mainly used for the arch elements in Austria, as they allow continuous adjustment of dam curvature to the terrain. Thus, the Schlegeis dam, owned by TKW⁴ and completed in 1971, with an unusual length (770 m) in relation to its height (130 m), was given a curvature increasing towards the crown at crest level and towards the abutments in the lower dam portion.

As to concrete technology, it should be mentioned that *separation of ultra-fine particles* and dedusting of the sand fraction by means of decanting installations were introduced in 1952–1955 for the construction of the Mooser and Drossen dams (Kaprun scheme owned by TKW), totalling more than 1 million m³ in concrete. Achieving a substantial improvement of concrete quality and, in particular, frost resistance even with low cement contents, these measures have since been applied on all major concrete construction projects.

For the construction of its *Kölnbrein arch dam*, 200 m high and 1.6 million m³ in volume, completed in 1977, ÖDK applied a practice developed for the dams on the river Danube. This consisted of automatic water batching based on aggregate moisture as continuously measured by neutron gauges, so as to reduce scatter substantially. An Austrian type of climbing formwork designed for the Kölnbrein dam, with elements of up to 30 m² in surface area, was used for the Itaipú dam recently put into service on the Paraná in South America (with a concrete volume of 12 million m³, this is so far the largest concrete dam in the world).

As to embankment dams, remarkable progress has been made in the *placement of quarry-run rockfill material*. This is very well demonstrated by a comparison between the TIWAG⁵-owned Gepatsch and Finstertal dams, both about 150 m high. Whereas at the Gepatsch dam, completed in 1964, lifts were placed 2.0 m high and compacted by 8-ton vibratory rollers, lifts at the Finstertal dam, constructed between 1978 and 1980, had to be not higher than 1.0 or 0.75 m and had to be compacted by 15-ton vibratory rollers, partly with addition of water. This reduced deformations of the Finstertal Dam to about one-fifth, and horizontal displacement at the crest during first filling was not more than about 14 cm. Good compaction of the rockfill was important in rendering feasible the construction of a *96 m-high asphaltic concrete core* as an impervious element, which was the first continuously sloping core in an embankment of such height. Part of the upstream shoulder of the Finstertal dam rests on steeply sloping *rock surfaces polished by glacial action*, which had to be *roughened* by blasting notches into them. The required extent of roughening and notch dimensions were determined on the basis of systematic large-scale shear tests conducted at the Innsbruck university.

Screened talus material with a maximum particle size of 80 mm proved well suited for the impervious cores of the above mentioned Gepatsch and the 85 m-high Durlasboden embankment dams.

Asphalt concrete facings, much used on embankment dams in Austria, have conquered high-level sites exposed to severe climatic conditions such as those of KELAG's⁶ Fragant group of power developments situated at elevations around 2400 m above sea-level. An additional advantage is their suitability for stage-wise construction schemes. E.g. the Oscheniksee dam, having a final total height of 106 m and a facing height of 60 m, was constructed in four stages.

Satisfactory results obtained in the use of reinforced-concrete cores that had been in operation for some time gave rise to thorough investigations at the Innsbruck university with the aim of testing their suitability for high embankment dams. The result was that such cores are indeed suited provided sliding layers are applied on both sides to prevent excessive loading of the core by dam settlement.

Particularly *difficult foundation conditions* at TKW's Durlasboden and Eberlaste embankment sites and at Bolgenach, owned by VKW⁷, were overcome by special measures, on which detailed reports are available. Important progress has also been achieved in the field of *embankment dam instrumentation* as e. g.:

— *Horizontal plate gauges*, developed for TIWAG's Gepatsch dam as a simple means of determining from the dam surface horizontal displacement and settlement within the fill so as to obtain better information on the behaviour of high embankments. These gauges now form part of the standard instrumentation of high embankment dams as recommended by ICOLD.

— The *"suspended shaft" consisting of independent precast annular members* embedded in the fill of the Finstertal dam. This was the first to be made up of two staggered sections connected by a gallery to follow the slope of the core. Equipped with a tele-transmitted plumb line installation, this allows direct observation of embankment and core deformations as well as short paths for the great number of instrument leads towards the measuring station at the foot of the shaft, so as to reduce potential line failures.

— A new device developed for the measurement of transverse strain in the asphaltic concrete core of the Finstertal dam. This indicates changes in core density by means of magnetic field measurements, thus obviating the need of piercing the core.

In Austria strict official regulations have long been in force for the approval and supervision of large dams. Among these, the following deserve special mention:

— The *Staubeckenkommission*, a storage reservoir commission within the Ministry of Agriculture and Forestry, consisting of 25 experts in the various special fields of large dam construction and the various


³ Steirische Wasserkraft- und Elektrizitäts AG, Graz.

⁴ Tauernkraftwerke AG, Salzburg.

⁵ Tiroler Wasserkraftwerke AG, Innsbruck.

⁶ Kärntner Elektrizitäts-AG, Klagenfurt.

⁷ Vorarlberger Kraftwerke AG, Bregenz.



Philip Forchheimer (1852—1933)



Josef Stini (1880—1958)




Karl v. Terzaghi (1883—1963)



Arthur Casagrande (1902—1981)



Leopold Müller




Armin Schoklitsch (1888—1969)



Christian Veder (1907—1984)



Viktor Kaplan (1876—1934)



Hermann Grengg (1891—1978)

relevant sciences, and preparing interdisciplinary expertises on large dam projects.

- Incumbent on each dam owner is the nomination, for each dam, of a *person responsible*, who will be in charge of all matters of safety.

Additional knowledge concerning solids transport has been derived from evaluating sand trap flushings at the stream intakes of transbasin diversions needed to fill storage reservoirs. The preferred type of stream intake in the Alps is the horizontal-rack drowned weir, where solids carried along by streamflow settle in a sand catching chamber, which is flushed now and then by hand or automatically. For the Kaunertal development, an automatic trip mechanism based on the depth of accumulated solids was developed. This allowed for the first time routine determination of the intensity and the volume of solids transport in mountain streams, where use of the usual wire baskets is not possible.

4. New Developments in Power Conduit Construction

Other developments concern power conduits, which, in the case of high and medium heads, normally consist of power tunnel, surge tank, and penstock or pressure shaft.

The excavation of large-diameter tunnels and shafts in difficult ground has greatly been facilitated all over the world by the use of the New Austrian Tunneling Method. Its basic principles were developed for the excavation of the power tunnel of TIWAG's Imst power station on the Inn river in 1953—1956. The allowance that was made for the stand-up time as a function of the span of unsupported rock mass proved of great advantage in classifying rock mass.

Simple *concrete linings* are normally applied in the power tunnels, usually of major length, to save time and money. It was already during the Second World War that concrete pouring in annular sections, without longitudinal joints, by means of mobile steel formwork and a concrete pump was developed for the Kaprun scheme. This method is now generally applied. As a result of the poor tensile strength of concrete, major internal pressures can be absorbed only if the lining is *prestressed against the rock mass*. This idea was first translated into practice by the Austrian A. Kieser, whose *Kernring method* was patented in 1943. This consists of section-wise pressure grouting an annular space left free around the inner lining. Since its first application for the Valüla tunnel owned by VIW⁸, the Kernring method has been used in various power tunnels in Austria and abroad. A variant of this method, extended by the use of a knobbed foil, was applied for part of the power tunnel of the Kops scheme, owned by VIW.

A *prestressing method based on gap grouting*, developed by TIWAG for the Kaunertal scheme in the early sixties, provides for the construction joint between concrete lining and excavation surface, or preliminary lining, to be widened during the prestressing grouting so as to form a gap allowing the grouting pressure to become effective around the whole circumference and to seize also the rock mass around the opening. To facilitate gap formation, a parting agent, usually a whitewash spray or

plastic foil, is applied and the grouting system, normally consisting of plastic pipe with valve-like outlets, is placed before the inner lining is poured. The cost involved tends to be lower than that of conventional borehole grouting, whereas the grouting process proper, which tends to involve an increased grout absorption, takes less time by allowing continuous working.

Where major demands are made on watertightness, e. g. where the internal pressure level substantially exceeds the ground water level, a sealing foil with welded joints is placed as a parting agent. This has been the subject of various extensive investigations involving some novel testing set-ups. The smooth excavation surface of tunnels driven by machines lends itself very well to the application of sealing foils. Thus, a foil of 5 mm thickness was used for the low-lying 3.3 m-diameter power tunnel of the Langenegg power scheme, owned by VKW. The foil was applied in a transition length of 600 m, loaded with a maximum pressure of 35 bar, between a steel-lined section and simple concrete lining. The invert part of the foil was laid beneath the precast invert elements placed immediately behind the full-section tunnelling machine.

After having stood its test in the operation of the power tunnel of the Kaunertal scheme, the gap grouting method has been used for ever increasing loads, as e. g. on for the Kühtai upperstage of TIWAG's Sellrain-Silz scheme, over a length of 1.1 km with a diameter of 4.0 m and for static pressures of up to 48 bar and dynamic pressures of up to 70 bar, with foil being placed over about one-third of the total length; in South Africa, for the 1000 MW Drakensberg pumped storage scheme, over a length of 2.2 km with a diameter of 5.5 m and for a maximum internal pressure of 52 bar.

A condition of permanent prestressing against the rock mass and of a permanent good performance of the rock mass in picking up internal pressure is that the stresses present in the rock mass exceed the prestressing pressure, or the percentage of internal pressure to be absorbed by the ground. Otherwise there is a potential risk of failure. On the pressure shafts of the Sellrain-Silz scheme, the hydrofracturing method was used to determine whether sufficient stresses were present in the rock mass.

In *steel-lined pressure shafts*, satisfactory grouting of the circumferential gap is particularly important in that an open gap tends to impair substantially the participation of the rock mass in resisting to the internal pressure, and the safety against bulging. The *gap grouting method* consists of injecting cement grout through injection piping fixed to the outside of the steel-lining sections. This requires connexion bores smaller in number and diameter to be provided in the steel-lining than are needed for the usual borehole injections.

This method was applied in the construction of the pressure shaft of the Kaunertal scheme. As this structure has shown satisfactory performance under extreme loads, as confirmed by a great number of measurements, gap grouting has since been applied on a large number of steel-lined pressure shafts.

With the permissible grouting pressure being limited by the bulging safety of the steel-lining, larger grouting pressures can be applied if grouting is carried out with the steel-lining-full and under pressure. This was first tried in the pressure shaft, designed to withstand a max-

⁸ Vorarlberger Illwerke AG, Bregenz.

imum internal pressure of 140 bar, of KELAG's Osche-niksee scheme, with grout being injected through the main drain.

The stress-strain curve method, introduced in Austria more than 20 years ago, has proved an efficient means of designing and testing all types of linings, by clearly revealing the effects of a prestressing system or its changes, or those of a potential gap. The radial jack improved at that time by TIWAG allowed the yielding properties of the rock mass, tending to vary substantially along the circumference of the lining, to be exactly determined for the first time. The stress-strain curves obtained from this method can be used as such, without conversion, for lining design. Geophysical methods such as sound velocity measurement along radial boreholes have been used for the interpolation of measured values.

Damage so far experienced in steel-lined pressure shafts has mainly been caused by *bulging inward* under external pressure. Bulging that occurs during emptying, after the shaft has been placed into operation, is particularly annoying because the steel-lining may deform unnoticed over several hundreds of metres. The most vulnerable zones are the upper portions of pressure shafts where the lining has to be designed to withstand external pressure rather than internal pressure; and external pressure assumptions usually involve great uncertainties.

In order to *enhance bulging safety*, the following novel methods have been applied in Austria:

- *Filling the circumferential gap completely* by use of the gap grouting method, which experience gained at Kaunertal has shown to be more efficient if carried out after a pressure test of the shaft.
- *Anchoring the steel lining* in the concrete backfill by means of head bolt anchors instead of the normally used dowels and claws, which mainly act by shear. Austrian power companies, steel construction firms and universities have cooperated these last few years to study systematically the effect of such anchors on bulging resistance by means of a bulging test installation previously developed by TIWAG. Thus, reliable design is now possible provided, however, that the head bolt anchors are firmly embedded in the backfill concrete.
- Installation of an *inner concrete ring* as had already been applied earlier for the thin-walled steel-linings of the power tunnels of the Gerlos lower stage and the Kaunertal scheme. An improved version of this method was used in the upper portion of the power shaft, 2.7 m in internal diameter, of TIWAG's Sellrain-Silz lower stage. An inner ring of high-strength concrete B 500, 10 cm in wall thickness, was constructed of individual sections produced in a precast factory. The amount of time and money required by this method hardly exceeds that needed for protection against corrosion in conventional structures, but the permissible external pressure involved is much higher. This method is also planned to be applied in the pressure shaft of TKW's Ziller upper stage.

Ever since the construction of the Lünensee project, thrust blocks for *penstocks* have been constructed without concrete tops. In the Ausserfragant and Malta main stage penstocks, longitudinal forces are transmitted to the thrust block concrete foundations through

web plates with head bolt anchors, welded to the underside of the pipe. Following minor applications in the sag pipes of VIW's Upper Ill-Lünensee development, concrete embedded steel pipes in trenches have been used to a major extent on KELAG's Fragant power scheme. This method requires no thrust blocks even at pipe bends and allows better adjustment to the configuration of the terrain. Buried pressure pipes without expansion joints were used on several projects, e.g. on ÖDK's Reisseck storage scheme, over the lowest section of the penstock designed to resist a maximum pressure of 196 bar.

A main condition of the safe performance of penstocks and steel-linings subjected to major loadings is the use of durable structural steels resistant to brittle fracture. For this purpose, the much tested ALDUR steels have been available in Austria since Hauttmann started their development with VÖEST in 1948.

In the *surge tanks*, provided as oscillation absorbers between power tunnels and penstocks, the *reverse-flow control throttle*, first used by TIWAG on the Kaunertal development, has brought about a substantial reduction in dampening time, so that the increasing requirements of the power system have been satisfied without calling for an increase in surge tank volumes. The new type of surge tank, which affords particular advantages where major reservoir level variations are involved, has also been applied on TKW's Zemm-Ziller and ÖDK's Malta developments.

5. New Developments in the Run-of-river Schemes on Austria's Rivers

In Austria, rivers are mainly developed by *run-of-river schemes involving heads* of between 8 and 25 m. Continuous chains of power schemes exist over many river stretches. To answer local hydrological requirements and also for historical reasons, several *typical construction methods* have developed on a number of rivers.

The power schemes of the Austrian reach of the Danube, the only navigable river in this country, utilise a design flow of 2000 to 3150 m³/s and heads of 10 to 15 m. Out of the 11 planned projects, not including boundary reaches, eight are in operation and a ninth has been submitted for authorization of construction. Particulars of the Danube construction method developed by DoKW⁹ will be discussed later in this report.

On the *lower Inn*, where this river forms the boundary with Bavaria, development in common with Germany has been completed by ÖBK¹⁰ and IW¹¹, by the construction of five power projects with a design flow of 1000 m³/s and heads varying between 10 and 11 m. All the projects were constructed by use of a *flat construction method* introduced in the Bavarian section of the Inn. The construction method used on the Inn provides for no rising powerhouse structure, with a single gantry crane serving both the weir and the adjacent power station and placing the emergency gates for weir and turbines. Emergency gates are introduced from the tailwater on sloping tracks.

⁹ Donaukraftwerke AG, Vienna.

¹⁰ Österreichisch-Bayerische Kraftwerke AG, Simbach (Germany) and Braunau (Austria).

¹¹ Innwerke AG, Töging am Inn (Germany).

International cooperation, first practised on the Inn projects, proved a great advantage in connexion with the uniform construction and operation of the power stations.

On the other Austrian rivers lending themselves to development by series of low head power plants—in particular, the Drau, Mur, Enns, Traun, Salzach and Tyrolean Inn rivers, most of which allow a design flow of between 200 and 400 m³/s—the *conventional construction method* has preferably been used. This provides for a rising powerhouse structure adjacent to the weir and equipped with vertical-shaft Kaplan turbines, whereas bulb turbines are still rare. Local conditions at the sites of the great number of power projects constructed have given rise to the development of special features, which cannot be treated in this report.

A novelty that should, however, be mentioned in this context is the *pierhead power station*, first realised on the lower Drau, where the power units are accommodated in widened weir piers. On the model of the Inn flat construction method, the station is equipped with a main gantry crane serving the whole installation.

Some of the advantages of this design are the straight-line flow of both power water and flood water, more efficient handling of floating debris and bed load due to the absence of a power station bay, and the smaller total width, which is of particular importance in the case of minor heads. Where the so-called wet construction method with several successive construction pits is applied, the pierhead power station will allow earlier completion dates.

Apprehensions regarding increased personnel requirements because power units are not concentrated in a single hall, or of potential risks to the power station piers from ice or floods have not come true although the oldest power stations of this type have been in operation for forty years. Neither are such disadvantages expected to arise as remote plant control is now generally practised.

Since pierhead power stations were first built — Lavamünd and Dravograd on the river Drau, commissioned in 1943/44 and utilising a head of approximately 9 m and a flow of 400 m³/s, the following stations of this type, equipped with vertical-shaft Kaplan turbines, have been constructed:

- to 1960 — another four stations on the Yugoslav section of the Drau, each consisting of four weir bays and three turbine piers, utilising heads of between 14 and 17 m and flows of between 400 and 450 m³/s,
- to 1970 — the Weyer power station on the river Enns, owned by EKW¹², utilising a head of 16.5 m and having a single turbine pier for 125 m³/s and a diversion-type power station of equal capacity,
- to 1978 — Perach power station, owned by IW, on the river Inn, utilising a head of only 5 m and having three turbine piers for 510 m³/s,

to 1982 — Nussdorf power station, owned by ÖBK, on the Inn section forming the boundary between Bavaria and Tyrol, utilising a head of about 10 m and having two turbine piers for 550 m³/s,

to 1983 — Villach power station, owned by ÖDK, on the river Drau, utilising a head of about 10 m and having two turbine piers for 300 m³/s.

A similar method, using bulb turbines, was used on the Argentat power project in the Dordogne in France in the mid-fifties.

The following are features particular to the *Austrian Danube construction method*:

- *integrated construction method* by uniting the twin locks, the weir and the powerhouse in a single structure served by gantry cranes,
- use of the locks for the discharge of catastrophic floods, during which periods navigation has to be stopped anyway,
- water intake and discharge for lock operation from the headwater and to the tailwater above and below the weir rather than by the lock approaches,
- weir with five or six bays 24.0 m wide each, hydraulic-driven tainter gates with flaps,
- low powerhouse structure with nine large-capacity Kaplan bulb turbines.

The so-called *flat-country power stations* on the Austrian Danube are remarkable for the following features:

- dykes with sections overflowed by major floods to maintain flooding of the riverine woodlands and to accomplish a flood-retarding effect, tested on large-scale open air models,
- provision in these dykes of impervious cores consisting of particularly fine-grained riverside sand mixed with riverbed gravel, with deep slurry-trench or thin diaphragm cutoffs, the latter consisting of I-beams driven or jetted into place and a cement-based slurry being injected into the space forming as the beams are slowly withdrawn,
- construction in a single flood-free pit protected by cofferdams, most of which are sealed with plastic foil.

These features, combined with careful scheduling of design and construction, allowed the Greifenstein power scheme to be completed within a period of not more than 30 months, which is unusually short for the construction of a dam across a navigable river.

6. Environmental Requirements

The development of the Danube is also a convincing example of a regard for the environment that has long been a matter of course in water power development in Austria and is achieved by a design and construction aimed at minimum interference with the natural landscape. This has also been accomplished to a very large extent in the Austrian storage schemes.

Any unbiased visitor will realise that hydro power development in Austria at its present stage does no real harm to nature or landscape and, thus, can be continued with a good conscience.

¹² Ennskraftwerke AG, Steyr.

7. References

Chapter 3

Large dams in general

- Grenng, H.: Statistik 1971 der Talsperren, Kunstspeicher und Flußstauwerke. Schriftenreihe "Die Talsperren Österreichs", Heft 19. (Statistics 1971 of large dams, artificial reservoirs and run-of-river plants.)
- Lauffer, H.: Die Talsperren und Flußstauwerke Österreichs und der Wasserkraftausbau. Österreichische Wasserwirtschaft, 29. Jg. (1977), H. 9/10. (Austria's large dams and hydro power development.)
- Partl, R.: Statistik 1977 der großen Talsperren und Flußstauwerke Österreichs. Schriftenreihe "Die Talsperren Österreichs", Heft 24. (Translation published under the title of "Large Dams in Austria 1977".)

Concrete dams

- Dvorak, F.: Die neue Tauernmoosperre. ÖZE, 23. Jg. (1970), H. 1. (The new Tauernmoossee dam.)
- Fischer, E. and Grenng, H.: Die Gewölbemauern Salza und Hierzmann. Österreichische Bauzeitschrift (1951), H. 11/12. (The Salza and Hierzmann arch dams.)
- Fritsch, J., Steinböck, W., Wogrin, A.: Fortschritte in der Betontechnik des Massenbetons. Schriftenreihe des Österreichischen Wasserwirtschaftsverbandes, H. 34 (1957). (Progress in concrete engineering in the field of mass concrete.)
- Steinböck, W.: Die Staumauer am Großen Mühlendorfersee. Schriftenreihe "Die Talsperren Österreichs", H. 10 (1959). (The dam impounding the Grosse Mühlendorfersee lake.)
- Widmann, R. et al.: Die Bogengewichtsmauer Schlegeis. ÖZE, 25. Jg. (1972), H. 1/2. (The Schlegeis arch-gravity dam.)
- Widmann, R.: Developments in Austrian concrete dam construction. 13th ICOLD Congress, New Delhi 1979, GP 1.
- Widmann, R. et al.: Die Gewölbemauer Kölnbrein. ÖZE, 32. Jg. (1979), H. 1/2. (The Kölnbrein arch dam.)

Embankment dams

- Innerhofer, G. and Loacker, H.: The connexion of the core of the Bolgenach Dam to weathered marl. 14th ICOLD Congress, Rio de Janeiro 1982, R 15/Q 53.
- Kießling, H.: Examination and reinforcement of asphaltic surface sealing on dams situated in high mountain regions. 13th ICOLD Congress, New Delhi 1979, R 33/Q 49.
- Kropatschek, H. and Rienöbl, K.: The efficiency of the grout curtain of Durlassboden Dam and the construction of a deep cut-off wall for the Eberlaste earthfill dam of the Zemm hydroelectric scheme. 10th ICOLD Congress, Montreal 1970, R 15/Q 37.
- Pircher, W. and Schwab, H.: Roughening of smooth and steeply sloping rock surfaces in the foundation of Finstertal rockfill dam. 13th ICOLD Congress, New Delhi 1979, R 22/Q 48.
- Pircher, W. and Schwab, H.: Austria's Finstertal rockfill dam. Water Power and Dam Construction, June 1980.
- Pircher, W. and Schwab, H.: Der Staudamm Finstertal der Kraftwerksgruppe Sellrain-Silz in Tirol. Wasserwirtschaft, 70. Jg. (1980), H. 3. (The Finstertal rockfill dam of the Sellrain-Silz hydroelectric scheme in the Tyrol.)
- Pircher, W. and Schwab, H.: Monitoring and alarm equipment at the Finstertal and Gepatsch rockfill dams. 14th ICOLD Congress, Rio de Janeiro 1982, R 64/Q 52.
- Schober, W.: The interior stress distribution of the Gepatsch rockfill dam. 10th ICOLD Congress, Montreal 1970, R 10/Q 36.
- Schober, W.: Besonderheiten beim Entwurf, bei der Ausführung und im Verhalten österreichischer Staudämme. Österreichische Wasserwirtschaft, 29. Jg. (1977), H. 9/10. (Special features of the design, construction and behaviour of embankment dams in Austria.)

Schober, W. and Rostek, R.: The shear resistance in the interface of the fill material or the rock overburden and the bedrock. 13th ICOLD Congress, New Delhi 1979, R 56/Q 48.

Schober, W.: Concrete core diaphragm walls for high embankment dams. 14th ICOLD Congress, Rio de Janeiro 1982, R 12/Q 55.

Schwab, H.: Staudamm Gepatsch. Analysen zum langjährigen Verhalten (1962—1978). Österreichische Wasserwirtschaft, 31. Jg. (1979), H. 5/6. (Gepatsch embankment dam. Analysis of long-term behaviour 1962 to 1978.)

Dam supervision

Melbinger, R. and Niel, A.: Surveillance and emergency measures for dams in Austria. 14th ICOLD Congress, Rio de Janeiro 1982, GP 6.

Wurzer, E. and Grabmayr, P.: Authorisation and supervision of large dams in Austria. Österreichische Wasserwirtschaft, Jg. 29 (1977), H. 9/10 (English version).

Sediment transport

Lauffer, H. and Sommer, N.: Studies on sediment transport in mountain streams of the Eastern Alps. 14th ICOLD Congress, Rio de Janeiro 1982, R 28/Q 54.

Chapter 4

Tunnel excavation and supporting

Detzhofer, H.: 25 Jahre Gebirgsklassifizierung nach "Lauffer" im Wandel der Stollenbautechnik. Österreichische Wasserwirtschaft, 31. Jg. (1979), H. 5/6. (25 years of rock classification after Lauffer in the course of changing tunnel engineering.)

Müller, L.: Das Lauffer-Diagramm in Theorie und Praxis des Tunnelbaues. Österreichische Wasserwirtschaft, 31. Jg. (1979), H. 5/6. (The Lauffer Diagram in the theory and practice of tunnel construction.)

Seeber, G.: Entwicklung und derzeitiger Stand der Neuen Österreichischen Tunnelbauweise (NATM). Österreichische Wasserwirtschaft, 31. Jg. (1979), H. 5/6. (Development and present state of the New Austrian Tunnelling Method [NATM].)

Rabcewicz, L. v. and Pacher, F.: Die Elemente der Neuen Österreichischen Tunnelbauweise (NATM) und ihre geschichtliche Entwicklung. Österreichische Ingenieur-Zeitschrift, 18. Jg. (1975), H. 9. (The elements of the New Austrian Tunnelling Method [NATM] and its history.)

Pressure tunnel and pressure shaft linings:

Bonapace, B.: Die Druckschachtpanzerung der Kraftstufe Silz. Stahlbau-Rundschau, Nr. 53 (Okt. 1979). (The pressure shaft lining of the Silz power scheme.)

Bonapace, B.: Test and measurements for the pressure tunnels and shafts of the Sellrain-Silz hydroelectric power scheme with extremely high head. 5th ISRM Congress, Melbourne 1983, Vol. D.

Finger, W.: Die Baudurchführung des Druckstollens, des Wasserschlosses und des Druckschachtes des Kopswerkes. ÖZE, 23. Jg. (1970), H. 7. (The construction of the pressure tunnel, the surge tank and the pressure shaft of the Kops scheme.)

Finger, W. and Wieser, H.: Zur Aufnahme des Außendruckes bei Stollenpanzerungen — Neue Lösungen und ihre rechnerische Erfassung. Bauingenieur, 55. Jg. (1980), p. 241ff. (Absorption of external pressure by tunnel steel-linings — new solutions and their analysis.)

Grenng, H.: Das Großspeicherwerk Glockner-Kaprun. (Entwurf und Bauausführung 1938—1945.) Österreichische Bauzeitschrift, 7. Jg. (1952), H. 8 u. 10. (The Glockner-Kaprun large-scale storage scheme; design and construction 1938 to 1945.)

- Innerhofer, G.: Die Verwendung thermoplastischer Kunststofffolien im Kraftwerksbau. Österreichische Ingenieur-Zeitschrift, 11. Jg. (1968), H. 8. (The use of thermoplastic foils in hydro scheme construction.)
- Kieser, A.: Druckstollenbau. Springer-Verlag, Wien 1960. (Pressure tunnel construction.)
- Lauffer, H. and Seeber, G.: Design and control of linings of pressure tunnels and shafts, based on measurements of the deformability of the rock. 7th ICOLD Congress, Rome 1961, R 91/Q 25.
- Lauffer, H.: Vorspanninjektionen für Druckstollen. Bauingenieur, 43. Jg. (1968), H. 7. (Prestressing grouting for power tunnels.)
- Seeber, G.: Die Sicherheit von Druckschachtpanzerungen. Österreichische Ingenieur-Zeitschrift, 18. Jg. (1975), H. 3. (The safety of pressure shaft steel-linings.)
- Seeber, G.: Neue Entwicklungen für Druckstollen und Druckschächte. Österreichische Ingenieur-Zeitschrift, 18. Jg. (1975), H. 5. (New developments for pressure tunnels and pressure shafts.)
- Seeber, G.: Prestressing a power tunnel. Water Power and Dam Construction (1976), No. 4.
- Seeber, G.: Möglichkeiten und Grenzen im Druckstollenbau. Schweizer Ingenieur und Architekt, 99. Jg. (1981), H. 29. (Possibilities and limits of power tunnel construction.)
- Stefko, E.: Das Kraftwerk Langenegg. Österreichische Wasserwirtschaft, 35. Jg. (1983), H. 5/6. (The Langenegg power scheme.)
- Wellacher, H.: Hochdruckspaltinjektionen bei gefülltem Panzerrohr. ÖZE, 22. Jg. (1969), H. 10. (High-pressure gap grouting with a full steel-liner.)
- Widmann, R.: Die Kraftwerksgruppe Zemm-Ziller. Österreichische Wasserwirtschaft, 35. Jg. (1983), H. 5/6. (The Zemm-Ziller group of power schemes.)

Penstocks

- Beer, H.: Neue Wege im Rohrleitungsbau. ÖZE, 22. Jg. (1969), H. 10. (New methods in pipeline construction.)
- Fox, H.: Die Druckrohrleitung der Speicherstufe Reißbeck. ÖZE, 13. Jg. (1960), H. 6. (The penstock of the Reisseck storage scheme.)
- Gsell, G. and Fastner, E.: Die Druckrohrleitung des Kraftwerkes Malta. Bauingenieur, 50. Jg. (1975), H. 9. (The penstock of the Malta scheme.)
- Kießling, H.: Die Druckrohrleitung Wurten als Ergebnis einer neueren Entwicklung. ÖZE, 22. Jg. (1969), H. 10. (The Wurten penstock as a result of a recent development.)

Surge tanks

- Seeber, G.: Das Wasserschloß des Kaunertal-Kraftwerkes der TIWAG — Ein neuer Typ eines rückstromgedrosselten Kammerwasserschlosses. Schweizer Bauzeitung (1970), H. 1. (The surge tank of TIWAG's Kaunertal scheme — a new type of double-chamber surge tank with reverse flow throttle.)

Chapter 5

Run-of-river Schemes

- Baustädter, K.: Das Pfeilerkraftwerk aus heutiger Sicht. Österreichische Wasserwirtschaft, 31. Jg. (1979), H. 5/6. (The pierhead power station from a modern point of view.)
- Fenz, R.: Heutige und geplante Wasserkraftnutzung an der Donau. Wasser- und Energiewirtschaft, 65. Jg. (1973), H. 3/4. (Present and planned hydro power development on the Danube.)
- Fenz, R.: Flußstauwerke in Österreich. Österreichische Wasserwirtschaft, 29. Jg. (1977), H. 9/10. (Run-of-river schemes in Austria.)
- Fenz, R. and Neiger, F.: Hydraulic model tests as auxiliary means for a general plan of chain of dams on the Austrian river Danube. 12th ICOLD Congress, Mexico 1976, R 29/Q 46.
- Grassinger, H. and Kobilka, J.: Embankment and cofferdams for run-of-river stations on the Austrian stretch of the Danube river. 14th ICOLD Congress, Rio de Janeiro 1982, R 9/Q 55.
- Grenng, H. and Lauffer, H.: Das Kraftwerk im Strom (Pfeilerkraftwerk). Österreichische Wasserwirtschaft, 1. Jg. (1948), H. 9/10. (The power station in the river [pierhead power station].)
- Grenng, H.: Die Entwicklung des Pfeilerkraftwerkes. Österreichische Ingenieur-Zeitschrift, 4. Jg. (1961), H. 4. (The development of the pierhead power station.)
- Kobilka, J.: Der Österreichische Donauausbau — ein Bindeglied zwischen Ost und West. Schriftenreihe des Österreichischen Wasserwirtschaftsverbandes, H. 57 (1983). (The development of the Danube in Austria — a link between East and West.)
- Neiger, F.: Das Donaukraftwerk Greifenstein. Österreichische Wasserwirtschaft, 35. Jg. (1983), H. 5/6. (The Greifenstein power station on the Danube.)
- Various authors: Die Kraftwerkskette am Unteren Inn (Sonderheft). ÖZE, 20. Jg. (1967), H. 5. (The chain of power stations on the Lower Inn.)

Chapter 6

Environmental Requirements

- Fenz, R.: Laufwasserkraft und Umwelt. Österreichische Wasserwirtschaft, 27. Jg. (1975), H. 5/6. (Run-of-river plants and the environment.)
- Lauffer, H.: Auswirkungen der Speicherkraftwerke auf die Umwelt. Österreichische Wasserwirtschaft, 27. Jg. (1975), H. 5/6. (Environmental effects of storage schemes.)
- Lauffer, H.: Die Jahresspeicherwerke Österreichs. ÖZE, 36. Jg. (1983), H. 5. (Austria's seasonal storage schemes.)

Baurat h. c. Dipl.-Ing. Dr. techn. Dr. techn. e. h. H. Lauffer
Gramartstrasse 20
A-6020 Innsbruck

REGISTER OF
LARGE DAMS IN AUSTRIA

(including large river barrages)

(from ICOLD's World Register of Dams — 1984 Edition)

REGISTRE DES BARRAGES EN AUTRICHE REGISTER OF DAMS IN AUSTRIA

FOLIO No. 1

49

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19
L I N E N O	NOM DU BARRAGE NAME OF DAM	ANNÉE D'ACHÈ- VEMENT OF COMPLE- TION	SITUATION - LOCATION			SITUATION ET TYPE DE BARRAGE AND NATURE OF SEALING ELEMENT	HAUTEUR AU DESSUS DU FOND DE LA BASSE FOUR N.W.	LONGUEUR DE CRÊTE DE CRÊTE LENGTH OF CRÊTE (m)	VOLUME DU BARRAGE VOLUME CONTENT OF DAM (10 ³ m ³)	CAPACITÉ TOTALE DU RÉSÉROIR SURFACE OF GROSS CAPACITY OF RÉSÉROIR AREA (10 ³ m ²)	CAPACITÉ MAXIMALE DES ÉVACUA- TEURS MAXIMUM CAPACITY OF SPILL- WAYS (m ³ /h)	PROPRIÉTAIRE OWNER	BUREAU D'ÉTUDES ENGINEERING BY	CONSTRUCTEUR CONSTRUCTION BY	No.			
			COURS DEAU RIVER	VILLE LA PLUS PROCHE NEAREST CITY	ÉTAT OU DÉPAR- TEMENT STATE PROVINCE OR COUNTRY													
1	ERLAUFKLAMSE	1911	Erlauf	Mariazell	Lower Austria	PG	R 37	88	22	1720	160	N E W A G	N E W A G	N E W A G	1			
2	GOSAU	1911	Gosausee	Hallstatt	Upper Austria	TE	R/S 17	50	23	24700	60	O K A	Stern & Haferl	Stern & Haferl	2			
3	WESTAL	1913	Almbach	Hallein	Salzburg	PG	R 28	66	12	2000	470	Municipality Salzburg	Müller - Georgini	Municipality Salzburg	3			
4	LANCHALSEN	1924	Gr.Mühl	Rohrbach	Upper Austria	PG	R 17	117	10	800	400	O K A	G. Beutle	Spychinger & Hartmann	4			
5	STRUBKLAMN	1924	Almbach	Hallein	Salzburg	PG	R 36	86	9	2100	300 } 330	Municipality Salzburg	Mayrhofer	Pittel & Brausewetter	5			
6	LANCHAMN	1925	Teisitzsch	Voitsberg	Styria	PG	R 26	85	12	320	180 } 200	STEWEAG	STEWEAG	Steirisches Wasserbaudisat	6			
7	SPILLERSEE SOUTH	1925 (1965 a)	Kr. Alfenz	Bludenz	Vorarlberg	PG	R 39	298	66	13100	37	Federal Railways	Federal Railways	Innerbühner & Nayer	7			
8	SPILLERSEE NORTH	1925 (1965 a)	Kr. Alfenz	Bludenz	Vorarlberg	PG	R 28	200	27	1650	-	Federal Railways	Federal Railways	Innerbühner & Nayer	8			
9	PERNEGG	1927	Mur	Bruck/Mur	Styria	PG	R 25	161	24	1650	1500	STEWEAG	STEWEAG	n	9			
10	MINNITZ	1931	Mur	Bruck/Mur	Styria	PG	R 12	143	15	550	1500	STEWEAG	STEWEAG	n	10			
11	PACK	1931	Kr.Teisitzsch	Koglach	Styria	PG	R 33	183	39	3500	180	STEWEAG	STEWEAG	Alpenland Tiefbau	11			
12	VEDOMT	1931	Ill	Scheuns	Vorarlberg	PG	R 53	386	14	3200	122 } 175	V I W	Lahmayer & Co	J.V. Universale-Dyckerhoff et alia	12			
13	ENGINGENBOUEN	1940	Stubache	Mittersill	Salzburg	PG	R 29	68	11	420	140	Federal Railways	Federal Railways	Universale	13			
14	KIRCHBICHL	1941	Imn	Wörgl	Tyrol	PG	S 17	106	8	3500	2000	T I W A G	Innerbühner & Nayer	Innerbühner & Nayer	14			
15	SCHWABECK	1943	Drau	Völkmarkt	Carinthia	PG	R 34	141	160	26000	3500	Ö D K	Alpenelktrowerke Grzywnski	Art & Co	15			
16	MOTSCHLACH	1944	Mur	Bruck/Mur	Styria	PG	S 19	53	10	540	1200	STEWEAG	STEWEAG	n	16			
17	GERLOS	1945 (1944)	Serlosbach	Zell/Ziller	Tyrol	VA	R 39	69	10	880	265	T K W	Alpenelktrowerke - TKW	Unionbau	17			
18	LAVAMUND	1945	Drau	Völkmarkt	Carinthia	PG	R 19	144	52	3500	3500	Ö D K	Alpenelktrowerke	Art & Co	18			
19	STANING	1946	Enna	Steyr	Upper/Lower Austria	PG	S 27	160	72	15100	3500	E K W	Siemens	Holmann	19			
20	MURG	1947	Kapruner Ache	Zell/See	Salzburg	PG	R 19	73	11	2236	108	T K W	T K W	J.V. Rella et alia	20			
21	MURBACH	1948	Enna	Steyr	Upper/Lower Austria	PG	S 21	200	75	4900	3500	E K W	Siemens	Holmann	21			
22	SILVETTA	1948	Ill	Scheuns	Vorarlberg	PG	R 80	432	407	32100	164 } 165	V I W	V I W - Lahmayer	Kunz - Beton Monierbau	22			
23	Biel	1948	Ill	Scheuns	Vorarlberg	TE	R/S 25	730	375	110	-	V I W	V I W - Lahmayer	Kunz - Beton Monierbau	23			
24	HOLLERSBACH	1949	Hollersbach	Mittersill	Salzburg	TE	R/S 16	87	16	200	200	S A F E	S A F E - Interplan	Hinteregger - Fischer	24			
25	SALZA	1949	Kr. Enna	Liesen	Styria	VA	R 53	121	23	11000	140 } 148	STEWEAG	STEWEAG	Mayreder-Teintl & Spitz	25			

NOTES

FOOTNOTES a) Dam of 1925 raised by 4 m in 1965

Österr. Elektrizitätswerke AG
Energiekraftwerke AG
Kärntner Elektrizität AG
Tiroler Elektrizitätswerke AG
Vorarlberger Elektrizitätswerke AG
Oberösterreichische Kraftwerke AG

Salzburger Aktiengesellschaft f. Elektrizitätswirtschaft
Steirisches Wasserstraßen- und Elektrizitätswesen AG
Tiroler Elektrizitätswerke AG
Vorarlberger Elektrizitätswerke AG
Vorarlberger Elektrizitätswerke AG

Salzburger Aktiengesellschaft f. Elektrizitätswirtschaft
Steirisches Wasserstraßen- und Elektrizitätswesen AG
Tiroler Elektrizitätswerke AG
Vorarlberger Elektrizitätswerke AG
Vorarlberger Elektrizitätswerke AG

J.V. Joist Venture
n no data available

REGISTRE DES BARRAGES EN AUTRICHE REGISTER OF DAMS IN AUSTRIA

FOLIO No. 2

50

19

18

17

16

15

14

13

12

11

10

9

8

7

6

5

4

3

2

1

L G N E	NOM DU BARRAGE NAME OF DAM	ANNÉE D'ACHÈVEMENT YEAR OF COMPLETION	SITUATION - LOCATION			SITUATION ET TYPE D'ÉTAN- CHÉMENT AND POSITION OF SEALING ELEMENT	HAUTEUR AU DESSUS DU FOND HEIGHT ABOVE FOUN- DATION (m)	LON- GUEUR DE CRÊTE LENGTH OF CREST (m)	VOLUME DU BARRAGE VOLUME CONTENT (10 ³ m ³)	CAPACITÉ TOTALE DU RESERVOIR GROSS CAPACITY OF RESERVOIR (10 ³ m ³)	CAPACITÉ MAXI- MALE DES TÉLÉ- TELS MAXIMUM DIS- CHARGE CAPACITY OF WAYS (m ³ /h)	TYPE DES TÉLÉ- TELS TYPE OF WAYS	PROPRIÉTAIRE OWNER	BUREAU D'ÉTUDES ENGINEERING BY	CONSTRUCTEUR CONSTRUCTION BY	No.
			VILLE LA PLUS PROCHE CITY	COURS D'EAU RIVER	ÉTAT PROVINCE OU DÉPAR- TEMENT STATE NEAREST CITY											
1	TERNBERG	1949	Enns	Enns	Steyr Austria	PG	29	140	95	37000	2500	V	E K W	Stahlwerke Linz (VOEST)	Asst & Co	1
2	GROSSANING	1950	Enns	Enns	Meyer Austria	PG	41	122	225	17100	2420	V	E K W	Siemens	Kunz - Rella	2
3	HIERZMANN	1950	Teigitzsch	Teigitzsch	Küflach Styria	VA	58	172	43	2600	1800	L	STEWEAG	STEWEAG	Asst - Universale	3
4	RANNA	1950	Ranna	Ranna	Rothenbach Austria	VA	65	126	32	2230	160	L	O K A	Beurle - Grenng	Ferro Betonit - Teiml & Spitz	4
5	BÄCHENTAL	1950	Dürrenbach	Dürrenbach	Jenbach Tyrol	VA	34	70	3	none	150	L	TIWAG	TIWAG	Asst & Co	5
6	LDHBERG	1951	Kapruner Ache	Kapruner Ache	Zell/See Salzburg	VA	120	357	466	86000	900	V	T K W		J.V. Rella et alia	6
7	MÖLL	1952	Möhl	Möhl	Heiligenblut Carinthia	VA	93	164	35	13500	64	V	T K W		Port	7
8	Margareitze	1952	Margareitze	Margareitze	Heiligenblut Carinthia	PG	39	170	33	2100	274	L	T K W		Port	8
9	THURNBERG	1952	Kamp	Kamp	Worm Austria	PG	25	248	69	2500	500	V	NEHAG	Siemens Bautechnik	Mayreder Kraus	9
10	WEISSEE	1952	Tr. Stabach	Tr. Stabach	Mittersill Salzburg	PG	39	235	64	16000	23	L	Federal Railways	Federal Railways	Kunz	10
11	DOBRA	1953	Kamp	Kamp	Zwettl Lower Austria	VA	52	234	90	21000	500	L	NEHAG	Siemens Bautechnik	Rella	11
12	ROSENAU	1953	Enns	Enns	Steyr Austria	PG	25	140	100	28000	2275	V	E K W		Mayreder-Hambberger-Akt	12
13	WIEDERSCHING	1953	Weissenbach	Weissenbach	Villach Carinthia	VA	30	74	8	1200	108	L/V	KELAG	KELAG	Mayreder, Teiml & Spitz	13
14	BRANNAU-SIMBACH	1954	Ilon	Ilon	Braunau Upper Austria	PG	22	240	140	36000	6200	V	Usterr.-Bayer. Kraftwerke AG	Usterr.-Bayer. Kraftwerke AG	J.V. Ast & Co - Sager	14
15	GSTATTERBODEN	1955	Enns	Enns	Hierflau Styria	PG	18	45	9	8500	1000	V	STEWEAG	STEWEAG	Mayreder, Teiml & Spitz	15
16	MOOSER	1955	Kapruner Ache	Kapruner Ache	Zell/See Salzburg	PG	107	494	665	87000	1300	V	T K W		J.V. Rella et alia	16
17	Drosen	1955	Kapruner Ache	Kapruner Ache	Zell/See Salzburg	VA	112	357	355	16600	160	V	T K W		J.V. Rella et alia	17
18	JOCHENSTEIN	1956	Danube	Danube	Engelhartsdorf Upper Austria	PG	20	383	440	50000	11000	V	Donaukraftwerk Jochenstein	Donaukraftwerk Jochenstein	J.V. Rella et alia	18
19	OTTENSTEIN	1956	Kamp	Kamp	Zwettl Lower Austria	PG	69	240	124	21000	436	V	NEHAG	Siemens Bautechnik	J.V. Rella et alia	19
20	RUNSEAU	1956	Ilon	Ilon	Landeck Tyrol	PG	16	52	14	9000	750	V	TIWAG	TIWAG	Polensky - Hintersberger - Polensky - Unionbau	20
21	GROSSER HILFENFEE	1957	Tr. Möll	Tr. Möll	Spittal Carinthia	PG	46	433	153	27000	17	L	UDK	UDK	J.V. Universale et alia	21
22	ROTGLUNDENSEE	1957	Tr. Mur	Tr. Mur	St. Michael Salzburg	ER	18	112	35	29000	61	L/V	SAPE	SAPE - Pösch	Polensky Zöllner - Heins - Ferro Betonit	22
23	AMERSEE	1958	Tr. Salzach	Tr. Salzach	Mittersill Salzburg	PG	30	162	20	5500	8	L	Federal Railways	Federal Railways	Kunz - Unionbau	23
24	FREITACH	1958	Tr. Drau	Tr. Drau	Perlach Carinthia	TE	41	150	235	3500	208	L	KELAG	KELAG	Isola - Weiss & Freitag	24
25	ROCHALMSEE	1958	Tr. Möll	Tr. Möll	Spittal Carinthia	PG	24	120	29	4100	15	L/V	UDK	UDK	J.V. Universale et alia	25

NOTES
FOOTNOTES

*) Border Dam Austria/Fed. Rep. Germany, owned by bi-national power company.

SAPE Salzburger Abtriebsgesellschaft f. Elektrizitätswirtschaft
STEWEAG Steirische Elektrizitätswerke AG
TIWAG Tiroler Kraftwerke AG
UDK Oberösterreichische Kraftwerke AG
VNW Vorarlberger Kraftwerke AG

DOKW Österreichische Donaukraftwerke AG
ENW Ennstalwerke AG
KEW Kärntner Elektrizitätswerke AG
KEMAG Kärntner Elektrizitätswerke AG
ODK Oberösterreichische Kraftwerke AG
OKA Oberösterreichische Kraftwerke AG

J.V. Joint Venture
n no data available

NOTES	1000/NOTES	*) Border Dem Austria/Fed. Rep. Germany, owned by bi-national power company.	DokW	Usterreichtische Donaukraftwerke AG	SAFE	Salzburger Aktiengesellschaft f. Elektrizitäts- wirtschaft	J.V. Joint Venture n no data available
			ENW	Ennskraftwerke AG	STENAG	Steirische Wasser- und Elektrizitäts AG	
			KEIAG	Kleinener Elektrizitäts AG	TIWAG	Tiroler Wasserkraftwerke AG	
			NUWAG	Niederösterreichische Elektrizitätswerke AG	TEW	Tauernkraftwerke AG	
			ÖEW	Österreichische Elektrizitätswerke AG	VIEW	Vorarlberger Illwerke AG	
			ORA	Oberösterreichische Kraftwerke AG	VZW	Vorarlberger Kraftwerke AG	

Kalzbürger Aktiengesellschaft f. Elektricitäts- versorgungs-Gesellschaft	J.V. Joint Venture n no data available
Deutsche Wasserkraft- und Elektrizitäts AG	
Eisner Maschinenfabrik AG	
Gewerkschaftwerke AG	
Forscherberger Werke AG	
Vereinigte Kraftwerke AG	

DoKW	Österreichische Donaukraftwerke AG
EWK	Einkaufskraftwerke AG
KELAG	Kärntner Elektrizitäts AG
NEWMAG	Niederösterreichische Elektrizitätswerke AG
ÖDK	Österreichische Druckkraftwerke AG
ÖKA	Oberösterreichische Kraftwerke AG

- a) replaced and submerged seller dam of same name but 2cm lower, built from 1926 to 1929
- b) stepwise construction as planned; first dam of 1972 raised in 1973, 1976 and 1979 by 7+20+10m.
- c) Dam of 1974 raised by 10m in 1978/79.

REGISTRE DES BARRAGES EN AUTRICHE REGISTER OF DAMS IN AUSTRIA

FOLIO No. 5

53

1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19
L I G N E	NOM DU BARRAGE NAME OF DAM	ANNÉE D'ACHÈVEMENT YEAR OF COMPLETION	SITUATION - LOCATION			T Y P E	SITUATION ET TYPE D'ÉTAN- CHÉMENT POSITION AND NATURE OF SEALING ELEMENT	F O U N D A T I O N	HAUTEUR AU DESSUS DU DÉLAPELUS N O T A T I O N HEIGHT A B O V E T H E C R E S T OF CREST	LON- GUEUR DE CRÊTE LENGTH OF CREST (m)	VOLUME DU BARRAGE VOLUME OF DAM (10 ³ m ³)	CAPACITÉ DU RÉSERVOIR GROSS CAPACITY OF RESERVOIR (10 ³ m ³)	O C C U P I E D C A P A C I T Y O F C O U N T E R S I N C U B I C M E T R E (10 ³ m ³)	CAPACITÉ MAXI- MALE DES ÉVACUA- TEURS MAXIMUM CAPACITY OF W A Y S (m ³ /h)	TYPE DES ÉVACUA- TEURS TYPE OF S P I L L W A Y S	PROPRIÉTAIRE OWNER	BUREAU D'ÉTUDES ENGINEERING BY	CONSTRUCTEUR CONSTRUCTION BY
L I G N E	NOM DU BARRAGE NAME OF DAM	ANNÉE D'ACHÈVEMENT YEAR OF COMPLETION	VILLE LA PLUS PROCHE NEAREST CITY	ÉTAT PROVINCE OU DÉPAR- TEMENT STATE PROVINCE OR COUNTRY														
1	ARMINDEN-ASTEN	1979	Danube	Mautausen	Upper Austria	PC	PC	R	31	395	850	46000 9500	H, N	8400 1000	V	D O K W		J.V. Nayerder-Pella-Porr Hofman Maculan et alia
2	MACHITTENK	1979	Traun	Belz	Upper Austria	PC	PC	R	38	98	100	25000 2200	H	2300	V	O K A	Siemens Bautechnik	J.V. Nayerder et alia
3	FINSTERTAL	1980	tr. Neder- bach	Ötz	Tyrol	ER	ER	R/S	150	652	4500	10000 10000	H, N	200	V	T I W A G	T I W A G	J.V. Hochleit-Obermannmeyer- Strabag et alia
4	LÄNGENTAL	1980	Nederbach	Ötz	Tyrol	TE	TE	R/S	37	418	400	3300 2200	H	126	V	T I W A G	T I W A G	Strabag-TS Bau-Stettin- Inneebner
5	ANNABRÜCKE	1981	Drau	Klagenfurt	Carinthia	PC	PC	S	40	104	108	36000 3500	H	3300	V	Ö D K	Ö D K	J.V. Nayerder-Porr et alia
6	ROCKHARTSEE	1982	tr. Gastel- ner Ache	Badgastein	Salzburg	ER	ER	R	33	238	225	14800 410	H	44	V	S A F E	S A F E - Siemens Bau- technik	Porr
7	RODERDORF	1982	Mur	Murau	Styria	PC	PC	R	23	67	30	290 100	H	560	V	S T E W E A G	S T E W E A G	Hinterberger-Fritz
8	PAAL (Bodenort)	1982	tr. Mur	Murau	Styria	PC	PC	R	39	118	20	330 330	H	200	L/V	S T E W E A G	S T E W E A G	Strabag-TS Bau-Stettin
9	MELK	1982	Danube	Melk	Lower Austria	PC	PC	R/S	29	442	900	54000 7500	H, N	11170	V	D O K W	D O K W	J.V. Nayerder-Pella-Porr Hofman Maculan et alia
10	SPIELFELD	1982	Mur	Leibnitz	Styria	PC	PC	S	19	99	27	13000 240	H	1660	V	S T E W E A G	S T E W E A G	Universale
11	TRAUN-PÜCKING	1982	Traun	Linz	Upper Austria	PC	PC	R	45	101	110	7600 830	H	2300	V	O K A	Siemens Bautechnik	J.V. Nayerder et alia
12	HEINZDÖL	1982	Mur	Graz	Styria	PC	PC	R	20	93	n	n	H	1800	V	Steiernmärktische Elektrizi- tät AG (S T E O)	Steiernmärktische Elektrizi- tät AG (S T E O)	Art - Nayerder - VUGEST
13	ZIMMER	1983	tr. Mill	Heiligenblut	Carinthia	ER	ER	R	44	315	525	8700 1000	H	12	L	K E L A G	K E L A G	Strabag
14	GREIFENSTEIN	1984	Danube	Stockerau	Lower Austria	PC	PC	R/S	31	455	n	27000 1000	H, N	8640 2110	V	D O K W	D O K W	J.V. Nayerder-Pella-Porr Hofman Maculan et alia
15	MELLACH	1985	Mur	Wildon	Styria	PC	PC	S	20	87	26	1180 300	H	1650	V	S T E W E A G	S T E W E A G	Universale
16	ZILLERGRUNDL	1986	Ziller	Mayrhofen	Tyrol	VA	VA	R	186	506	1355	9000 1410	H	663 50	V	T K W	T K W	J.V. Hofman Maculan et alia
17																		
18																		
19																		
20																		
21																		
22																		
23																		
24																		
25																		

NOTES
FOOTNOTES

DOK Österreichische Donaukraftwerke AG
 KTAG Kraftwerke Tagtau AG
 NEMAG Niederösterreichische Elektrizitätswerke AG
 OBK Oberösterreichische Donaukraftwerke AG
 ORA Oberösterreichische Kraftwerke AG
 SAFE Salzburger Aktiengesellschaft f. Elektrizitäts-
 wirtschaft
 STEIRAG Steirische Elektrizitätswerke AG
 TRK Tiroler Kraftwerke AG
 VIK Vorarlberger Kraftwerke AG
 VKW Vöcklabruck Kraftwerke AG
 J.V. Joint Venture
 n no data available

The "Austrian National Committee on Large Dams" would like to thank the Federal Chamber of Commerce and the construction firms listed below for their essential contribution to the publication of this Special Issue:

Allgemeine Baugesellschaft — A. Porr
Aktiengesellschaft

Hofman & Maculan
Bauaktiengesellschaft

Ilbau AG

Bauunternehmung Innerebner & Mayer
Gesellschaft m. b. H.

Ing. Karl Jäger
Unternehmung für Hoch- und Tiefbau

Mayreder, Keil, List & Co.
Baugesellschaft m. b. H.

Polensky & Zöllner
Baugesellschaft m. b. H.

Strabag
Baugesellschaft m. b. H.

Stuag
Straßen- und Tiefbau-Unternehmung
Aktiengesellschaft

Universale-Bau
Aktiengesellschaft

Ed. Züblin Aktiengesellschaft
Bauunternehmung
Niederlassung Wien

The Chairman
W. Pircher

The Secretary
R. Weiss



Finstertal dam (centre) and Längental dam (right)
 (photo released for publication by BMLV unter Zl. 13080/252 — 1. 6./82)



Gepatsch dam (Tiroler Wasserkraftwerke Aktiengesellschaft — TIWAG)



Mooserboden reservoir with Drossen and Mooser dams as well as Wasserfallboden reservoir with Limberg dam (Tauernkraftwerke Aktiengesellschaft — TKW)
(photo released for publication by BMLV under Zl. 13080/347 — 1.6./82)



Margaritze dam (left) and Möll dam (right)



Schlegeis dam (Tauernkraftwerke Aktiengesellschaft — TKW)



Oscheniksee dam (Kärntner Elektrizitäts-Aktiengesellschaft — KELAG)




Tauernmoos dam (Österreichische Bundesbahnen — ÖBB)



Kölnbrein dam



Annabrunnen dam and power plant (Österreichische Draukraftwerke Aktiengesellschaft — ÖDK)
(photo released for publication by BMLV under ZI. 13080/479-1981)



Lavamünd power station on the Drau river, the first pier head power station
(Österreichische Draukraftwerke AG — ÖDK)



Losenstein power station on the Enns river (Ennskraftwerke AG — EKW)



Wallsee-Mitterkirchen power station on the Danube (Österr. Donaukraftwerke AG — DoKW)
(photo released for publication by BMLV under ZI. 13080/463-1. 6./79)

